

**Peak Load Report of transformers at Various 400kV/220 KV /132 KV GSS under Jaipur Zone during FY2015 - 16**

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16
		Voltage Ratio(KV)	Capacity (MVA)	
1	2	3	4	5
220 kV GSS Chomu	Jaipur	220/132	160	111
		220/132	160	111
		132/33	40/50	68
		132/33	20/25	
		132/11	10/12.5	17
		132/11	10/12.5	
132 kV GSS Rampura-dabri	Jaipur	132/33	20/25	20
		132/33	20/25	23
132 kV GSS Markhi	Jaipur	132/33	20/25	22
		132/33	20/25	21
132 kV Govindgarh	Jaipur	132/33	20/25	20
		132/33	20/25	20
		132/33	40/50	32
		33/11	2x5	8
132 kV GSS Jatawali	Jaipur	132/33	20/25	4
132 kV GSS Kaladera	Jaipur	132/33	20/25	21
		132/33	40/50	36
220 kV GSS Mansarovar	Jaipur	132/33	40/50	44
		132/33	40/50	45
		220/132	160	83
		220/132	160	99
132 kV GSS SMS Stadium	Jaipur	132/33	37.5/50	40
		132/33	37.5/50	40
220 kV GSS Phulera	Jaipur	220/132	100	72
		220/132	100	71
		132/33	20/25	13
		132/33	20/25	13
132 kV GSS, Jobner	Jaipur	132/33	20/25	13
		132/33	10/12.5	10
220 kV GSS NPH, Jaipur	Jaipur	220/132/11	160	114
		220/132/11	160	53
		132/33	40/50	45
		132/33	40/50	38
		132/33	20/25	23
		132/11	10/12.5	22
132/11	10/12.5			
132 kV GSS, PWD Bunglow, Jaipur	Jaipur	132/33	37.5/50	42
		132/33	37.5/50	34
220 kV GSS Duni	Tonk	220/132	100	82
		220/132	50	46
		132/33	20/25	11
		132/33	6/8	off
132 kV GSS R Deoli (TONK)	Tonk	132/33	20/25	21
		132/33	10/12.5	11
132 kV GSS Malpura	Tonk	132/33	10/12.5	8
		132/33	10/12.5	8
132 kV GSS Todaraisingh	Tonk	132/33	20/25	11
		132/33	10/12.5	10
132 kV GSS Tonk	Tonk	132/33	20/25	17
		132/33	40/50	29
		132/11	10/12.5	11
132 kV GSS Uniara	Tonk	132/33	20/25	15
		132/33	10/12.5	9

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16	
		Voltage Ratio(KV)	Capacity (MVA)		
1	2	3	4	5	
132 kV GSS Thadoli	Tonk	132/33	20/25	12	
		132/33	20/25	12	
132 kV GSS Newai	Tonk	132/33	20/25	24	
		132/33	20/25	24	
132 kV GSS Chambal	Jaipur	132/33	40/50	34	
		132/33	40/50	41	
		132/11	16/20	15	
		132/11	16/20		
		132/11	10/12.5	16	
		132/11	16/20		
132 kV GSS Jawahar Nagar	Jaipur	132/33	40/50	40	
		132/33	40/50	45	
		132/33	40/50	38	
		132/11	2X10/12.5	18	
220 kV GSS VKIA	Jaipur	220/132	160	85	
		220/132	100	77	
		132/33	40/50	45	
		132/33	40/50	45	
		132/33	40/50	21	
132 kV GSS Sarna Doongar	Jaipur	132/33	20/25	16	
132 kV GSS VKIA Jaipur	Jaipur	132/33	25	23	
		132/33	25	28	
		132/33	50	50	
		132/33	50	50	
		132/11	12.5	11	
		132/11	12.5	11	
132 kV GSS New Jhotwara	Jaipur	132/33	37.5/50	0	
		132/33	37.5/50	0	
132 kV GSS Champapura KAlwar Road Jaipur	Jaipur	132/33	20/25	16	
		132/33	20/25	9	
220 kV GSS I.G.NAGAR	Jaipur	220/132	100	108	
		220/132	100	107	
		132/33	50	40	
		132/33	50	32	
132 kV GIS,MNIT	Jaipur	132/33	37.5/50	34	
		132/33	37.5/50	45	
220 kV GSS Renwal	Jaipur	220/132	100	88	
		220/132	100	98	
		132/33	20/25	21	
		132/33	20/25	21	
		132/33	10/12.5	10	
132 kV GSS , Hingonia	Jaipur	132/33	20/25	21	
		132/33	20/25	21	
		132/33	20/25	21	
220 kV GSS Dausa	Dausa	220/132	160	137	
		220/132	100	78	
		132/33	40/50	30	
		132/33	20/25	16	
		132/11	10/12.5	12	
		132/11	6	5	
132 kV GSS Dhaula Kunwa	Dausa	132/33	20/25	23	
132 kV GSS , Toonga	Jaipur	132/33	20/25	21	
		132/33	20/25	22	
132 kV GSS , Andhi	Jaipur	132/33	20/25	18	

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16	
		Voltage Ratio(KV)	Capacity (MVA)		
1	2	3	4	5	
132 kV GSS Bassi	Jaipur	132/33	40/50	44	
		132/33	20/25	23	
		33/11	5	4	
		33/11	5	4	
220 kV GSS Gangapur city	Sawai Madhopur	220/132	100	100	
		132/33	20/25	21	
132 kV GSS Gangapur city	Sawai Madhopur	132/33	20/25	21	
		132/33	20/25	20	
		132/11	10/12.5	6	
132 kV GSS Baroli(SWM)	Sawai Madhopur	132/33	20/25	15	
		132/33	10/12.5	6	
132 kV GSS Batoda	Sawai Madhopur	132/33	20/25	15	
220 kV GSS Kunda Ki Dhani	Jaipur	220/132	160	109	
		132/33	20/25	20	
		132/33	20/25	19	
		132/33	10/12.5	11	
		132/11	6	6	
220 kV GSS Kotputli	Jaipur	220	100	98	
		220	100	94	
		220	100	98	
		132	40/50	50	
		132	20/25	25	
		132	20/25	25	
132 kV GSS Keshwana	Jaipur	132	20/25	16	
		132	20/25	17	
132 kV GSS Paota	Jaipur	132	20/25	20	
		132	20/25	19	
220 kV GSS Kukas	Jaipur	220/132	100	85	
		220/132	100	58	
		132/33	10/12.5	10	
		132/33	16/20	13	
		33/11	8	6	
132 kV GSS Jamwa Ramgarh	Jaipur	132/33	20/25	25	
		132/33	10/12.5	8	
220 kV GSS Lalsot	Dausa	220/132	100	92	
		132/33	40/50	47	
		132/33	20/25	25	
132 kV GSS, Bagdi (Dausa)	Dausa	132/33	20/25	13	
132 kV GSS Nagal pyariwas	Dausa	132/33	20/25	19	
220 kV GSS Mandawar	Dausa	220/132	100	82	
		220/132	100	82	
		132/33	20/25	22	
		132/33	20/25	22	
132 kV GSS D.Bheem	Dausa	132/33	40/50	22	
132 kV GSS Mahuwa	Dausa	132/33	20/25	22	
132 kV GSS Bandikui	Dausa	132/33	20/25	18	
		132/33	20/25	20	
220 kV GSS Manoharpur	Jaipur	220/132	100	85	
		220/132	100	85	
		132/33	20/25	25	
		132/33	40/50	35	

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16
		Voltage Ratio(KV)	Capacity (MVA)	
1	2	3	4	5
132 kV GSS Shahpura	Jaipur	132/33	20/25	22
		132/33	40/50	26
		132/11	10/12.5	11
132 kV GSS BILWADI	Jaipur	132/33	20/25	25
220 kV GSS Sikrai	Dausa	220/132	100	80
		132/33	20/25	16
		132/33	20/25	14
132 kV GSS Sikandra	Dausa	132/33	20/25	25
		132/33	20/25	25
		132/33	10/12.5	12
220 kV GSS Sawai Madhopur	SAWAI MADDHOPUR	220/132	100	90
		220/132	100	90
		132/33	20/25	23
		132/33	40/50	37
		132/11	10/12.5	8
132 kV GSS Bhadoti	Sawai Madhopur	132/33	20/25	22
		132/33	10/12.5	10
133 kV GSS Khandar	Sawai Madhopur	132/33	20/25	20
		132/33	10/12.5	10
		132/33	10/12.5	10
132 kV GSS Purana Ghat	Jaipur	132/33	40/50	34
		132/33	40/50	33
		132/11	10/12.5	6
220 kV GSS Baran	Baran	220/132	100	97
		220/132	100	97
		132/33	20/25	5
132 kV GSS Sangod	Kota	132/33	20/25	20
		132/33	20/25	20
132 kV GSS Baran	Baran	132/33	40/50	41
		132/33	40/50	41
132 kV GSS Kelwara	Baran	132/33	20/25	24
		132/33	10/12.5	13
		132/33	15/20	20
132 kV GSS Bapawar	Kota	132/33	20/25	18
220 kV GSS Bundi	Bundi	220/132	100	85
	Bundi	220/133	100	80
	Bundi	133/33	20/25	11
132 kV GSS Hindoli	Bundi	132/33	20/25	22
	Bundi	132/33	10/12.5	11
132 kV GSS Lakheri	Bundi	132/33	10/12.5	12
	Bundi	132/33	10/12.5	12
	Bundi	132/11	6	5
132 kV GSS Nainwa	Bundi	132/33	20/25	20
	Bundi	132/33	10/12.5	11
	Bundi	132/33	20/25	22
132 kV GSS Bundi	Bundi	132/33	20/25	23
	Bundi	132/33	20/25	24
	Bundi	132/33	10/12.5	12
	Bundi	132/11	16/20	7
132 kV GSS Talera	Bundi	132/33	20/25	25
	Bundi	132/33	20/25	26
132 kV GSS Deoli-Manjhi	Kota	132/33	20/25	24
		132/33	10/12.5	12
132 kV GSS Mandana, Town Kota	Kota	132/33	20/25	21

Name of GSS	Distt.	Transformer		Peak load in MVA in	
		Voltage Ratio(KV)	Capacity (MVA)	FY	2015-16
1	2	3	4	5	
220 kV GSS Dahra	Kota	220/132	100	65	
		220/132	100	50	
		132/33	25	20	
		132/33	12.5	10	
		132/33	25	17	
132 kV GSS Itawa	Kota	132/33	20/25	16	
		132/33	10/12.5	9	
132 kV GSS Anta	Baran	132/33	10/12.5	9	
		132/33	20/25	17	
132 kV GSS Sultanpur	Kota	132/33	20/25	21	
220 kV GSS Kawai	Baran	220/132	100	90	
		220/132	100	90	
		132/33	20/25	22	
		132/33	20/25	22	
132 kV GSS Atru	Baran	132/33	20/25	20	
		132/33	20/25	20	
132 kV GSS, Kolukheri	Baran	132/33	20/25	14	
132 kV GSS, Chipabarod	Baran	132/33	10/12.5	10	
		132/33	10/12.5	10	
		132/33	20/25	15	
132 kV GSS Khanpur	Jhalawar	132/33	20/25	22	
		132/33	20/25	22	
220 kV GSS Modak	Kota	220/132	100	95	
		220/132	100	91	
		132/33	20/25	18	
		132/33	20/25	18	
132 kV GSS Mayla	Kota	132/33	20/25	20	
		132/33	20/25	25	
132 kV GSS Hemda	Jhalawar	132/33	20/25	22	
		132/33	10/12.5	11	
		132/33	10/12.5	11	
132 kV GSS Dug	Jhalawar	132/33	10/12.5	10	
		132/33	20/25	24	
		132/33	20/25	21	
132 kV GSS Bhawani Mandi	Jhalawar	132/33	1x20/25	24	
		132/33	1x20/25	24	
220 kV GSS Sakatpura Kota	Kota	220/132	160	151	
			100	81	
			100	85	
			100	89	
		132/33	20/25	24	
			40/50	36	
132 kV GSS Gopal Mill	Kota	132/33	40/50	35	
		132/33	20/25	25	
132 kV GSS IA Kota	Kota	132/33	40/50	42	
		132/33	16/20	13	
		132/33	40/50	37	
		132/33	20/25	23	
		132/31	15.75/31.5	11	
		132/31	16/20	18	
132 kV GSS M.Nagar Kota	Kota	132/33	40/50	47	
		132/33	40/50	48	
220 kV GSS Jhalawar	Jhalawar	220	100	99	
			100	99	
132 kV GSS Kanwari	Jhalawar	132/33	20/25	14	
			10/12.5	OFF	

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16
		Voltage Ratio(KV)	Capacity (MVA)	
1	2	3	4	5
132 kV GSS Manoharthana	Jhalawar	132/33	20/25	21
			10/12.5	12
132 kV GSS Aklera	Jhalawar	132/33	20/25	22
			20/25	19
132 kV GSS Bakani	Jhalawar	132/33	20/25	20
			10.12.5	11
			10/12.5	10
220 kV GSS Bhiwadi	Alwar	220 /132 ,	160	110
		220 /132 ,	160	125
		220 /132 ,	100	62
		132 /33	40 /50	36
		132 /33	40 /50	36
		132 /33	20 /25	21
		132/11	16 /20	12
132 kV GSS Bhiwadi	Alwar	132/33	40/50	37
		132/33	20/25	23
		132/33	20/25	23
		132/11	16/20	14
		132/11	16/20	14
		132/11	10	7
220 kV GSS, Alwar	Alwar	220/132	160	122
		220/132	160	122
		220/132	100	80
		132/33	40/50	39
		132/33	40/50	39
		132/33	20/25	26
		132/11	16/20	7.11
132 kV GSS, Rajgarh	Alwar	132/33	20/25	22
		132/33	20/25	22
		33/11	5	5
132 kV GSS, Thanagazi	Alwar	132/33	20/25	13
		132/33	20/25	17
		132/33	10/12.5	12
		132/33	10/12.5	12
132 kV GSS Pinan	Alwar	132/33	20/25	14
		132/33	20/25	14
132 kV GSS Narayanpur	Alwar	132/33	20/25	24
132 kV GSS Bansur	Alwar	132/33	40/50	36
		132/33	20/25	22
		132/33	20/25	23
		132/11	10/12.5	12
132 kV GSS Bayana	Bharatpur	132/33	20/25	25
		132/33	40/50	47
132 kV GSS Roopwas	Bharatpur	132/33	25	18
220 kV GSS , Kishangarh bas	Alwar	220/132	100	86
		220/132	100	98
		132/33	20/25	22
		132/33	20/25	22
		132/33	20/25	22
132 kV GSS ,Tizara	Alwar	132/33	20/25	20
		132/33	20/25	19
		132/33	10/12.5	10
132 kV GSS , Pur-Kotkasim	Alwar	132/33	20/25	24
		132/33	20/25	20

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16	
		Voltage Ratio(KV)	Capacity (MVA)		
1	2	3	4	5	
220 kV GSS Nadbai	Bharatpur	220/132	100	94	
		220/132	160	108	
		132/33		22	
		132/33	20/25	22	
		132/33	20/25	22	
132 kV GSS Nagar	Bharatpur	132/33	12.5	10	
		132/33	12.5	12	
		132/33	25	25	
		132/33	50	37	
132 kV GSS Weir	Bharatpur	132/33	10/12.5	10	
		132/33	20/25	21	
		132/33	20/25	21	
(132 kV GSS) , Bhusawar	Bharatpur	132/33	20/25	23	
		132/33	10/12.5	9	
		132/33	20/25	19	
220 kV GSS MIA -Alwar	Alwar	220/132	100	92	
		220/132	100	82	
		132/33	40/50	36	
		132/33	20/25	25	
		132/33	20/25	25	
132 kV GSS Ramgarh	Alwar	132/33	40/50	39	
		132/33	20/25	25	
		132/33	20/25	23	
132 kV GSS Malakhera	Alwar	132/33	20/25	22	
		132/33	20/25	21	
132 kV GSS Laxmangarh	Alwar	132/33	20/25	25	
		132/33	20/25	25	
		132/33	20/25	24	
132 kV GSS Kherli (Alwar)	Alwar	132/33	20/25	26	
		132/33	14/20	18	
132 kV GSS Govind Garh	Alwar	132/33	20/25	17	
220 kV GSS Behror	Alwar	220/132	160	62	
		132/33	20/25	13	
132 kV GSS Behror	Alwar	132/33	20/25	23	
		132/33	20/25	23	
		132/33	20/25	23	
		132/11	10/12.5	11	
220 kV GSS , Bharatpur	Bharatpur	220/132	100	96	
		220/132	100	71	
		220/132	100	88	
		132/33	20/25	20	
		132/33	20/25	20	
132 kV GSS , Bharatpur	Bharatpur	132/33	20/25	22	
		132/33	20/25	22	
		132/11	10	4	
132 kV GSS , Kumher	Bharatpur	132/33	20/25	16	
		132/33	10/12.5	7	
132 kV GSS , Deeg	Bharatpur	132/33	10/12.5	12	
		132/33	10/12.5	12	
132 kV GSS , Kaman	Bharatpur	132/33	10/12.5	9	
		132/33	10/12.5	9	
		132/33	20/25	18	

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16	
		Voltage Ratio(KV)	Capacity (MVA)		
1	2	3	4	5	
220 kV GSS Khushkhera	Alwar	220/132	100	94	
		220/132	100	94	
		132/33	40/50	41	
		132/33	20/25	22	
		132/33	20/25	22	
132 kV GSS Chopanki I/A	Alwar	132/33	40/50	44	
		132/33	40/50	46	
220 kV GSS Neemrana	Alwar	220/132	100	81	
		220/132	100	77	
		220/132	100	81	
		132/33	20/25	23	
		132/33	40/50	35	
		132/33	40/50	37	
132 kV GSS, Shahjahanpur	Alwar	132/33	20/25	23	
		132/33	20/25	23	
		132/33	10/12.5	13	
132 kV GSS, Mandan	Alwar	132/33	20/25	17	
		132/33	20/25	17	
132 kV GSS Jakhrana	Alwar	132/33	20/25	16	
		132/33	20/25	16	
132 kV GSS Mundawar	Alwar	132/33	20/25	25	
		132/33	20/25	24	
		132/33	20/25	23	
220 kV GSS, Chaksu	Jaipur	220/132	160	138	
		132/33	20/25	21	
		132/33	20/25	21	
220 kV GSS Sanganer	Jaipur	220/132	100	99	
		220/132	100	79	
		132/33	40/50	38	
		132/33	20/25	19	
		132/33	40/50	37	
		132/11	10/12.5	10	
132 kV GSS Phagi	Jaipur	132/33	20/25	13	
132 kV GSS Balawala	Jaipur	132/33	20/25	3	
		132/33	20/25	3	
220 kV GSS Bagru	Jaipur	220/132	100	96	
		220/132	100	87	
		132/33	20/25	25	
		132/33	40/50	41	
132 kV GSS,Dudu	Jaipur	132/33	20/25	16	
			10/12.5	10	
132 kV GSS,, Bagru	Jaipur	132/33	20/25	19	
		132/33	20/25	19	
		132/33	10/12.5	9	
		132/11	16/20	10	
		132/11	10/12.5	9	
220 kV GSS SEZ	Jaipur	220/132	100	9	
		132/33	20/25	9	
132 kV GSS,Sirsi	Jaipur	132/33	40/50	37	
		132/33	40/50	26	
		33/11	5	4	
		33/11	3.15	3	
220 kV GSS Heerapura	Jaipur	220/132	160	100	
		220/132	160	96	
		220/132	100	95	
		220/132	160	114	



Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16
		Voltage Ratio(KV)	Capacity (MVA)	
1	2	3	4	5
132 kV GSS,Bhankrota	Jaipur	132/33	20/25	14
		132/33	20/25	14
		33/11	5	5
		33/11	5	5
132 kV GSS VaishaliNagar	Jaipur	132/33	40 /50	41
		132/33	40 /50	39
220 kV GSS Sitapura	Jaipur	220/132/11	160	73
132 kV GSS Sitapura	Jaipur	132/33	50	43
		132/33	50	43
220 kV GSS NPH, Jaipur	Jaipur	220/132/11	160	114
		220/132/11	160	53
		132/33	40/50	45
		132/33	40/50	38
		132/33	20/25	23
		132/11	10/12.5	21
		132/11	10/12.5	
400 kV GSS Heerapura	Jaipur	400/220	250	194
		400/220	250	166
		400/220	250	181
		400/220	315	232
400 kV GSS Hindaun	Karauli	400/220/33	315	267
		400/220/33	315	270
220 kV GSS Dholpur	Dholpur	220/132	100	92
		220/132	100	85
		132/33	40/50	38
		132/33	20/25	23
		132/33	20/25	23
		132/11	10/12.5	8
		132/11	6.3/8	6
132 kV GSS Rajakhera	Dholpur	132/33	20/25	22
		132/33	20/25	22
132 kV GSS Baseri	Dholpur	132/33	20/25	22
		132/33	10/12.5	18
132 kV GSS Maniya	Dholpur	132/33	10/12.5	0
		132/33	20/25	18
132 kV GSS Sarmathura	Dholpur	132/33	20/25	16
		132/33	10/12.5	8
220 kV GSS Hindaun	Karauli	220/132	100	98
		220/132	100	98
		220/132	50	49
		132/33	20/25	23
		132/33	20/25	23
		132/33	10/12.5	7
		132/33	20/25	21
132 kV GSS ,Todabheem	Karauli	132/33	20/25	21
		132/33	20/25	21
132 kV GSS Karauli	Karauli	132/33	20/25	21
		132/33	40/50	37
132 kV GSS Kailadevi	Karauli	132/33	20/25	22
132 kV GSS Sapotra	Karauli	132/33	20/25	22
			10/12.5	11
132 kV GSS ,Shri Mahaveer Ji	Karauli	132/33	20/25	19
		132/33	20/25	19
132 kV GSS Nangal sherpur	Karauli	132/33	20/25	23

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16
		Voltage Ratio(KV)	Capacity (MVA)	
1	2	3	4	5
132 kV GSS Gudachander Ji	Karauli	132/33	20/25	22
765 kV GSS ANTA	Baran	765/400	3X500 ICT BANK -I	1132
		765/400	3X500 ICT BANK -III	1126
765 kV GSS Phagi	Jaipur	765/400	3X500 ICT BANK -I	1225
		765/400	3X500 ICT BANK -III	1221

**Peak Load Report of transformers at Various 400kV/220 KV / 132 KV GSS under  
Ajmer Zone during FY2015 - 16**

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16
		Voltage Ratio(KV)	Capacity (MVA)	
1	2	3	4	5
220 kV GSS Ajmer	Ajmer	220/132	160	139
		220/132	160	139
		132/33	20/25	19
		132/33	20/25	21
		132/33	40/50	35
		132/33/11	7.5	1
		132/33/11	7.5	1
132 kV GSS Saradhana	Ajmer	132	20/25	24
		132	40/50	37
132 kV GSS MDSU Ajmer	Ajmer	132/33	40/50	24
		132/33	20/25	14
132 kV GSS Subhash Nagar	Ajmer	132/33	20/25	4
132 kV GSS Pushkar Road	Ajmer	132/33	20/25	14
		132/33	20/25	16
132 kV GSS Pushkar	Ajmer	132/33	20/25	17
		132/33	20/25	17
220 kV GSS Kishangarh	Ajmer	220/132/11	100	86
		220/132/11	100	86
		132/33	20/25	12
132 kV GSS Kishangarh	Ajmer	132/33	40/50	25
		132/33	20/25	17
		132/33	20/25	22
		132/11	2x 10/12.5	16
132 Roopangarh	Ajmer	132/33	20/25	24
		132/33	20/25	21
132 kV GSS Silora	Ajmer	132/33	20/25	19
		132/33	20/25	22
220 kV GSS Beawar	Ajmer	220/132	100	79
		220/132	100	77
		220/132	100	71
		132/33	20/25	21
		132/33	40/50	41
		132/33	20/25	22
		132/11	16/20	3
132 kV GSS Kekri	Ajmer	132/33	20/25	21
		132/33	10/12.5	11
		132/33	20/25	21
132 kV GSS Masuda	Ajmer	132/33	20/25	12
132kV GSS Nasirabad	Ajmer	132/33/11	12.5/7.5/5	8
		132/33	20/25	24
132 kV GSS Sawar	Ajmer	132/33	10/12.5	11
132 kV GSS Suwana	Bhilwara	132/33	20/25	22
		132/33	40/50	27

**Peak Load Report of transformers at Various 400kV/220 KV / 132 KV GSS under  
Ajmer Zone during FY2015 - 16**

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16
		Voltage Ratio(KV)	Capacity (MVA)	
132 kV GSS Danta	Bhilwara	132/33	20/25	16
		132/33	20/25	19
132 kV GSS Partapura	Bhilwara	132/33	20/25	6
132 kV GSS L Raila	Bhilwara	132/33	20/25	13
		132/33	10/12.5	11
132 kV GSS Jahajpur	Bhilwara	132/33	20/25	18
132 RIICO Bhilwara	Bhilwara	132/33	40/50	29
		132/33	20/25	21
132 kV GSS Karera Bhilwara	Bhilwara	132/33	20/25	16
		132/33	20/25	12
220 kV GSS Hamirgarh	Bhilwara	220/132	100	78
		220/132	100	88
		132/33	20/25	25
		132/33	20/25	23
		132/33	40/50	41
132 kV GSS Asind	Bhilwara	132/33	10/12.5	11
		132/33	20/25	24
132 kV GSS Bidgod	Bhilwara	132/33	20/25	19
		132/33	20/25	18
132 kV GSS Bijoliya	Bhilwara	132/33	20/25	20
		132/33	20/25	14
132 kV GSS Kachhola	Bhilwara	132/33	20/25	21
132 kV GSS Mandalgarh	Bhilwara	132/33	20/25	24
		132/33	20/25	24
132 kV GSS Gangapur	Bhilwara	132/33	20/25	16
		132/33	20/25	17
132 kV GSS Raipur	Bhilwara	132/33	20/25	14
220 kV GSS Gulabpura	Bhilwara	220/132	100	91
		220/132	100	90
		132/33	20/25	20
		132/33	20/25	20
		132/11	7.5	3
132 kV GSS Shahpura	Bhilwara	132/33	20/25	16
400 GSS Bhilwara	Bhilwara	400/220/33	315	280
		400/220/33	315	318
220 kV GSS Bhilwara	Bhilwara	220/132	160	134
		220/132	160	130
		220/132	100	89
		132/33	20/25	24
		132/33	20/25	24
		132/33	40/50	44
		132/33	20/25	23
		132/11	12.5	4
220 kV GSS Kankroli	Rajsamand	220/132	100	85
		220/132	100	70
132 kV GSS Kankroli	Rajsamand	132/33	40/50	17
		132/33	20/25	12
132 kV GSS Nathdwarra	Rajsamand	132/33	20/25	20

**Peak Load Report of transformers at Various 400kV/220 KV / 132 KV GSS under Ajmer Zone during FY2015 - 16**

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16
		Voltage Ratio(KV)	Capacity (MVA)	
132 kV GSS Nandawra	Rajsamand	132/33	20/25	23
132 kV GSS Sapol	Rajsamand	132/33	20/25	17
220 kV GSS Bamantukada	Rajsamand	220/132	160	71
		132/33	20/25	18
132 kV GSS Mokhampura	Rajsamand	132/33	40/50	29
		132/33	20/25	20
132 kV GSS AMET	Rajsamand	132/33	20/25	20
		132/33	20/25	21
132 kV GSS Deogarh	Rajsamand	132/33	20/25	15
		132/33	10/12.5	8
220 kV GSS Aspur	Dungarpur	220/132	100	77
		132/33	20/25	14
132 kV GSS Dungarpur	Dungarpur	132/33	20/25	24
		132/33	40/50	47
132 Seemalwara	Dungarpur	132/33	20/25	13
132 Sagwara	Dungarpur	132/33	20/25	17
		132/33	20/25	22
220 kV GSS Debari	Udaipur	220/132	100	97
		220/132	100	92
		220/132	160	143
		220/132	160	103
		220/132	40/50	34
		132/33	14.6/20	18
		132/33	16/20	14
132 kV GSS Bhinder	Udaipur	132/33	10/12.5	11
		132/33	20/25	21
132 kV GSS Bhatewar	Udaipur	132/33	20/25	22
		132/33	20/25	19
132 kV GSSZawar mines	Udaipur	132/33	16/20	7
		132/33	16/20	7
132 kV GSS Sanwad	Udaipur	132/33	20/25	17
132 kV GSS Dakankotda	Udaipur	132/33	20/25	23
132 kV GSS Sukher	Udaipur	132 / 33	20/25	15
		132 / 33	40/50	29
132 kV GSS Pratapnagar Udaipur	Udaipur	132/33	20/25	21
		132/33	40/50	32
132 kV GSS Kherwara	Udaipur	132/33	10/12.5	12
132 kV GSS Rishabhdeo	Udaipur	132/33	16/20	17
		132/33	20/25	18
132 kV GSS Salumber	Udaipur	132/33	10/12.5	9
		132/33	20/25	21
220 kV GSS Madri	Udaipur	220/132	100	84
		132/33	20/25	17
		132/33	20/25	16
		132/33	40/50	30
132 kV GSS SisramaUdaipur	Udaipur	132/33	40/50	22
		132/33	20/25	18
132 kV GSS Mavli	Udaipur	132/33	10/12.5	11

**Peak Load Report of transformers at Various 400kV/220 KV / 132 KV GSS under  
Ajmer Zone during FY2015 - 16**

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16
		Voltage Ratio(KV)	Capacity (MVA)	
132 kV GSS Mavli	Udaipur	132/33	20/25	17
132 kV GSS Gogunda	Udaipur	132/33	20/25	13
132 kV GSS Dariba	Udaipur	132/33	20/25	18
		132/33	20/25	11
132 kV GSS Jhadol	Udaipur	132/33	20/25	15
220 kV GSS Banswara	Banswara	220/132	100	65
		220/132	100	77
		132/33	40/50	37
		132/33	20/25	31
132 kV GSS Partpur	Banswara	132/33	20/25	19
132 kV GSS Paloda	Banswara	132/33	20/25	17
132 kV GSS Bagidora	Banswara	132/33	20/25	20
		132/33	10/12.5	9
132 kV GSS Kushalgarh	Banswara	132/33	20/25	12
132kV GSS Choti Sadri	Pratapgarh	132/33	20/25	25
	Pratapgarh	132/33	10/12.5	12
	Pratapgarh	132/11`	10/12.5	6
132 kV GSS Dhariyawad	Pratapgarh	132 / 33	20/25	17
	Pratapgarh	132 / 33	20/25	4
132 kV Gss Dalot	Pratapgarh	132/33	20/25	21
	Pratapgarh	132/33	10/12.5	11
132 kV GSS Pratapgarh	Pratapgarh	132/33	20/25	20
		132/33	40/50	39
220kV GSS Nimbahera	Chittorgarh	220/132	100	80
		220/132	160	104
		132/33	20/25	20
		132/33	20/25	20
		132/33	40/50	34
132 kV GSS Mangalwar	Chittorgarh	132/33	20/25	20
		132/33	20/25	20
132 kV GSS Badisadri	Chittorgarh	132/33	40/50	26
		132/33	20/25	24
132 kV GSS Bhadesar	Chittorgarh	132/33	20/25	23
		132/33	20/25	22
220 kV GSS Chittorgarh	Chittorgarh	220/132	100	80
		220/132	100	81
		220/132	100	70
		132/33	40/50	28
		132/33	20/25	21
		132/11	6.3/8	3
132 kV GSS Kapasan	Chittorgarh	132 /33	40/50	27
		132 /33	20/25	17
132kV GSS Bassi	Chittorgarh	132/33	20/25	22
132 kV GSS Baroli Rawatbhata	Chittorgarh	132/33	10/12.5	12
		132/33	10/12.5	12
132kV GSS Rashmi	Chittorgarh	132/33	20/25	22
132 kV GSS Ajoliy Ka Khera	Chittorgarh	132/33	20/25	20
		132/33	20/25	19

**Peak Load Report of transformers at Various 400kV/220 KV / 132 KV GSS under  
Ajmer Zone during FY2015 - 16**

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16
		Voltage Ratio(KV)	Capacity (MVA)	
132 kV GSS Begun	Chittorgarh	132/33	20/25	21
	Chittorgarh	132/33	20/25	21
132kV GSS RAPP	Chittorgarh	132/33	10/12.5	12
		33/11	3.15	2
220kV GSS Sawa	Chittorgarh	220/132	160	104
		220/132	100	86
		132/33	20/25	16
		132/33	10/12.5	8
132kV GSS Senth	Chittorgarh	132/33	20/25	10
		132/33	40/50	14
132 kV GSS Rasoolpura	Chittorgarh	132/33	20/25	14
220kV GSS Jhunjhunu	Jhunjhunu	220/132	100	64
		220/132	100	87
		220/132	100	72
		132/33	20/25	9
132 kV GSS Kumawas	Jhunjhunu	132/33	20/25	18
		132/33	20/25	21
132 kV GSS Jhunjhunu	Jhunjhunu	132/33	40/50	23
		132/33	20/25	24
132 kV GSS Bagar	Jhunjhunu	132/33	10/12.5	7
		132/33	20/25	14
132kV GSS Bissau	Jhunjhunu	132/33	20/25	14
		132/33	10/12.5	10
132 kV GSS Mandwa	Jhunjhunu	132/33	10/12.5	12
		132/33	20/25	20
132 kV GSS Bherunda Kalan	Jhunjhunu	132/33	20/25	22
		132/33	20/25	17
132 kV GSS UdaipurWATI	Jhunjhunu	132/33	20/25	20
		132/33	20/25	8
132 kV GSS Malsisar	Jhunjhunu	132/33	10/12.5	3
		220/33	35	14
220kV GSS Khetri Nagar	Jhunjhunu	220/33	35	26
		220/33	50	21
		220/132	100	69
		220/132	100	59
		220/132	100	63
		132/33	20/25	18
132 kV GSS Gudagorji	Jhunjhunu	132/33	20/25	18
		132 / 11	10/12.5	9
		132/33	20/25	16
132kV GSS Buhana	Jhunjhunu	132/33	20/25	12
		132/33	40/50	34
		132/33	20/25	19
		132/33	20/25	19
132 kV GSS Nawalgarh	Jhunjhunu	132/33	40/50	31
		132/33	20/25	19
220 kV GSS Chirawa	Jhunjhunu	220/132	100	86
		132/33	100	84
		132/33	20/25	14

**Peak Load Report of transformers at Various 400kV/220 KV / 132 KV GSS under  
Ajmer Zone during FY2015 - 16**

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16
		Voltage Ratio(KV)	Capacity (MVA)	
		132/33	40/50	41
132 kV GSS Nangali	Jhunjhunu	132/33	20/25	11
		132/33	20/25	11
132 kV GSS Pilani	Jhunjhunu	132/33	20/25	8
		132/33	40/50	22
		132/11	10/12.5	7
132 kV GSS Sultana	Jhunjhunu	132/11	10/12.5	7
		132/33	20/25	14
132 kV GSS Sultana	Jhunjhunu	132/33	20/25	14
		132/33	20/25	14
132kV GSS Dulaniya	Jhunjhunu	132/33	20/25	13
		132/33	20/25	13
132 kV GSS Surajgarh	Jhunjhunu	132/33	10/12.5	9
		132/33	20/25	17
132 kV GSS Mandrella	Jhunjhunu	132/33	20/25	15
		132/33	20/25	15
132kV GSS Babai	Jhunjhunu	132/33	20/25	19
		132/33	20/25	16
220 kV Dhod	Sikar	220/132	100	80
		220/132	100	80
		132/33	40/50	36
		132/33	20/25	23
		132/33	20/25	23
132 kV Losal	Sikar	132/33	20/25	12
		132/33	20/25	14
132kV GSS PatanSikar	Sikar	132/33	20/25	21
		132/33	20/25	21
132 kV GSS Khood	Sikar	132/33	20/25	12
		132/33	20/25	12
132kV GSS Kachawa	Sikar	132/33	10/12.5	8
		132/33	20/25	22
220kV GSS Laxmangarh	Sikar	220/132	100	63
		132/33	40/50	28
		132/33	20/25	21
132 kV GSS L Fatehpur	Sikar	132/33	20/25	18
		132/33	20/25	18
132 kV GSS Antroli	Sikar	132/33	20/25	22
220 kV GSS Reengus	Sikar	220/132	160	159
		220/132	160	142
		132/33	20/25	20
		132/33	20/25	20
		132/33	20/25	20
132 kV GSS RIICO Reengus	Sikar	132/33	20/25	20
		132/33	20/25	19
132.kV.GSS.Ajeetgarh	Sikar	132/33	20/25.	21
		132/33	20/25.	19
132 kV GSS DantaSikar	Sikar	132/33	40/50	33
		132/33	20/25	21
132 kV GSS Srimadhampur	Sikar	132/33	20/25	19
		132/33	20/25	19



**Peak Load Report of transformers at Various 400kV/220 KV / 132 KV GSS under  
Ajmer Zone during FY2015 - 16**

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16
		Voltage Ratio(KV)	Capacity (MVA)	
132kV GSS Thoi	Sikar	132/33	20/25	17
132 kV GSS Sanwalpura Tanwaran	Sikar	132/33	10/12.5	10
132 kV GSS Khatushyamji	Sikar	132/33	20/25	17
		132/33	20/25	17
132 kV GSS Khandelamod	Sikar	132/33	20/25	15
132 kV GSS Khachariyawas	Sikar	132/33	20/25	24
		132/33	10/12.5	9
220 kV GSS Sikar	Sikar	220/132	100	83
		220/132	160	144
		220/132	160	120
		132/33	40/50	36
		132/33	20/25	24
		132/33	20/25	21
		132/33	40/50	42
132kV GSS Ranoli	Sikar	132/33	20/25	18
		132/33	20/25	18
132kV GSS Piprali	Sikar	132/33	20/25	22
		132/33	20/25	23
132kV GSS Kudan	Sikar	132/33	20/25	21
		132/33	20/25	17
132kV GSS Neemkathana	Sikar	132/33	40/50	34
		132/33	20/25	23
400kV GSS Merta City	Nagaur	400/220	315	286
		400/220	315	273
		220/132	100	85
		220/132	100	79
		220/132	100	79
132 kV GSS Merta city	Nagaur	132/33	40/50	32
		132/33	10/12.5	32
		132/33	20/25	
132kV GSS Lamba Jatan	Nagaur	132/33	20/25	16
		132/33	20/25	16
132 kV GSS Bherunda	Nagaur	132/33	20/25	39
		132/33	16-20	
132kV GSS Gotan	Nagaur	132/33	10/12.5	10
		132/33	40/50	29
220 kV GSS Khinvsar	Nagaur	220/132	100	76
		220/132	100	76
		132/33	40/50	30
		132/33	20/25	20
		132/33	20/25	20
132 kV GSS Heesaba	Nagaur	132/33	40/50	30
		132/33	20/25	23
132 kV GSS Narwa	Nagaur	132/33	20/25	15
		132/33	20/25	15
		220/132	100	82
		220/132	100	78

**Peak Load Report of transformers at Various 400kV/220 KV / 132 KV GSS under  
Ajmer Zone during FY2015 - 16**

Name of GSS	Distt.	Transformer		Peak load in MVA in FY 2015-16
		Voltage Ratio(KV)	Capacity (MVA)	
220kV GSS Kuchaman City	Nagaur	132/33	40/50	31
		132/33	20/25	22
		132/33	20/25	22
132kV GSS Chitawa	Nagaur	132/33	10/12.5	12
		132/33	20/25	24
132kV GSS Dayalpura	Nagaur	132/33	20/25	9
132kV GSS Molasar	Nagaur	132/33	20/25	18
		132/33	20/25	18
132kV GSS Deedwana	Nagaur	132/33	20/25	18
		132/33	20/25	19
220 kV GSS Nagaur	Nagaur	220/132	100	76
		220/132	100	76
		220/132	100	44
		132/33	20/25	22
		132/33	40/50	34
		132/33	20/25	22
		132/11	2X6.3/8	2
132 kV GSS Mundwa	Nagaur	132/33	20/25	9
		132/33	20/25	10
132 kV GSS Deh	Nagaur	132/33	20/25	10
132 kV GSS Sanjoo	Nagaur	132/33	20/25	14
		132/33	20/25	21
		132/33	40/50	34
132 kV GSS Jayal	Nagaur	132/33	20/25	15
		132/33	20/25	15
132 kV GSS Kuchera	Nagaur	132/33	20/25	24
		132/33	10/12.5	11
		132/33	40/50	35
		132/11	10/12.5	10
220 kV GSS Makrana	Nagaur	220/132	100	82
		220/132	100	82
		132/33	40/50	41
		132/33	20/25	18
		132/11	10/12.5	8
132 kV GSS Bagot	Nagaur	132/33	20/25	16
		132/33	20/25	14
132 kV GSS Nawa City	Nagaur	132/33	20/25	18
		132/33	40/50	23
132 kV GSS Bidiyad	Nagaur	132/33	20/25	13
		132/33	20/25	13
132 kV GSS Roon	Nagaur	132 /33	20/25	19
		132 /33	20/25	19
132 kV GSS Merta Road	Nagaur	132/33	20/25	24
		132/33	20/25	24
		132/33	40/50	30

**Peak Load Report of transformers at Various 400kV/220 KV /132 KV GSS under Jodhpur Zone during FY2015 - 16**

Name of GSS	Distt.	Transformer		FY	2015-16
		Voltage Ratio(kV)	Capacity (MVA)		
1	2	3	4	5	
400 kV GSS Jodhpur	Jodhpur	400/220	315	312	
		400/220	315	296	
		220/132	100	107	
132 kV GSS Surpura, Mandore	Jodhpur	132/33	20/25	16	
		132/33	10/12.5	8	
220kV GSS Aau	Jodhpur	220/132	160	78	
		132/33	20/25	19	
		132/33	20/25	19	
132kV GSS Aau	Jodhpur	132/33	20/25	19	
		132/33	20/25	19	
220kV GSS Baithwasia	Jodhpur	220/132	160	132	
		132/33	20/25	23	
		132/33	20/25	19	
132 kV GSS Hatundi	Jodhpur	132/33	20/25	13	
132 kV GSS Osian	Jodhpur	132/33	40/50	37	
		132/33	20/25	22	
132 kV GSS Matora	Jodhpur	132/33	40/50	44	
		132/33	40/50	47	
132 kV GSS Soorsagar	Jodhpur	132/33	20/25	17	
		132/33	20/25	18	
220 kV GSS Boranada	Jodhpur	220/132	100	59	
		220/132	100	53	
		132/33	40/50	31	
		132/33	20/25	23	
132kV GSS PS-8 Narwa	Jodhpur	132/33	10/12.5	15	
132 kV GSS CHB Jodhpur	Jodhpur	132/33	20/25	17	
		132/33	40/50	29	
132 kV GSS Pratap Nagar, Jodhpur	Jodhpur	132/33	40/50	33	
		132/33	40/50	33	
220kV GSS Dechu	Jodhpur	220/132	100	77	
		220/132	100	85	
132kV GSS Dechu	Jodhpur	132/33	20/25	22	
		132/33	20/25	23	
		132/33	20/25	23	
132 kV GSS Sanwreej	Jodhpur	132/33	20/25	22	
		132/33	20/25	20	
132 kV GSS Kalau	Jodhpur	132/33	20/25	21	
		132/33	20/25	23	
220kV GSS Jodhpur	Jodhpur	220/132	160	120	
		220/132	100	84	
		220/132	100	75	
		132/33	20/25	21	
		132/33	20/25	20	
		132/33	40/50	26	
132 kV GSS Kuri Bhagtasani Jodhpur	Jodhpur	132/33	37.5/50	33	
		132/33	37.5/50	32	
132 kV GSS OPH	Jodhpur	132/33	37.5/50	36	
		132/33	37.5/50	35	
132 kV GSS MRM F.C. Jodhpur	Jodhpur	132/33	37.5/50	10	

132 kV GSS MDH E.C. Jodhpur	Jodhpur	132/33	37.5/50	12
132 kV GSS Banar	Jodhpur	132/33	40/50	43
		132/33	40/50	41
132 kV GSS NPH Jodhpur	Jodhpur	132/33	20/25	15
		132/33	20/25	18
		132/33	20/25	18
		132/33	20/25	15
		132/11	12.5/20	14
		132/11	10/12.5	10
		220kV GSS Tinwari	Jodhpur	220/132
220/132	100			78
132/33	20/25			43
132/33	20/25			
132/33	40/50			44
132/11	6			9
132/11	6			
132kV GSS Balesar	Jodhpur	132/33	20/25	22
		132/33	10/12.5	11
132kV GSS Chamu	Jodhpur	132/33	20/25	21
		132/33	40/50	41
220kV GSS Phalodi	Jodhpur	132/33	20/25	22
		132/33	20/25	22
		132/33	20/25	22
		220/132	100	99
		220/132	100	89
		220/132	160	130
		132 kV GSS PS-5	Jodhpur	132/33
132/33	20/25			
132/33	20/25			22
132 kV GSS Lohawat	Jodhpur	132/33	20/25	22
		132/33	40/50	44
132 kV GSS Ketusar	Jodhpur	132/33	20/25	24
		132/33	20/25	13
220 kV GSS Bap	Jodhpur	220/132	160	94
		132/33	40/50	48
		132/33	40/50	48
		132/33	40/50	48
132 kV GSS PS-1	Jodhpur	132/33	20/25	22
		132/33	20/25	0
132 kV GSS PS-4	Jodhpur	132/33	20/25	8
132 kV GSS PS-3	Jodhpur	132/33	40/50	35
		132/33	40/50	18
		132/33	20/25	21
132 kV GSS PS-2	Jodhpur	132/33	20/25	19
220kV GSS Bhadla	Jodhpur	220	160	81
		132	40/50	39
		132	20/25	22
220kV GSS Badisid	Jodhpur	220/132	160	139
		132/33	25	NR
220 kV GSS, Bilara	Jodhpur	220/132	100	77
		220/132	100	77
		132/33	25	23
		132/33	25	18
132kV GSS Borunda	Jodhpur	132/33	10/12.5 & 20/25	31
132 kV GSS Pinar city	Jodhpur	132/33	20/25	15

132 kV GSS Pipliya City	Jodhpur	132/33	10/12.5	9
132kV GSS Pipliya Kallan	Pali	132/33	10/12.5	10
		132/33	10/12.5	11
220kV GSS Bhopalgarh	Jodhpur	220/132	70/100	82
		220/132	30/50	39
		132/33	20/25	23
		132/33	10/12.5	11
132kV GSS Bhopalgarh	Jodhpur	132/33	14/20	18
		132/33	20/25	24
		132/11	10/12.5	10
132 kV GSS Soyla	Jodhpur	132/33	20/25	19
		132/33	20/25	NIL
		132/33	40/50	26
220kV GSS Bhawad	Jodhpur	220/132	100	76
		220/132	160	84
		132/33	20/25	4
132kV GSS Mathania	Jodhpur	132/33	20/25	22
		132/33	20/25	24
132 kV GSS, Baori	Jodhpur	132/33	20/25	18
		132/33	20/25	18
		132/33	20/25	18
220 kV GSS Pali	Pali	220/132	100	69
		220/132	100	85
		132/33	10/12.5	1
132 kV GSS Jaitaran	Pali	132/33	10/12.5	11
		132/33	20/25	22
132 kV GSS Sojat City	Pali	132/33	10/12.5	12
		132/33	10/12.5	12
132 kV GSS Pali	Pali	132/33	20/25	22
		132/33	20/25	22
132kV GSS Kharchi	Pali	132/33	10/12.5	11
		132/33	10/12.5	10
132 kV GSS Jojawar	Pali	132/33	20/25	19
		132/33	10/12.5	6
132kV GSS A. P. Kaloo	Pali	132/33	20/25	13
132kV GSS Tagore Nagar	Pali	132/33	20/25	14
		132/33	20/25	15
220 kV GSS Bali	Pali	220/132	100	78
		220/132	100	59
		132/33	20/25	22
		132/33	10/12.5	11
132 kV GSS Rani	Pali	132/33	20/25	16
		132/33	16/20	14
132 kV GSS Sumerpur	Pali	132/33	20/25	23
		132/33	20/25	22
132 kV GSS Falna	Pali	132/33	12.5/7.5/5	10
		132/33	10/12.5	8
		400/220/33	315	244

400 kV GSS , Barmer	Barmer	400/220/33	315	218
		220/132	100	89
		220/132	100	82
		132/33	10/12.5	12
132kV GSS Mahloo	Barmer	132/33	20/25	21
		132/33	10/12.5	11
132 kV GSS , Barmer	Barmer	132/33	20/25	23
		132/33	10/12.5	21
		132/33	10/12.5	
		132/11	10/12.5	3
132 kV GSS Gadra Road	Barmer	132/33 ()	10/12.5	11
		132/33()	10/10.5	10
132 kV GSS Sheo	Barmer	132/33	20/25	23
		132/33	16/20	17
		132/33	40/50	34
132 kV GSS Undoo	Barmer	132/33	20/25	21
		132/33	20/25	23
220 kV GSS Balotra	Barmer	220/132	100	77
		220/132	100	64
		132/33	20/25	20
		132/33	20/25	20
		132/33	50	25
132 kV GSS Samdari	Barmer	132/33	20/25	17
		132/33	10	9
132 kV GSS Sindhari	Barmer	132/33	20/25	80
		132/33	20/25	28
132 kV GSS Siwana	Barmer	132/33	10/12.5	12
		132/33	10/12.5	11
		132/33	10/12.5	12
132 kV GSS Padroo	Barmer	132/33	20/25	17
		132/33	20/25	17
132 kV GSS Juna Meetha Khera	Barmer	132/33	20/25	21
220 kV GSS Dhorimanna	Barmer	220/132	100	93
		220/132	100	93
		132/33	20/25	23
		132/33	20/25	24
132 kV GSS Sawa	Barmer	132/33	20/25	22
		132/33	20/25	21
132kV GSS Gudamalani	Barmer	132/33	20/25	21
		132/33	10/12.5	11
132 kV GSS Ranasar	Barmer	132/33	20/25	16
		132/33	10/12.5	7
132 kV GSS Sedwa	Barmer	132/33	20/25	21
132kV GSS Sata	Barmer	132/33	20/25	20
		132/33	10/12.5	
400 kV GSS Akal	Jaisalmer	400/220/33	315	255
			315	234
			315	234
			500	345

220kV GSS Amarsagar	Jaisalmer	220/132	100	53
		220/132	160	124
		220/132	100	77
		132/33	20/25	19
		132/33	20/25	20
		132/33	20/25	19
		132/33	20/25	19
132 kV GSS Chandan	Jaisalmer	132/33	40/50	29
		132/33	20/25	23
		132/33	20/25	20
132kV GSS Jaisalmer	Jaisalmer	132/33	40/50	34
		132/33	20/25	18
132 kV GSS Pokaran	Jaisalmer	132/33	40/50	40
		132/33	25	12
		132/33	12.5	10
132 kV GSS Ajarar	Jaisalmer	132/33	25	20
220kV GSS, , Ramgarh, Jaisalmer	Jaisalmer	132/33	25	15
		220/132	160	63
220 kV GSS Sirohi	Sirohi	132/33	20/25	19
		220/132	100	87
		220/132	50	50
		132/33	20/25	26
132 kV GSS REODAR	Sirohi	132/33	10/12.5	13
		132/33	20/25	22
132kV GSS Posaliya	Sirohi	132/33	20/25	22
220kV GSS Pindwara	Sirohi	132/33	20/25	12
		220/132	100	76
		132/33	10/12.5	13
132 kV GSS Aburoad	Sirohi	132/33	10/12.5	13
		132/33	20/25	22
132 kV GSS RIICO Aburoad	Sirohi	132/33	10/12.5	10
		132/33	20/25	19
220 kV GSS Bhinmal	Jalore	220/132	100	94
		220/132	100	76
		132/33	40/50	30
		132/33	20/25	16
		132/11	10/12.5	10
132 kV GSS Raniwara	Jalore	132/33	20/25	22
		132/33	10/12.5	8
		132/33	10/12.5	12
132 kV GSS Poonasa	Jalore	132/33	20/25	23
		132/33	20/25	21
132 kV GSS Sankad	Jalore	132/33	25	25
132 kV GSS Bagora	Jalore	132/33	25	25
		132/33	50	40
		132/33	25	27
132kV GSS Ramseen	Jalore	132/33	25	19
		132/33	20/25	17
132kV GSS Badgaon	Jalore	132/33	10/12.5	10
		132/33	20/25	16
220 kV GSS Jalore	Jalore	132/33	20/25	15
		220/132	100	99
		220/132	50	46
		132/33	10/12.5	7

132 kV GSS Jalore	Jalore	132/33	20/25	16
		132/33	10/12.5	7
		132/33	10/12.5	7
132 kV GSS Bagra	Jalore	132/33	20/25	21
		132/33	20/25	21
132 kV GSS Umedpur	Jalore	132/33	10/12.5	9
		132/33	10/12.5	9
132 kV GSS Mandawala	Jalore	132/33	20/25	13
		132/33	20/25	13
220 kV GSS Sanchore	Jalore	220/132/11	100	97
132 kV GSS Galifa	Jalore	132/33	20/25	4
132 kV GSS Sanchore	Jalore	132/33	10/12.5	19
		132/33	10/12.5	
		132/33	16/20	13
132 kV GSS Bhadroona	Jalore	132/33	20/25	24
		132/33	10/12.5	12
132 kV GSS Paladar	Jalore	132/33	20/25	15
220 kV GSS Sayla	Jalore	220/132	160	109
		132/33	20/25	23
132 kV GSS Daspan	Jalore	132/33	20/25	21
		132/33	20/25	23
132 kV GSS Sayla	Jalore	132/33	20/25	22
		132/33	20/25	21
132 kV GSS Jeewana	Jalore	132/33	20/25	17
		132/33	20/25	17
220 kV GSS, Suratgarh	Sriganganagar	220/132	100	88
		220/132	50	47
		220/132	100	81
		132/33	20/25	26
		132/33	20/25	23
132 kV GSS, , Rajiasar	Sriganganagar	132/33	10/12.5	12
		132/33	10/12.5	12
132 kV GSS SRI Vijaynagar	Sriganganagar	132/33	20/25	12
		132/33	20/25	12
132 kV GSS, Gharsana	Sri Gnganagar	132/ 33	20/25	21
		132/ 33	10/12.5	12
132 kV GSS, Jokhasar	Hanumangarh	132/ 33	10/12.5	9
		132/ 33	10/12.5	9
132 kV GSS, Anoopgarh	Sriganganagar	132/33	10/12.5	10
		132/33	20/25	14
220 kV GSS Udyogvihar	Sriganganagar	220/132	100	89
		220/132	50	50
		132/33	20/25	26
		132/33	20/25	24
132 kV GSS Sriganganagar	Sriganganagar	132/33	14.6/20	19
		132/33	40/50	52
		132/33	20/25	24
132kV GSS Sadulshahar	Sri Ganga nagar	132/33	20/25	14
		132/33	16/20	13
220 kV GSS Padampur	Sriganganagar	220/132	100	84
		220/132	100	0
		132/33	20/25	17
		132/33	20/25	17



132 kV GSS Sri Karanpur	Sriganganagar	132/33	20/25	8
		132/33	10/12.5	6
132 kV GSS Raisinghnagar	Sriganganagar	132/33	20/25	18
		132/33	10/12.5	8
132 kV GSS Kaminpura	Sriganganagar	132/33	20/25	13
220 kV GSS Hanumangarh	Hanumangarh	220/132/11	100	88
			160	135
132 kV GSS Amarpurathedi	Hanumangarh	132/33	20/25	26
		132/33	20/25	16
		132/33	40/50	31
132 kV GSS Hanumangarh	Hanumangarh	132/33	40/50	34
		132/33	20/25	23
		132/33	20/25	23
		132/33	10/12.5	12
		132/11	10/12.5	7
132kV GSS Pilibanga	Hanumangarh	132/33	40/50	28
		132/33	20/25	23
		132/33	20/25	23
		132/11	10/12.5	11
132 kV GSS Sangaria	Hanumangarh	132/33	20/25	24
		132/33	20/25	24
132kV GSS, Rawatsar	Hanumangarh	132/33	20/25	25
		132/33/11	12.5/7.5/5	9
132 kV GSS Goluwala	Hanumangarh	133/33	20/25	23
		133/33	10/12.5	7
220 kV GSS Bhadra	Hanumangarh	220/132	100	79
		220/132	50	63
132 kV GSS Bhadra	Hanumangarh	132/33/11	12.5/7.5/5	9
		132/33	20/25	22
		132/33	20/25	24
132 kV GSS Nohar	Hanumangarh	132/33	20/25	22
		132/33	10/12.5	12
400 kV GSS, Bikaner	Bikaner	400/200/33	315	335
220 kV GSS Bikaner	Bikaner	220/132	100	88
		220/132	100	90
		220/132	100	76
		132/33	20/25	23
		132/33	20/25	22
		132/33	40/50	45
132kV GSS Napasar	Bikaner	132/33	20/25	23
		132/33	20/25	23
		132/33	10/12.5	11
132 kV GSS Bhinasar	Bikaner	132/33	20/25	23
		132/33	20/25	23
		132/33	20/25	23
132 kV GSS Pugal Rd	Bikaner	132/33	20/25	24
		132/33	40/50	34
132 kV GSS Loonkaransar	Bikaner	132/33	20/25	25
		132/33	10/12.5	12
132 kV GSS Khajuwala	Bikaner	132/33	20/25	21
		132/33	20/25	16
220 kV GSS, Sri Dungargarh	Bikaner	220/132	100	97
		220/132	100	99
		132/33	40/ 50	39
		132/33	20/ 25	21

132kV GSS, Sri Doongargarh	Bikaner	132/33	20/25	22
		132/33	20/25	22
132 kV GSS, Momasar	Bikaner	132/33	20/25	21
		132/33	20/25	24
		132/33	20/25	23
132 kV GSS, Riri	Bikaner	132/33	20/25	24
		132/33	20/25	24
132 kV GSS, Upani	Bikaner	132/33	20/25	19
		132/33	20/25	19
220 kV GSS, Nokha	Bikaner	220/132	100	97
		220/132	160	136
		132/33	20/25	23
		132/33	20/25	23
		132/33	40/50	40
132 kV GSS, Deshnok	Bikaner	132/33	20/25	23
		132/33	20/25	22
		132/33	20/25	23
		132/33	20/25	22
132 kV GSS, Jarasar	Bikaner	132/33	20/25	22
		132/33	20/25	22
132 kV GSS, Panchu	Bikaner	132/33	20/25	22
220 kV GSS, Gajner	Bikaner	220/132	160	96
		220/132	100	83
		132/33	40/50	41
		132/33	20/25	26
		132/33	20/25	23
132 kV GSS, Nokha Daiya	Bikaner	132/33	10/12.5	11
		132/33	10/12.5	11
132 kV GSS, Bajju	Bikaner	132/33	10/12.5	14
		132/33	10/12.5	14
132 kV GSS, Kolayat	Bikaner	132/33	20/25	23
		132/33	20/25	22
		132/33	20/25	23
220 kV GSS, Badnu	Bikaner	132/33	22/25	22
			20/25	23
			20/25	23
		220/132	160	151
		220/132	160	95
132 kV GSS, , Lalamdesar	Bikaner	132/33	20/25	23
132 kV GSS, , Mundsar	Bikaner	132/33	20/25	22
132 kV GSS, , Dulhasar	Bikaner	132/33	20/25	23
			20/25	71
132 kV GSS, , Sherera	Bikaner	132/33	20/25	16
400kV GSS , Ratangarh	Churu	400/220	315	252
		400/220	315	251
		400/220	315	252
220 kV GSS Ratangarh	Churu	220/132	100	94
		220/132	100	94
		132/33	20/25	22
		132/33	20/25	22
132 kV GSS Ratangarh	Churu	132/33	10/12.5	7
132kV GSS, Churu	Churu	132/33	10/12.5	11
		132/33	2*10/12.5	22
132kV GSS Sardarshahar	Churu	132/33	20/25	24
		132/33	20/25	24
		132/33	20/25	24

132 kV GSS Patlisar-Fanta	Churu	132/33	20/25	22
		132/33	20/25	22
132kV GSS Taranagar	Churu	132/33	20/25	12
		132/33	10/12.5	8
132kV GSS, Chandgothi	Churu	132/33	20/25	13
		132/33	20/25	13
132 kV GSS Sadulpur	Churu	132/33	20/25	23
		132/33	20/25	23
220 kV GSS Sujangarh	Churu	220/132	100	87
		220/132	100	92
132 kV GSS Sujangarh	Churu	132/33	20/25	14
		132/33	10/12.5	12
132 kV GSS Salasar	Churu	132/33	10/12.5	8
		132/33	10/12.5	8
132 kV GSS, Ladnun	Nagaur	132/33	20/25	19
		132/33	20/25	19
220 kV GSS Tenhdehsar	Churu	220/132	100	97
		132/33	20/25	17
		132/33	20/25	17
		132/33	40/50	35
132 kV GSS Bidasar	Churu	132/33	20/25	23
		132/33	20/25	23
132 kV GSS Parewara	Churu	132/33	20/25	22
		132/33	20/25	22
132kVGSS Bhasina	Churu	132/33	20/25	13