

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

[Corporate Identity Number(CIN):U40109RJ2000SGC016485]

Regd. Office : Vidyut Bhawan, Jyoti Nagar, Jaipur-302005

OFFICE OF THE EXECUTIVE ENGINEER(220 KV GSS) DAUSA

Near Pannu Petrol Pump, Agra Road, Dausa

Tele 01427-230200 ,Email:-xen_220_dausa@rvpn.co.in;Website:-www.rvpn.co.in

G-schedule for maintenance work of bay equipments for the year 2017-18 at 220 KV GSS DAUSA up to 31.07.2017(Part-A)

S. No.	Particulars	Number of bays	Frequency of maintenance	Rate as per BSR - 2011	Amount (Rs.)
		Nos.	Nos.	Rs.	Rs.
1.	Maintenance work of following bay equipments such as Circuit Breaker, Current Transformers, Lightning Arresters, Isolators, Capacitive Voltage Transformers, PLCC equipments and corresponding control & relay panel. <ol style="list-style-type: none"> a. Checking of tightness of clamps & connectors. b. Cleaning of all insulators c. Assistance to RVPN in attending to oil leakage, if any d. Cleaning of all junction boxes and secondary terminal boxes. e. Assistance to RVPN in checking of operation of CB through relays and verifying various logic and control circuits and annunciation circuits. f. Assistance to RVPN in measurement of CB operation timings. 				

[Handwritten Signature]

[Handwritten Signature]