

**G-schedule for maintenance work of bus bars and associated equipments for the year 2017-18 at 220 KV GSS Dausa (Part-C)**

S. No.	Particulars	Numbers of Section of Bus Bars Nos.	Frequency of maintenance Nos.	Rate as per BSR - 2011 Rs.	Amount (Rs.) Rs.
1.	<p>Maintenance work of bus bars of various voltage levels.(All spares, lubricating material and only special T&amp;P, shall be provided by RVPN. Cleaning material and general T&amp;P shall be arranged by the contractor.</p> <ul style="list-style-type: none"> <li>a. Tightening of clamps &amp; connectors on overhead conductors and gantries (at a maximum height of 25 meter using safety belts). Also tightening of clamp/connectors of all bus side associated equipments.</li> <li>b. Replacements of worn out clamps &amp; connectors of bus during work under item no.</li> <li>c. Cleaning of all insulators of suspension and tension strings of bus bars and insulators of bus isolators, bus CVTs/PTs.</li> <li>d. Checking of operation of bus isolators and their alignment including motorized operation.</li> <li>e. Maintenance of operating mechanism &amp; switches etc. of isolators.</li> <li>f. Lubrication of all moving parts of isolator</li> <li>g. Providing of other related work assistance as may be required by work in charge.</li> </ul>				

*Danwar*

*[Signature]*