



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM Ltd.

[Corporate Identity Number (CIN): L40109RJ2000SGC016485]
Regd. Office: Vidhyut Bhawan, Jyoti Nagar, Jaipur-302005
OFFICE OF THE ASSISTANT ENGINEER [132kV GSS]
RVPNL SUMERPUR (PALI, RAJASTHAN)-306902

Email-aen.132.sumerpur@rvpn.co.in phone-02933-252932, 252732

No. RRVPNL/AEN/132kV GSS/Sumerpur/S.Tech./F./2017-18/ D. 124 /Date 10.08.2017

NIT-02/2017-18

Date 10.08.2017

M/s

All Registered Contractors of T&C Kankani Circle/
All Registered Contractors of T&C Jodhpur Zone

Subject: - Painting of structure & Equipments at 132kV GSS Sumerpur (Pali)

Dear Sir,

Since you are enlisted contractor under this zone/ circle of RRVPNL, the following works are to be executed under this sub-division and we have decided to place order for Painting of structure & Equipments as per G-schedule at 132kV GSS Sumerpur Distt. Pali for the year 2017-18 on CLRC approved rates of RRVPNL.

Please send us your consent to the above work on CLRC within Seven (07) days from issue of this letter so that the further action viz placing the order kindly may be taken.

Assistant Engineer (132kV GSS)
R.V.P.N.L., Sumerpur

Copy submitted to the following for kind information & n/a please.


1. The Superintending Engineer (T& C) RRVPNL Kankani (Jodhpur)
2. The Executive Engineer (220kV GSS) RRVPNL, Bali
3. Feeder Manager (T&C) RVPN, Jodhpur for uploading on website of Nigam under Jodhpur zone Tender webpage.
4. The Account officer (T&C) RRVPNL Kankani (Jodhpur)


Assistant Engineer (132kV GSS)
R.V.P.N.L., Sumerpur

Rajasthan Rajya Vidhyut Prasaran Nigam Limited**(An ISO 9001 : 2008 Certified company)****Office of the Assistant Engineer (132 kV GSS) RRVPNL Sumerpur (Pali)**G Schedule for Painting of structure & Equipments prepared as per Nigam's BSR 2011Name of Work : Painting of structure & Equipments at 132kV GSS Sumerpur(Pali)Completion period: 03 Month

Sr. No.	Description	Unit	Qty.	Rate in Rs	Amount
1	2	3	4	5	6
2.0	Painting of unpaint steel structure				
2.1	Alumminium paint of unpainted steel structure at the GSS including paint and painting brush, emery paper, cloth & solvent etc. The surface shell be first cleaned with wire brush/emery paper and thereafter wiped with cloth to remove rust and any dust or other any deposits on erected M.S. steel structures & beams. One coat of red oxide paint shall be applied after carrying out cleaning and allowed to dry. Thereafter, two coats of aluminum paint shall be applied. Each subsequent coat shall be applied only after the previous coat has be dried up. The paints used shall be from any of the following recognized manufacturers, namely asian/Nerola/Berger/Johnson Nicholson.	Sq. mtr	496	31	15376.00
2.0	Painting of old paint steel structure				
2.2	Alumminium paint of unpainted steel structure at the GSS including supply of paint and painting brush, emery paper, cloth & solvent etc. The surface shell be first cleaned with wire brush/emery paper and thereafter wiped with cloth to remove rust and any dust or other any deposits on erected M.S. steel structures & beams. One coat of red oxide paint shall be applied after carrying out cleaning and allowed to dry. Thereafter, two coast of aluminum paint shall be applied. Each subsequent coat shall be applied only after the previous coat has be dried up. The paints used shall be from any of the following recognized manufacturers, namely asian/Nerola/Berger/Johnson Nicholson.	Sq. mtr	2200.6	24	52814.40
	Grand Total		2696.6		68190.40
	60 % above on BSR for CLRC Jodhpur Area.				40914.24
	Net Total				109104.64

Amount- Rs. 109105/- (Rs. one lakh nine thousand one hundred five only)**Note: - Work under CLRC no. T No. 2975 D. No. 501 dt 24/05/2013**


Junior Engineer (M)
RRVPNL Sumerpur


Assistant Engineer(132kV GSS)
RRVPNL Sumerpur