



CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LTD.
Office of Superintending Engineer (IT),
Old Power House Premises, Near Ram Mandir,
Jaipur-302006, Tel -0141-2205412

Regd. Office: Vidyut Bhawan, Jyoti Nagar, Jaipur 302004

Website: www.jaipurdiscom.com, email: seitjvvn@yahoo.in

No: JPD/ SE(IT) /TN 61/ D.- 1418

Date : 12.1.2017

Amendment against TN 61

Following amendments are hereby issued in the said specifications for Supply of GPRS Modems for Automated Meter Reading of Distribution Transformers in Jaipur Discom against TN 61:

Clause No.	Existing Particulars	Particulars Amended as
Section III Part-1 Schedule of Requirement (Pg 53) Section III Part III, 1 : Schedule of completion (Pg 59) Schedule-6: Schedule of completion (Pg 74)	Modems for AMR of DTs in 2 nd Phase : Preferred Delivery Time : shall be intimated later on	Preferred Delivery Time: Commencement after completion of delivery of 1st phase and completed within 6 months thereafter or as intimated during currency of contract.

22

Clause No.	Existing Particulars	Particulars Amended as
Section III Part III, 1 (xiii) : Type Test (Pg 58)	The GPRS modem shall be fully type tested at any NABL accredited test laboratory as per relevant standards. The bidder shall furnish two sets of type test reports along with the bid. The type test reports shall not be more than three years old from the date of opening of bid. Besides above bidders should also submit the test report from CPRI Bangalore along with the bid.	The GPRS modem shall be fully type tested at any NABL accredited test laboratory as per relevant standards. The bidder shall furnish two sets of type test reports along with the bid. The type test reports shall not be more than three years old from the date of opening of bid. Besides above bidders should also submit the test report from CPRI , Bangalore / Bhopal or ERDA along with the bid.
Section III Part III, 1 (xiii) : GTP of GSM/GPRS modem (Pg 58)	Three Phase power supply input (50V to 540 Volts AC, 50 Hz Surge withstand capacity – 10KV	Three Phase power supply input (90V to 470 Volts AC, 50 Hz Surge withstand capacity – 6KV


(Anil Gupta)

Superintending Engineer (IT)

24