

No./JPD/SE/PROC/SPO-II/D. 5813

DATED: 22-3-16

**CORRIGENDUM IN e-TENDER NOTICE**

The following amendments in the Technical Specification of TN-4569 for supply of 9 mtr. 200 kg. PCC poles to be read as under:

**1. Clause No.3 'REQUIREMENT'**

First para of existing clause no. 3 may be read as under:

The tentative requirement of 9 M long poles designed for working load 200 Kg with factor of safety 2.5 is **3,75,000** nos. (including tentative requirement of **8300** Nos. for RGGVY 12th plan) approx. These poles are required for erection of 11 KV & LT over head lines and installation of 11/4 KV distribution transformers.

**2. Clause No.12 'MARKING'**

In the existing clause no. 12 (A-4) following is added:-

Poles consigned for RGGVY works, marking in respect of Sr. No. 4 should be as JVVNL-TN-4569-RGGVY-TW

**3. SCHEDULE-I (SCHEDULE OF REQUIREMENT OF 9 metre LONG 200 KG. PCC POLES AGAINST TN-4569.**

This schedule is amended as under:

S.No.	Item	Provisional qty. in Nos.	Remarks
1	Rectangular shaped solid PCC Poles conforming to REC spec. No. 24/1983 amended upto 1987 & there-after and ISS 2905/1989 latest amended) & as per requirement of section-III of this spec. in overall length of 9 M. poles having working load of 200 KG. with factor of safety 2.5	3,66,700	
2	Rectangular shaped solid PCC Poles conforming to REC spec. No. 24/1983 amended upto 1987 & there-after and ISS 2905/1989 latest amended) & as per requirement of section-III of this spec. in overall length of 9 M. poles having working load of 200 KG. with factor of safety 2.5 (For RGGVY 12 <sup>th</sup> Plan)	8,300	
	<b>Total</b>	<b>3,75,000</b>	

**4. SCHEDULE-IV-A :**

The Tender Quantity of 9 Meter long 200 KG PCC Poles may be read as 3,75,000 Nos.(366700 Nos.+8300 Nos. for RGGVY 12<sup>th</sup> plan)  
The other terms and conditions will remain same as per original Notice published for Tender Invitation. The Tender documents are available on e-tendering portal <https://www.eproc.rajasthan.gov.in/nicgep/app> for viewing.

(AJEET SAXENA)  
SUPERINTENDING ENGINEER (PROC) 22/3/16

**Not to be published.**

Copy to

1. Superintending Engineer (IT), JVVNL, Jaipur for arranging hosting of this documents at Nigam's website ([www.jaipurdiscom.com](http://www.jaipurdiscom.com)).
2. The Sr. Accounts Officer (MM), JVVNL, Jaipur.

SUPERINTENDING ENGINEER (PROC) 22/3/16