

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (MM)
OLD POWER HOUSE PREMISES, BANI PARK, JAIPUR - 302006
PH:0141-2202607 FAX.: 0141-2202025

NO.JPD/SE/MM/SPO-IV/TN-2357/D. 3485

DATED: 24/10-2016

CORRIGENDUM No. 4

TN-2357

(TENDER ENQUIRY FOR PURCHASE OF THREE PHASE STATIC ENERGY METERS WITHOUT METER BOX HAVING DLMS PROTOCOL WITH ADDL. PORT ON LPRF TECHNOLOGY)

The Addendum/Corrigendum in the above technical specification is issued as under:-

Technical Specification (Section-III)

Following clauses are hereby amended to read as under:-

Sr. No.	Spec. Clause no.	Particulars	To be read as under:-
1	7.5(B) i	Reading through LPRF in case of power failure without use of push button	This clause is hereby amended to read as under:- "In case of failure of power supply, it shall be possible to download the reading at least two times in an interval of maximum 10 minutes through an in-built battery with the use of push button. "


(ASHOK MATHUR)
SUPERINTENDING ENGINEER (MM)