

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (MM)
OLD POWER HOUSE PREMISES, BANI PARK, JAIPUR - 302006
PH: 0141-2202607 FAX: 0141-2202025

NO.JPD/SE/MM/SPO-V/TN-2440/D. 7427 DATED: 27/12/17

TN-2440
(Tender ID-2017_JVVNL_82361_1)

(Purchase of 8.0 MVA 33/11 KV Power Transformers)

CORRIGENDUM NO.2

The following amendment is issued in the Technical Specification of above item:-

S. No.	Clause No	Existing provision	Amended provision
1.	3.14.1	No load losses in KW 6.1 KW	Load losses at 75 deg.C.in KW (At normal tap condition) 44 KW
			No load losses in KW 5.5 KW
			Load losses at 75 deg.C.in KW (At normal tap condition) 40 KW
	3.46 (B) (i)	(a) No Load Losses: 10% tolerance is allowable. Penalty shall be leviable @ Rs.386.00 per watt for losses exceeding 6100 watts and upto 6710 watts. (b) Load Losses: 3% tolerance is allowable. Penalty @ Rs.178.00 per watt on losses exceeding 44000 watts and upto 45320 Watts for 8.0 MVA rating.	(a) No Load Losses: 10% tolerance is allowable. Penalty shall be leviable @ Rs.386.00 per watt for losses exceeding 5500 watts and upto 6050 watts. (b) Load Losses: 3% tolerance is allowable. Penalty @ Rs.178.00 per watt on losses exceeding 40000 watts and upto 41200 Watts for 8.0 MVA rating.


(R. K. MEENA)

SUPERINTENDING ENGINEER (MM)

Copy forwarded to the Superintending Engineer (IT), Jaipur Discom, Jaipur for arranging hosting of the above Corrigendum on JVVNL Portal.


SUPERINTENDING ENGINEER (MM)