

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (MM)
OLD POWER HOUSE, NEAR RAM MANDIR, BANI PARK, JAIPUR

No:JPD/SE/MM/SPO-VI/TN-2459/D. 6571

Dated: 13/12/2017

TN-2459

(Tender ID 2017_JVVNL_85646_1)

**(Purchase of 16 KVA Three Phase Aluminium wound Distribution Transformer
BIS Level-2 (Star-1))**

CORRIGENDUM NO. 2

1. The Guarantee Period Clause No. 33 of the specification is hereby amended as under:

GUARANTEE PERIOD:

- I.** Performance guarantee of the transformer(s) with LT protection unit shall be for the period of 36 (Thirty Six) months from the date of dispatch of material. The date of expiry of guarantee period shall be marked on the rating plate. Transformer(s) alongwith LT protection unit failed within such guarantee period shall have to be **replaced by new transformer with new Sr. No.** free of cost expeditiously.
- i)** The firm will **replace** all type of GP failed Distribution Transformers without asking any segregation on account of manufacturing defect. However, the Discom will compensate the cost of missing parts as per practice in vogue.
- ii)** The guarantee period failed transformers will directly be lifted by the suppliers from the respective circle store **within a period of 60 days from the date of intimation by the respective consignee and will supply new Distribution Transformers against G.P. failed within 30 days from the date of lifting** in the ACOS, JCC (Achrol) store/central store along with the joint inspection sheet of missing parts issued by the respective consignee. After receiving the material at ACOS, JCC store, the same shall be tested at CTL as per provisions of the relevant contracts and will be issued to the circle store as per requirement on Nigam's account. The invoices of missing parts shall be verified by the ACOS, JCC store as per the joint inspection sheet issued by the circle store as per practice in vogue and accordingly, the Sr. A.O. (CPC) will make the payment of missing parts, if any.



iii) The loading of G.P. failed Distribution Transformers at circle store and un-loading of **new replaced Transformer** at ACOS, JCC (Achrol store) will be on suppliers' account.

iv) The firm will **replace** G.P. failed transformers by new transformer **with new Sr. No.** irrespective of breakage of body seals as well as physical damage of transformer tank body due to bursting. The period during which transformer remained defective/failed will not be accounted in the performance Guarantee period. The period of defective will be reckoned from the date of first intimation (i.e. field officer/consignee whichever is earlier) to date of delivery of **new replaced transformer**.

Firms shall lift the G.P. failed Transformer(s) within a period of 60 days from the date of intimation by the respective consignee and will supply new Distribution Transformers against G.P. failed within 30 days from the date of lifting positively. In case firm fails to deliver new Transformer(s) within 90 days from date of intimation, the cost of the transformer(s) shall be withheld from firm's financial hold and in case firm fails to deliver new transformer within 90 days from date of intimation, a penalty at the rate of 1/2% per week subject to maximum 10%, shall be levied for the late delivery of replaced Transformer(s). Firm shall lift G.P. failed transformers after furnishing safe custody bank guarantee, the slab of safe custody Bank Guarantee shall be as under.

Safe custody Bank Guarantee:-

In case if order is upto 1000 Nos. DT's the firm have to give safe custody Bank Guarantee for Rs. 5.00 Lacs and if order is more than 1000 Nos. but upto 3000 Nos. then the safe custody BG for Rs. 10.00 lacs and for orders more than 3000 Nos. DT's the value of safe custody BG shall be Rs. 20.00 Lacs. **The safe custody bank Guarantee (SCBG) shall be of 1% of the value of the contract or as per above mentioned slab whichever is lower.** In case firm fails to furnish the safe custody BG the amount equivalent to safe custody BG shall be deducted from firm's first bill due for payment. On furnishing of safe custody BG the amount so deducted shall be returned to the firm. The safe custody BG shall be valid for a period of 12 months over and above the normal GP. After a period of 16 months from normal GP the safe custody BG shall be returned back unless there is some specific direction from the purchaser.

II. All the **new replaced** transformers by the manufacturer under guarantee clause shall carry a further guarantee of 12 months after **replacement** or unexpired guarantee of 36 months from the date of supply, whichever is later, after **replacement**. The bank guarantee equivalent to cost of **replaced** transformers shall be furnished after expiry of performance guarantee period to cover **such**

Handwritten signature in blue ink.

guarantee. The purchaser also reserves the right to withhold the payment of supplier firm, under any other contract, if the performance of the supplier in **new replaced** transformers is not satisfactory. Each supplier shall invariably furnish the detailed information about the total number of transformers failed and **replaced** by them, every month after commencement of supplies.

III. In order to ascertain that transformers have successfully completed guarantee period the following details shall be provided on the transformer body:

A. A replacement identification steel plate on new replaced transformer against G.P. failed transformer of size 75 x 75 x 2.5 mm duly engraved with following details shall be welded on the transformer body.

Particulars	New Supply	1 st Replacement	2 nd Replacement	3 rd Replacement
Firm's Name/Logo				
TN				
Rating (KVA)				
Sr. No.				
Date of Dispatch				
Date of failure				
Guarantee period Upto				

B. Such metallic plate fixed on first **replacement** should not be removed at the time of second **replacement** or any subsequent **replacement**. However, necessary details of failure and **replacement** shall be graved on **the identification plate**, each time it is **replaced** in guarantee.

Note:-

- 1) All other plates such as rating and terminal marking plate and Technical cum Identification Plate have to be affixed on the replaced transformers as in case of new transformers.
- 2) A commercial procedure be followed so that GST shall not be applicable on the firm against new supply in lieu of G.P. failed Distribution Transformers.

C. The **replaced new** transformer shall be provided with 40 mm wide red color band all around transformers including radiator each time it is **replaced by new**

[Handwritten signature]

