

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (MM)
OLD POWER HOUSE, NEAR RAM MANDIR, BANI PARK, JAIPUR

No:JPD/SE/MM/SPO-VI/D. 2187

Dated: 01/02/18

CLARIFICATION

TN-2475

(Tender ID 2018_JVVNL_92074_1)

(16 KVA, 11/0.433KV, Three Phase, Al. wound Distribution Transformers BIS Level-2 (Star-1) with Meter & Protection Box)

- 1. The Technical Cum Identification Plate Clause No. 24(B) of the specification is hereby amended as under:**

Earlier	Now
M.S. plate of size 125 x 75 x 2.5 mm having following details punched with letters of size 8mm X 6mm shall be continuously welded to the main tank body below the middle HV bushing and on top cover of tank in clearly visible position.	M.S. plate of size 125 x 75 x 2.5 mm having following details punched with letters of size 8mm X 6mm shall be continuously welded to the main tank body below the middle HV bushing in clearly visible position.

(Signature)
01/02/18
(R. K. MEENA)

Superintending Engineer (MM)
Jaipur Discom, Jaipur

Copy forwarded to the Superintending Engineer (IT), Jaipur Discom, Jaipur for arranging hosting of the above corrigendum on JVVNL, Portal.

(Signature)
01/02/18
Superintending Engineer (MM)
(Signature)