



JAIPUR VIDYUT VITRAN NIGAM LTD.
Office of The superintending Engineer (TW),
Old Power House Premises, Near Ram Mandir,
Jaipur-302006, TELE FAX NO.0141-2201022
Website: <http://energy.rajasthan.gov.in/jvvn>,
Email: setw@jvvn.org

No. JPD/SE (TW)/XEN/TW-III/TN-482/F. /D. 2288 Dated: 26/07/2019

BOQ Corrigendum/Addendum/Clarification-II (TN-482)

To

All intending bidders

Subject: - Addendum in the BOQ of TN-482 (Tender ID- 2019_JVVNL_150849_1)

The addendum is hereby issued in the already uploaded BOQ of TN-482. All intending bidders are requested to go through the amendments and act accordingly while participating in the aforesaid bids.

The new items added in existing BOQ as detailed below, bidder shall quoted the rates considering new added items also as mentioned below:

Addendum in BOQ

S. No.	Volume/ Section	BOQ Item Description	Particulars of BOQ New items		
			Quantity	Units	Rate/ Unit (Rs.)
1.0	Financial BOQ	Identification numbering on support pole/ structure/transformer/other equipment/ Warning instruction of availability of two sources of supply on same structure, at source structure, at cut points, properly labelled using yellow base and black indication marks (number or digits) 40/50 mm height digits/words should be used for this purpose. Base shall be made using 2 or more coats of yellow enamel paint till good surface finish. Base painting and marking of digits should be performed by a skilled and trained painter using branded enamel paint. Engineer - Incharge shall approve type and brand of enamel paint.			
1.1		In urban area	1	Nos.	10
1.2		In rural area	1	Nos.	12
2.0		Supply & erection of Maintenance free Gel Earthing with Pipe in pipe / Pipe in strip technology filled with anti corrosive conductive compound (CPRI Tested) below the ground in 150 - 200 mm dia. earth pit & surrounding filled with required mineral filling compound (MFC should have hygroscopic property to retain the moisture for long time to create low resistance zone) and C.C. finished chamber covered with hinged type with locking arrangement C.I. Cover, C.I. Frame of size 300mm x 300mm complete testing of earth resistance as required. G.I Pipe (IS: 1239 marks) GI pipe 2000 mm long, 80 / 40 mm, Terminal 12 mm GI Strip. Earthing as per IS:3043-1987	1	Set	7500

Other particulars in the already uploaded BOQ will remains same.

(Handwritten signature)

This is issued without prejudice to any other terms & conditions of the subject bidding documents.


(K.C.Sharma)
SUPERINTENDING ENGINEER (TW)

Copy submitted / forwarded to the following for information & necessary action:-

1. The Superintending Engineer (IT), Jaipur Discom, Jaipur for arranging hosting of this corrigendum / addendum/ clarification (TN-482) at Nigam's website (<http://energy.rajasthan.gov.in/jvvn/>).
2. The Accounts Officer (PPM)/MM Jaipur Discom, Jaipur.


SUPERINTENDING ENGINEER (TW)