



No.JdVVNL/MD/CE(HQ)/SE(RA&C)/JU/2017-18/D. 713 Dt. 24.08.17

**ORDER**

**Sub.: Guidelines regarding metering and routine testing/ checking of temporary connections.**

Guidelines regarding the regular inspection / testing and checking of all category of consumers to be carried out by M&P wing have been issued vide order Comml.JDP/790 dt.13.06.2017. During the course of meeting, it came in the notice that routine testing / checking of temporary connections are not being carried out by M&P wing even in the cases of connections having load/ demand above 18.65 KW.

In order to record correct energy consumption in case of temporary connections, the following guidelines are hereby issued in respect of release of temporary connections and for carrying out the routine testing/ checking thereof:

1. All temporary connections having sanctioned connected load more than 18.65 KW shall be released with proper metering and sealing arrangements by M&P wing.
2. The monthly meter reading of temporary connections above 18.65 KW, shall be taken through CMRI every month by M&P wing and after making further analysis, results/assessment be intimated to concerning AEN(O&M), so that performance of the metering equipment and any defect thereof may be ascertained in time.
3. Routine testing/ checking of all temporary connections above 18.65 KW be done twice in a year.
4. The AEN (O&M) shall ensure to intimate the time extension of temporary connection regularly to M&P wing so that routine testing could be carried out by them, if due.

The field officers are directed to comply with above instructions.

By Order,

  
(M.R. MEENA)

**ADDL.CHIEF ENGINEER (HQ)  
JODHPUR DISCOM, JODHPUR**