



JODHPUR VIDYUT VITRAN NIGAM LTD.
 Corporate Identity Number (CIN) –U40109RJ2000SGC016483
 Regd. Office: New Power House, Jodhpur- 342003
OFFICE OF THE SUPERINTENDING ENGINEER (DDUGJY)
 Phone No: 0291-2742336, Fax No: 0291-2745259
 E-mail: seddugjyjdvvnl@gmail.com, Web site: www.jdvvnl.com

No: JdVVNL/SE(DDU)/JU/XEN (DDU)/ TNTW 356/VA_122/D_ 21 Dated 31/4/18

**M/s Absolute Projects (India) Ltd., 4222/1, First Floor,
 Laxmi Kunj, Ansari Road,
 New Delhi**

Subject: GTP & Vendor approval for supply of different material against DDUGJY works under Jodhpur Discom.

Ref: - (i) LOA No. JdVVNL/SE(DDUGJY)/XEN(DDUGJY)/TNTW-356/W.O-202/Supply/D.4203 Dt. 22.03.17
 (ii) Your Letter No.nil dt 16.3.18(recd. On 22.3.18)
 (iii) E-mails dtd.27.3.18 & 28.3.18

Dear Sir,

May kindly refer your letter captioned above vide which you have furnished GTP and name of vendor for supply of items for approval of this office. You have also furnished other relevant supporting documents for the GTP and vendors approval for the work against the subject contract as well as all DDUGJY works with details as under:-

Name of The Vendor	Particulars of The Material
M/s MAHAVEER TRANSMISSION LIMITED Works: A-9. B-4, 11-13 S, Industrial Estate, Vikas Nagar - 248198,Dehradun (Uttarakhand) Regd. Office : 4510-12,7/33 Ansari Road, Darya Ganj , New Delhi- 110002 Corporate Office :C-58, Sector-4, Noida(U.P)-201301	ACSR Weasel Conductor [30sq. mm (6+1)/(2.59+2.59)mm]

The GTP approval in respect of above mentioned vendors is issued in accordance with clause 30.3 of the detailed letter of award of contract placed on you subject to fulfillment of the following parameters:

- That the material to be supplied shall conform to the relevant ISS and GTP & Drawing as well as governing specifications of SBD for DDUGJY works.
- That Type Test Certificates of relevant items shall not be older than 3 Year and vendor approval valid till validity of type tests.
- That all the material shall be got marked/punched/painted/ engraved/embossed with following as per approved GTP/drawing: -
 (A) Name of supplier (B) JdVVNL/DDUGJY (C) TNTW-___ /Name of Contractor.
- That presently only technical parameters are being approved.
- That instant approval stands valid for DDUGJY works.

It may be noted that JdVVNL reserves the right to withdraw the vendor approval in case of following conditions:-

- Any default or poor performance observed during execution of contract.
- Blacklist or banned/debar by any central and state electricity board/Discom/PSU/Power Utility
- Deviation in respect of approved GTP/Drawing.

OFFICE OF SE (IT-DSM)

NEW DELHI

AEN/TA

JEN/TA

Estt./Conf

AEN/TA

XEN

SE

Handwritten notes:
 V... up load
 21/4