



**OFFICE OF THE SUPERINTENDING ENGINEER (MM&C)
JODHPUR VIDYUT VITRAN NIGAM LTD.**

Corporate Identity Number (CIN) – U40109RJ2000SGC016483

Regd. Office: New Power House, Jodhpur –342003 Raj.

Phone No. : 0291-2742223

Fax No. : 0291-2746539

E-mail : semmcjdvvnl@gmail.com

web site : www.jdvvn.com

No.JdVVNL/SE(MM&C)/JU./ EIIAII / TN-1288 /D.

Dated

2 JAN 2017

To

6268

All Intending Bidders

Subject: Clarification in technical specifications for purchase of HT XLPE Insulated PVC Sheathed ACSR RABBIT Conductor Suitable for Working Voltage upto & including 11000 Volts against TN-1288.

Reference: (1) M/s CMI Energy India Pvt. Ltd., New Delhi letter dated 26.12.2016.
(2) M/s Tirupati Plastomatics Pvt. Ltd., Jaipur letter dated 29.12.2016.

Dear Sirs,

On the subject reference, TN-1288 for purchase of HT XLPE Insulated PVC Sheathed ACSR RABBIT Conductor Suitable for Working Voltage upto & including 11000 Volts, the various clarifications as desired by intending bidders are as follows:

1. Rated Voltage 11KV (Earthed System).
2. Conductor screening shall be provided before XLPE as per requirement of IS:7098 (Part 2) 2011 with latest amendment.
3. After providing XLPE insulation and PVC Sheath Insulation screening is not required. Since HT insulated ACSR Rabbit conductor is to be provided for overhead transmission purpose.
4. The Type Test requirement for ACSR Rabbit Conductor / XLPE insulation /PVC Sheath shall be as per relevant IS: 398 (Pt.2 1996)/ IS:7098 (PT.2 1985) /ISIS:5831(1984) with latest amendments as mentioned in specification.

In view of above you are requested to complete the bidding process on E-procurement portal without any delay.

The due date for opening of following bid is hereby extended as detailed hereunder:

S. No	TN No.	Description of Item	Schedule Date of opening	New Date of opening
1.	1288	HT XLPE Insulated PVC Sheathed ACSR RABBIT Conductor Suitable for Working Voltage upto & including 11000 Volts.	03.01.2017	18.01.2017

All other terms & conditions shall remain unchanged.



(PRAMOD TAK)
SUPERINTENDING ENGINEER (MM&C)
JODHPUR DISCOM, JODHPUR

Copy to SE(IT &Trg.), JdVVNL, Jodhpur for uploading the clarification and date extension notice on web site of Jodhpur Discom.


SUPERINTENDING ENGINEER (MM&C)
JODHPUR DISCOM, JODHPUR



