

**JODHPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER (MM&C)**  
**NEW POWER HOUSE, INDUSTRIAL AREA, JODHPUR-342003**  
No. /JdVVNL/SE(MM&C)/XIII/III/TN-1412/D 483 Date 23.4.18

**AMENDMENT**

Following amendment is hereby made in clause no.10 of Technical Specification of TN-1412 for supply of Galvanised M. S. rod type Earthing set with clamps and G.I. wire:


**10. MARKING :**

The following marking shall be stamped / punched / emboss with a metal dye on the both clamps and shall be legible.

- i. The name of manufacturers in suitable code
- ii. The word "JUD" & "TN No"
- iii. Year of manufacture

If the above marking is not found on the material received in the stores, the receipted challan shall not be given by the concerned stores. The challan shall only be issued after verification of material by the Store officer.

Each bundle of earthing sets shall be legibly marked with the physical condition, weight, date of manufacture, trade mark or the name of manufacturer. The material which is inspected and cleared for dispatch shall be sealed with the JdVVNL seal.

  
(PRAMOD TAK)  
Superintending Engineer (MM&C)  
Jodhpur Discom, Jodhpur