



AJMER VIDYUT VITRAN NIGAM LIMITED
(COMMERCIAL WING)

No. AVVNL/CE(Comml.)/XEN-II/F-57(F)/2012/D. ⁴⁴⁷¹ Ajmer Dt 7/1/13


ORDER

Sub:- Procedure for installation of main meter, check meter and stand-by meter in respect of Open Access Consumers.

It is observed that generally the provision of Metering Regulation of RERC dt. 29.05.2007 in respect of providing ABT complaint main meter, check meter and stand by meters are not being followed by the Field Officers & may lead to any sort of complications in future. Beside, it is also reported that the defective/ stopped ABT meters of Open Access Consumers are not being replaced timely as per the requirement of Open Access Regulation of RERC, which is suppose to be replaced immediately.

In order to streamline the uniform action for Open Access Consumers the following guidelines are issued for compliance by the Field Officers.


1. Provide main meter and check meter in respect of Open Access Consumers as per Metering Regulation of RERC Clause 11(1)(a)(i).
2. In future if a consumer comes for Open Access the provision of stand by meter shall also be ensured and action for providing stand by meter of required specification shall be initiated on existing Open Access Consumers.
3. The defective/ stopped ABT complaint meter of Open Access Consumers shall be replaced immediately to avoid any complications for which necessary 15 days notice shall be served to the consumer by respective Executive Engineer (O&M) for replacement of the defective/stopped meter and same shall be installed in Co-ordination with M&P Wing.
4. As per prescribed norms the monthly reading of HT/EHT consumer's is to be taken jointly by O&M Wing & M&P Wing so the monthly readings of all ABT meters viz main meter, check meter etc. of Open Access Consumers shall be taken timely & jointly by O&M Wing and M&P Wing Officers.
5. Comparison of the same shall be furnished to Chief Engineer (Comml.) every month. In case difference between the readings of main and check meter, exceeds twice the percentage error applicable to relevant class. Both the meter shall be tested and one found defective shall be immediately replaced and reading of other will be considered.



6. The Sub-divisional officers should keep proper data to these monthly reading in record and back up of the same shall also be kept for future reference and record, if necessary. The main and check meter shall be periodically tested and sealed as per the provision.
7. Monthly data shall be sent to Chief Engineer (Comml.) on mail ID cecommercialavvnl@yahoo.co.in through email followed by hard copy containing required 15 minutes block wise data of relevant parameters. The same shall also be furnished to SLDC and Open Access Consumers and others as per Clause 17(5) of RERC Open Access Regulation.


Strict compliance of the above instructions be adhere.

By Order,


(G.R. Choudhary)
Chief Engineer (Comml.)

Copy to the following for information and necessary action:-

1. The Zonal Chief Engineer (O&M), AVVNL, Jhunjhunu/ Udaipur/ Ajmer.
2. The Secretary (Admn.), AVVNL, Ajmer
3. The Chief Accounts Officer(Account/Audit/Revenue), AVVNL, Ajmer
4. The Superintending Engineer (O&M), AVVNL, -----with----- Nos. of _____ spare copies for circulating among field officers.
5. The Superintending Engineer (M&P/Plan/MM/RDPPC), AVVNL, Ajmer/Udaipur/Jaipur.
6. The Superintending Engineer (IT), AVVNL, Ajmer for uploading the above circular on website.
7. The Addl.S.P. (Vig), AVVNL, Ajmer.
8. The Company Secretary, AVVNL, Ajmer
9. Shri P.N. Bhandari,IAS (Retd.), jaipur.
10. Sh.D.S. Agrawal, Rudraksh Energy, jaipur
11. Dr. K.L.Jain, Honorary Secretary,Raj Chamber of Commerce &Industry, Jaipur
12. Secretary General, Consumer Unity & Trust Society,('CUTS'), Jaipur
13. Chief Electrical (General) Engineer, O/o the G.M. (North), Jagatpura, Jaipur
14. Rajasthan Vidhyut Vikas Sansthan,, Vaishali Nagar, Jaipur
15. The Executive Engineer (_____), AVVNL, -----.
16. The Sr.Accounts Officer (_____), AVVNL, -----.
17. The Incharge of Legal Section AVVNL, Ajmer.
18. The Public Relation Officer, AVVNL, Ajmer.
19. The TA to MD, AVVNL, Ajmer.
20. The PA to Chairman Discoms Jaipur.
21. The PA to MD, Johhpur Discom, Jodhpur.
22. The PA to Director (Finance / Technical), AVVNL, Ajmer.
23. The PA to Electricity Ombudsman, GOR, Sahakar Marg, Jaipur.


Chief Engineer (Comml.)