



AJMER VIDYUT VITRAN NIGAM LIMITED

(Commercial Deptt.) (Website-www.avvnl.com)

Corporate Identification Number (CIN)-U40109RJ2000SGC016482

Regd. Off. Vidyut Bhawan, Panchsheel Nagar, Makadwali Road, Ajmer 305004

Tel No -0145 2644501 , Fax 01452644502, E-mail-cecomavvnl@gmail.com

No. AVVNL/ ACE(H.Q.)/SE(Comml)/XEN(C-II) /F. /2020-21/ D. 53 Dt. 14/5/20

ORDER

Sub:- Amendment in detailed Guidelines & procedure for Net Metering and Grid connectivity of grid connected Rooftop & Small Solar photovoltaic Systems.

Ref:-1. RERC Net Metering Regulations, 2015.

2. Comml Aj 580 dt.06.05.2015
3. Comml Aj 590 dt.24.07.2015
4. Comml Aj 601 dt 28.12.2015
5. Comml Aj 616 dt.05.06.2016
6. Comml Aj 623dt.10.08.2016
7. Comml Aj 638 dt.21.11.2016
8. Comml Aj 782 dt.03.07.2019
9. RERC S.M.O./20/01 Dt. 05.03.2020

The Detailed Guidelines & Procedure for Net Metering and Grid Connectivity of Grid Connected Rooftop & Small Solar Photovoltaic Systems have been issued vide Comml Aj 580, subsequently various amendments for Net Metering issued as referred above.

The RERC has issued the S.M.O./20/01 dt 05.03.2020 in the matter of Policy directives issued by the State Government u/s 108 (1) of Electricity Act, 2003 with regard to Solar / Wind / Wind-Solar Hybrid power generation in the state of Rajasthan and matters connected therewith.

Accordingly Clause D sub Clause (a) of Comml Aj 580 dt 06.05.2015 is amended as under;

“ The cumulative capacity to be allowed at a particular distribution transformer shall not exceed 50% of the capacity of the distribution transformer”

By Order,

N.S. Sahwal
14/05/20
(N.S. Sahwal)

Addl. Chief Engineer (HQ)