



AJMER VIDYUT VITRAN NIGAM LIMITED

(Commercial Deptt.) (Website-www.avvnl.com)

Corporate Identification Number (CIN)-U40109RJ2000SGC016482

Regd. Off. Vidyut Bhawan, Panchsheel Nagar, Makadwali Road, Ajmer 305004
Tel No -0145 2644501 , Fax 01452644502, E-mail-cccomavvnl@gmail.com

No. AVVNL/ ACE(H.Q.)/SE(Comml)/XEN(C-II) /F.

/2020-21/D 2702 Dt. 23-2-2)

CIRCULAR

Sub:- Regarding to provide additional metering at the premises of HT supply consumers for power factor purpose..

The new HT connections of higher connected load / demand are generally released through dedicated feeder emanating from 220/132/33 KV GSS and metering in such cases is provided at GSS. Sometimes due to ROW problem full feeder or part of the feeder is laid down by laying underground cable. In case of long length of the cable, power factor goes on leading side due to capacitance effect of the cable in no load condition which leads to poor power factor recording in the meter and resulting with power factor surcharge levied on the consumers.

Looking to such problem of consumers, an order Comml Aj 556 Dt 01.10.2014 was issued allowing the additional metering equipment at their premises for the purpose of recording proper power factor, subject to condition that in such cases the billing will be done on the basis of reading of meter installed at consumer's premises and the difference of KWH reading of two meters (one at GSS and other at consumer's premises) will be charged from the consumer.

The matter was discussed in the 26th meeting of reconstituted Co- ordination Committee where the said order is partially modified as under:-

“ In the cases of consumers having poor power factor and additional metering is provided at consumer's end, the billing will be done on the basis of reading of Main meter installed at 220/132/33 KV GSS and power factor will be taken from the Standby meter installed at consumer's premises.”

All concerned are directed to comply with the above directions.

M. C. Baldi

(M.C.Baldi)

Addl.Chief Engineer (HQ)

AVVNL Ajmer

Copy to the following for information and necessary action:-

1. The Zonal Chief Engineer (O&M), AVVNL, Jhunjhunu/ Udaipur/ Ajmer.
2. The Addl.Chief Engineer (MM / T&S-CSS), AVVNL, Ajmer.
3. The Secretary (Admn.), AVVNL, Ajmer
4. The Chief Accounts Officer (IA-W&M/ATP/ERB), AVVNL, Ajmer/Jaipur
5. The Superintending Engineer (O&M/ADC/ACC), AVVNL, -----with-----
Nos. of _____ spare copies for circulating among field officers.
6. The Superintending Engineer (M&P/Plan/MM/TW/DDUGJY/Vig/Legal), AVVNL,Ajmer/ Udaipur
/ Sikar/Jaipur.
7. The Superintending Engineer (IT), AVVNL, Ajmer for uploading the above circular on website.
8. The Addl.S.P. (Vig), AVVNL, Ajmer.
9. The Company Secretary, AVVNL, Ajmer
10. The Addl. Chief Secretary, Administrative Reforms (TIMES) Department, Jaipur on
email ID : cmv@rajasthan.gov.in
11. The TA to MD, AVVNL, Ajmer
12. The TA to Director (Technical), AVVNL, Ajmer.
13. The Executive Engineer (_____), AVVNL, -----.
14. The Sr.Accounts Officer (_____), AVVNL, -----.
15. The Executive Engineer (Comml-II), AVVNL, Ajmer.
16. The Public Relation Officer, AVVNL, Ajmer.
17. The PA to MD, Ajmer Discom, Ajmer for perusal of MD Sir.
18. The PA to Chairman Discoms Jaipur.
19. The Secretary General, Consumer Unity & Trust Society,('CUTS'), D-217, Bhaskar Marg Bani
Park, Jaipur
20. The Chief Electrical (General)Engineer, North Western Railway, Near Jawahar Circle, Jagatpura,
Jaipur
21. Sh K.L.Jain Honorary Secretary General, Raj. Chamber Of Commerce & Industries, Raj. Chamber
Bhawan, M.I.Road Jaipur.
22. Sh Hazari Lal Gujar, B-57, Shakti Nagar, Tonk Road Jaipur.
23. Sh. Mani Lal Labana, 381, Indra Nagar, Near 132 KV GSS, Dungarpur.
24. Sh D.S. Agarwal, Rudraksh Energy, R-15-A, Yudhishtar Marg C Scheme, Jaipur
25. Sh R.A.Gupta, Professor, MNIT, JLN Road, Malviya Nagar Jaipur.
26. The PA to MD, Jaipur/Jodhpur Discom, Jaipur/Jodhpur.
27. The PA to Director (Finance), AVVNL, Ajmer.
28. The PA to Electricity Ombudsman, GOR, Sahakar Marg, Jaipur.
29. The Head Corporate Affairs, M/s TPADL (Distribution Franchisee), Vaishali Nagar Power House,
Ajmer.
- 30.The Corporate Head, M/s Secure Metering & Service Pvt Ltd. (MBC), 13, Gandhi nagar, near
Punjab & Sindh Bank Bhilwara.


Addl. Chief Engineer (HQ)
AVVNL Ajmer