

Speed Post/Fax

	<b>AJMER VIDYUT VITRAN NIGAM LIMITED</b> (MATERIAL MANAGEMENT WING) Corporate Identification Number (CIN)- U40109RJ2000SGC016482 Regd. Off. Vidyut Bhawan, Panchsheel Nagar, Makarwali Road, Ajmer-305004 Phone:-0145-2644529, Fax:-0145-2644542. E-mail:semnavvnl@gmail.com, Website-www.avvnl.com
---	--

No. AVVNL/SE (MM)/E2A7/TN-1085/D.

6779

/Date. 04 NOV 2016

### AMENDMENTS


**Sub:- TENDER ENQUIRY FOR SUPPLY OF AC STATIC SINGLE PHASE, TWO WIRE, HAVING DLMS PROTOCOL WITH OPTICAL & ADDITIONAL LPR PORT, 5-30 AMP. RATING, WHOLE CURRENT, CLASS 1.0 ACCURACY KWh ENERGY METERS WITH BACKLIT LCD DISPLAY ALONG WITH SEPERATE METER CUPBOARD UNDER TN-1085 OF AVVNL**

The amendments in the above technical specification are issued as under:-

#### Technical Specification

1. The date of opening of Bids which was earlier schedule to be on 08.11.2016 at 2.30 PM is hereby amended as 23.11.2016 at 2.30 PM.
2. Following clause of specification of TN-1085 are hereby amended to be read as under:-

S. No.	As per Particular clause to Spec.	To be read as under
1	7.5 (C) III	The words "as well as additional connecting cable of minimum 1.5 mtr. length for spot billing compatible to optical port of the meter and SBM" appearing in this clause are hereby deleted.
2	12 (b) (ix) point no. 4 of table (Particulars of Tests)	The words "and meter base cut tamper" appearing in this clause are hereby deleted.
3	Annexure-A-1 point no. 28A(a) III of GTP	This point of GTP is hereby deleted.
4	12(a) (i)	This clause is hereby amended to read as:- The bidders shall be required to furnish valid type test reports in respect of single phase static energy meters with optical port as per the requirement of IS 13779:1999 from CPRI, or ERDA only which should not be older than three years as on the date of opening of techno-commercial bid. For this purpose date of conducting type test will be considered.
5	PQR Cl. No. VI	A Foot Note is added below the PQR Clause no. VI as under:- "Note:-The bidders are required to furnish one CMRI and LPR model along with communication cables so that the bid stage samples may be got checked /verified."

  
 (Ashok Kumar)  
 Superintending Engineer (MM),  
 AVVNL, Ajmer.