



## AJMER VIDYUT VITRAN NIGAM LIMITED

(Commercial Deptt.)

Corporate Identification Number (CIN)-U40109RJ2000SGC016482  
Regd. Off Vidyut Bhawan, Panchsheel Nagar, Makarwali Road, Ajmer-305004  
Phone No. 0145-2644501, Fax-2644502 E-Mail:- cecomavvnl@gmail.com  
Website-www.energy.rajasthan.gov.in/avvnl



NO. AVVNL/ACE (HQ)/SE(C)/XEN-I /F. 105C/2020-21/D. 94

Dated 19/05/2020

The Secretary,  
Rajasthan Electricity Regulatory Commission,  
Vidyut Viniyamak Bhawan, Sahkar Marg,  
Near State Motor Garage, Jaipur.

Sub: - Regarding submission of SAIFI & SAIDI information in SOP-4 and SOP-5 formats for the month of March-2020.

Sir,

In reference to implementation of BRAP (Business Reform Action Plan) of GoR, the SOP information in respect of SAIFI (SOP-4) and SAIDI (SOP-5) for the month of March-2020 is enclosed herewith for publishing / uploading on Hon'ble Commission's website.

Encl.:- As above.

*N. S. Sarwal*  
(N. S. Sarwal)

Addl. Chief Engineer (HQ)

Copy to the following for information & needful action please.

1. The Electricity Ombudsman Rajasthan, Jaipur.
2. The Superintending Engineer (IT) AVVNL, Ajmer for uploading on Nigam website.

Encl.:- As above.

*N. S. Sarwal*  
(N. S. Sarwal)  
Addl. Chief Engineer (HQ)

**Reliability Indices**  
**System Average Interruption Frequency Index (SAIFI)**

SOP-4

For the month March-2020

**Name of Licensee:-Ajmer Discom**

S.No.	Name of Circle	Total number of consumers served (1)	Total number of sustained interruptions to consumers (2)	SAIFI = (2) / (1) ( Number of interruptions/ consumer)	Target specified by the Commission
1	AJMER (ACC)	365906	3179876	8.69	
2	AJMER (ADC)	268597	2418793	9.01	
3	BHILWARA	537291	3838933	7.14	
4	CHITTORGARH	353760	1150132	3.25	
5	UDAIPUR	658326	2064394	3.14	
6	BANSWARA	296965	1213456	4.09	
7	NAGAU	631753	2409596	3.81	
8	SIKAR	631433	2432397	3.85	
9	JHUNJHUNU	511307	1753969	3.43	
10	RAJASAMAND	279804	1702198	6.08	
11	DUNGARPUR	316388	626235	1.98	
12	PRATAPGARH	186060	666540	3.58	
	<b>Total</b>	<b>5037590</b>	<b>23456519</b>	<b>4.66</b>	

**Reliability Indices**  
**System Average Interruption Duration Index (SAIDI)**

**Name of Licensee:-Ajmer Discom**

**SOP-5**  
**For the month March-2020**

S.No.	Name of Circle	Total number of consumers served (1)	Total minutes of sustained interruptions to consumers (2)	SAIDI = (2) / (1) (Minutes/consumer)	Target specified by the Commission
1	AJMER (ACC)	365906	35029667	95.73	
2	AJMER (ADC)	268597	29860485	111.17	
3	BHILWARA	537291	40949176	76.21	
4	CHITTORGARH	353760	16001205	45.23	
5	UDAIPUR	658326	12379345	18.80	
6	BANSWARA	296965	3356879	11.30	
7	NAGAUR	631753	15092563	23.89	
8	SIKAR	631433	44750373	70.87	
9	JHUNJHUNU	511307	11359996	22.22	
10	RAJASAMAND	279804	12590227	45.00	
11	DUNGARPUR	316388	4692322	14.83	
12	PRATAPGARH	186060	5168448	27.78	
	<b>Total</b>	<b>5037590</b>	<b>226062238</b>	<b>44.88</b>	