



AJMER VIDYUT VITRAN NIGAM LIMITED

(Commercial Deptt.)

Corporate Identification Number (CIN)-U40109RJ2000SGC016482
Regd. Off VidyutBhawan, Panchsheel Nagar, Makarwali Road, Ajmer-305004
Phone No. 0145-2644501, Fax-2644502E-Mail:- cecomavvnl@gmail.com
Website-www.energy.rajasthan.gov.in/avvnl



NO. AVVNL/ACE (HQ)/SE(C)/ XEN-I /F. 105C/2020-21/D. 502

Dated 13/07/20


The Secretary,
Rajasthan Electricity Regulatory Commission,
VidyutViniyamakBhawan, SahkarMarg,
Near State Motor Garage, Jaipur.

Sub: -Regarding submission of SAIFI & SAIDI information in SOP-4 and SOP-5 formats for the month of May-2020.

Sir,

In reference to implementation of BRAP (Business Reform Action Plan) of GoR, the SOP information in respect of SAIFI (SOP-4) and SAIDI (SOP-5) for the month of May-2020 is enclosed herewith for publishing / uploading on Hon'ble Commission's website.

Encl.:- As above.



(N. S. Sanwal)

Addl. Chief Engineer (HQ)

Copy to the following for information & needful action please.

1. The Electricity Ombudsman Rajasthan, Jaipur.
2. The Superintending Engineer (IT) AVVNL, Ajmer for uploading on Nigam website.

Encl.:- As above.


Addl. Chief Engineer (HQ)

Reliability Indices
System Average interruption Frequency Index (SAIFI)

SOP-4

Name of Licensee:-Ajmer Discom

For the month May-2020

| S.No. | Name of Circle | Total number of consumers served (1) | Total number of sustained interruptions to consumers (2) | SAIFI = (2) / (1) (Number of interruptions/ consumer) | Target specified by the Commission |
|-------|----------------|--------------------------------------|--|--|------------------------------------|
| 1 | AJMER (ACC) | 366129 | 3512109 | 9.59 | |
| 2 | AJMER (ADC) | 269128 | 2421171 | 9.00 | |
| 3 | BHILWARA | 538970 | 3412414 | 6.33 | |
| 4 | CHITTORGARH | 354470 | 1218447 | 3.44 | |
| 5 | UDAIPUR | 659446 | 2296112 | 3.48 | |
| 6 | BANSWARA | 297567 | 1182456 | 3.97 | |
| 7 | NAGPUR | 634170 | 2419595 | 3.82 | |
| 8 | SIKAR | 632177 | 2425379 | 3.84 | |
| 9 | JHUNJHUNU | 511882 | 1753982 | 3.43 | |
| 10 | RAJASAMAND | 280348 | 1712496 | 6.11 | |
| 11 | DUNGARPUR | 318506 | 956635 | 3.00 | |
| 12 | PRATAPGARH | 186816 | 781920 | 4.19 | |
| | Total | 5049609 | 24092716 | 4.77 | |

Reliability Indices
System Average interruption Duration Index (SAIDI)

SOP-5

Name of Licensee:-Ajmer Discom

For the month May-2020

| S.No. | Name of Circle | Total number of consumers served (1) | Total minutes of sustained interruptions to consumers (2) | SAIDI = (2) / (1) (Minutes/ consumer) | Target specified by the Commission |
|-------|----------------|--------------------------------------|---|---------------------------------------|------------------------------------|
| 1 | AJMER (ACC) | 366129 | 39798955 | 108.70 | |
| 2 | AJMER (ADC) | 269128 | 29308126 | 108.90 | |
| 3 | BHILWARA | 538970 | 18746561 | 34.78 | |
| 4 | CHITTORGARH | 354470 | 16401170 | 46.27 | |
| 5 | UDAIPUR | 659446 | 23543927 | 35.70 | |
| 6 | BANSWARA | 297567 | 3568749 | 11.99 | |
| 7 | NAGPUR | 634170 | 15179456 | 23.94 | |
| 8 | SIKAR | 632177 | 44307375 | 70.09 | |
| 9 | JHUNJHUNU | 511882 | 11359946 | 22.19 | |
| 10 | RAJASAMAND | 280348 | 12673139 | 45.21 | |
| 11 | DUNGARPUR | 318506 | 5792322 | 18.19 | |
| 12 | PRATAPGARH | 186816 | 4187520 | 22.42 | |
| | Total | 5049609 | 224867246 | 44.53 | |