

**Peak Load Reports of transformers at Various 400kV/220 KV / 132 KV GSS under Zonal CE(T&C)
Ajmer during FY 2020-21**

Name of Zone:-ZCE (T&C) RVPNL, Ajmer

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5
Name of Circle:-SE (T&C) RVPN, Ajmer				
400 KV GSS Ajmer	Ajmer	400/220	315	272.00
		400/220	315	284.00
220 KV GSS Beawar	Ajmer	220/132	100	85.00
		220/132	100	68.00
		220/132	100	77.00
		132/33	40/50	36.00
		132/33	20/25	23.00
		132/33	20/25	21.00
132 KV GSS Nasirabad	Ajmer	132/33	20/25	23.82
		132/33	20/25	24.09
132 KV GSS Sawar	Ajmer	132/33	10/12.5	8.51
		132/33	10/12.5	8.51
132 KV GSS Kekri	Ajmer	132/33	20/25	20.94
		132/33	20/25	23.32
220 KV GSS Kishangarh	Ajmer	220/132	100	82.42
		220/132	100	78.48
		132/33	20/25	24.22
132KV GSS Kishangarh	Ajmer	132/33	40/50	35.00
		132/33	20/ 25	23.00
		132/33	20/ 25	23.00
132 KV GSS Roopangarh	Ajmer	132/33	40/50	36.98
		132/33	20/ 25	21.69
132 KV GSS Silora	Ajmer	132/33	20/ 25	16.49
		132/33	20/ 25	17.44
132 KV GSS Arain	Ajmer	132/33	20/ 25	12.44
		132/33	10/12.5	9.04
220 KV GSS Jethana	Ajmer	220/132	160	128.18
		132/33	20/25	13.72
132 KV GSS Masuda	Ajmer	132/33	10/12.5	9.14
		132/33	10/12.5	11.02
132 KV GSS Saradhana	Ajmer	132/33	40/50	25.05
		132/33	20/ 25	16.25
220 KV GSS Ajmer	Ajmer	220/132	160	88.09
		220/132	160	90.44
		132/33	40/50	34.57
		132/33	20/25	23.31
		132/33	20/25	22.73
132 KV GSS Pushkarroad	Ajmer	132/33	20/25	17.47
		132/33	20/25	19.66
132 KV GSS Subhash Nagar	Ajmer	132/33	20/25	20.76
13 2KV GSS Pushkar	Ajmer	132/33	20/25	19.13
		132/33	20/25	20.49
132 KV GSS MDSU	Ajmer	132/33	40/50	25.41
		132/33	20/25	13.54
132 KV GSS Patan	Ajmer	132/33	20/25	8.45
Name of Circle:- SE(T&C) RVPN, Merta City				
400 KV GSS Merta	Nagaur	400/220	315	307.00
		400/220	315	292.00
		220/132	100	98.00
		220/132	100	90.00
		220/132	100	96.00
132 KV GSS Mertacity	Nagaur	132/33	40/50	28.21
		132/33	20/25 + 10/12.5	29.47
132 KV GSS Gotan	Nagaur	132/33	40/50	34.91
		132/33	10/12.5	8.61
132 KV GSS Lamba Jatan	Nagaur	132/33	20/25	16.17
		132/33	20/25	15.85
132 KV GSS Merta Road	Nagaur	132/33	40/50	31.52
		132/33	20/25	21.62

2

**Peak Load Reports of transformers at Various 400kV/220 KV / 132 KV GSS under Zonal CE(T&C)
Ajmer during FY 2020-21**

Name of Zone:-ZCE (T&C) RVPNL, Ajmer

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5
220 KV GSS Bherunda(upgrade)	Nagaur	220/132	160	118.16
		132/33	20/25	19.44
		132/33	20/25	22.08
		132/33	16/20	15.00
220 KV GSS Khinvsar	Nagaur	220/132	160	138.64
		220/132	100	97.49
		132/33	40/50	36.14
		132/33	20/25	21.00
132 KV GSS Heesaba	Nagaur	132/33	40/50	34.20
		132/33	40/50	38.64
132 KV GSS Narwa	Nagaur	132/33	40/50	0.00
		132/33	20/25	21.22
132 KV GSS Deh	Nagaur	132/33	20/25	12.14
220 KV GSS Kuchaman City	Nagaur	220/132	100	72.30
		220/132	100	66.87
		132/33	40/50	16.00
		132/33	20/25	23.23
132 KV GSS Dayalpura	Nagaur	132/33	20/25	14.56
		132/33	20/25	14.56
132 KV GSS Chitawa	Nagaur	132/33	20/25	20.93
		132/33	20/25	20.93
132 KV GSS Deedwana	Nagaur	132/33	20/25	16.46
		132/33	20/25	16.00
220 KV GSS Kuchera	Nagaur	220/132	160	135.63
		132/33	20/25	20.06
132 KV GSS Degana	Nagaur	132/33	20/25	9.96
132 KV GSS Mundwa	Nagaur	132/33	20/25	11.51
		132/33	20/25	12.67
132 KV GSS Kuchera	Nagaur	132/33	40/50	27.66
		132/33	20/25	18.28
		132/33	10/12.5	9.14
		132/11	10/12.5	10.40
132 KV GSS Sanjoo	Nagaur	132/33	40/50	42.78
		132/33	20/25	22.52
132 KV GSS Roon	Nagaur	132/33	20/25	14.97
		132/33	20/25	14.52
132 KV GSS Jayal	Nagaur	132/33	20/25	21.72
		132/33	20/25	22.92
220 KV GSS Makrana	Nagaur	220/132	100	47.00
		220/132	100	49.00
		132/33	40/50	32.00
		132/33	20/25	21.00
132 KV GSS Bagot	Nagaur	132/33	20/25	19.66
		132/33	20/25	22.34
132 KV GSS Bidiyad	Nagaur	132/33	20/25	20.10
		132/33	20/25	20.65
132 KV GSS Nawa City	Nagaur	132/33	40/50	24.42
		132/33	20/25	15.55
132 KV GSS Parbatsar	Nagaur	132/33	20/25	7.80
220 KV GSS Nagaur	Nagaur	220/132	100	72.46
		220/132	100	87.31
		220/132	100	67.53
		132/33	40/50	33.88
		132/33	20/25	23.64
132 KV GSS Ladnun	Nagaur	132/33	20/25	20.00
		132/33	20/25	23.48
132 KV GSS Gogelaw	Nagaur	132/33	20/25	21.55

(Handwritten mark)

**Peak Load Reports of transformers at Various 400kV/220 KV / 132 KV GSS under Zonal CE(T&C)
Ajmer during FY 2020-21**

Name of Zone:-ZCE (T&C) RVPNL, Ajmer

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5
Name of Circle:-SE (T&C) RVPN, Chittorgarh				
400 KV GSS Chittorgarh	Chittorgarh	400/220	315	305.00
		400/220	315	307.00
220 KV GSS Pratapgarh	Pratapgarh	220/132	160	139.81
		220/132	160	144.01
		132/33	40/50	44.54
		132/33	20/25	23.19
		132/33	20/25	21.55
132 KV GSS Mokhampura (Pratapgarh)	Pratapgarh	132/33	10/12.5	10.67
132 KV GSS Dhariyad	Pratapgarh	132/33	20/25	23.50
132 KV GSS Dalot	Pratapgarh	132/33	40/50	37.81
		132/33	20/25	21.87
220 KV GSS Chittorgarh	Chittorgarh	220/132	100	88.67
		220/132	100	89.69
		220/132	100	76.53
		132/33	40/50	30.01
		132/33	20/25	19.78
		132/11	6.3/8	1.52
132 KV GSS Begun	Chittorgarh	132/33	40/50	43.00
		132/33	20/25	24.00
132 KV GSS Ajoliya Ka Khera	Chittorgarh	132/33	20/25	18.32
		132/33	20/25	20.05
132 KV GSS Bassi	Chittorgarh	132/33	20/25	22.27
		132/33	10/12.5	11.14
132 KV GSS Rashmi	Chittorgarh	132/33	20/25	22.51
		132/33	10/12.5	11.70
132 KV GSS RAPP Rawatbhata	Chittorgarh	132/33	10/12.5	10.97
132 KV GSS Baroli Rawatbhata	Chittorgarh	132/33	20/25	18.46
		132/33	10/12.5	9.28
		220/132	160	121.74
220 KV GSS Nimbahera	Chittorgarh	220/132	100	88.61
		132/33	40/50	41.97
		132/33	20/25	22.27
		132/33	20/25	21.82
		132/33	20/25	16.10
132 KV GSS Rasoolpura	Chittorgarh	132/33	20/25	14.37
132 KV GSS Kanera	Chittorgarh	132/33	20/25	14.04
132 KV GSS Bijaipur	Chittorgarh	132/33	20/25	18.64
132 KV GSS Joojhpura	Chittorgarh	132/33	20/25	22.46
		132/33	20/25	22.46
132 KV GSS Chotisadri	Pratapgarh	132/33	40/50	41.81
		132/33	20/25	22.34
220 KV GSS Sawa	Chittorgarh	220/132	160	108.65
		220/132	100	91.88
		132/33	20/25	20.71
		132/33	10/12.5	9.87
132 KV GSS Kapasan	Chittorgarh	132/33	40/50	39.46
		132/33	20/25	17.81
132 KV GSS Senth	Chittorgarh	132/33	40/50	12.66
		132/33	20/25	12.80
132 KV GSS Mangalwar	Chittorgarh	132/33	20/25	22.52
		132/33	20/25	21.62
132 KV GSS Bhadesar	Chittorgarh	132/33	20/25	20.27
		132/33	20/25	20.50
220 KV GSS Banswara	Banswara	220/132	100	82.60
		220/132	100	65.00
		132/33	40/50	35.70
		132/33	20/25	23.77

BR

**Peak Load Reports of transformers at Various 400kV/220 KV / 132 KV GSS under Zonal CE(T&C)
Ajmer during FY 2020-21**

Name of Zone:-ZCE (T&C) RVPNL, Ajmer

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5
132 KV GSS Bagidora	Banswara	132/33	20/25	16.34
		132/33	10/12.5	8.17
132 KV GSS Kushalgarh	Banswara	132/33	20/25	18.18
		132/33	10/12.5	9.09
132 KV GSS Peeplawa	Banswara	132/33	20/25	16.92
132 KV GSS Paloda	Banswara	132/33	20/25	18.45
132 KV GSS Partapur	Banswara	132/33	20/25	21.78
132 KV GSS Ghatol	Banswara	132/33	20/25	21.44
132 KV GSS Dhoriya Chauraha	Chittorgarh	132/33	20/25	23.90
132 KV GSS Bhopalsagar	Chittorgarh	132/33	20/25	17.30
132 KV GSS Chordi (NC)	Banswara	132/33	20/25	18.47
132 KV GSS Kuwkhera (NC)	Chittorgarh	132/33	20/25	10.89
Name of Circle:-SE(T&C) RVPN, Babai				
400 KV GSS Babai	Jhunjhunu	400/220	315	243.00
		400/220	315	287.00
		220/132	160	67.00
220 KV GSS Chirawa	Jhunjhunu	220/132	100	92.00
		220/132	100	90.00
		132/33	40/50	31.00
132 KV GSS Pilani	Jhunjhunu	132/33	20/25	21.00
		132/33	40/50	24.74
		132/33	20/25	18.98
132 KV GSS Nangali	Jhunjhunu	132/11	10/12.5	1.14
		132/11	10/12.5	1.15
		132/33	20/25	19.00
132 KV GSS Surajgarh	Jhunjhunu	132/33	20/25	19.00
		132 /33	20/25	17.76
132 KV GSS Mahapalwas	Jhunjhunu	132 /33	20/25	17.76
		132/33	20/25	24.71
132 KV GSS Dulaniya	Jhunjhunu	132/33	20/25	24.71
		132/33	20/25	24.83
132 KV GSS Sultana	Jhunjhunu	132/33	20/25	20.88
		132/33	20/25	18.24
220 KV GSS Khetri Nagar	Jhunjhunu	220/132	100	18.24
		220/132	100	91.00
		220/33	50	86.00
		220/33	35	36.00
132 KV GSS Mehada	Jhunjhunu	220/33	35	21.00
		220/33	35	28.00
132 KV GSS Gudagorji	Jhunjhunu	132/33	20/25	18.00
		132/33	10/12.5	7.00
132 KV GSS Nawalgarh	Jhunjhunu	132/33	40/50	32.00
		132/33	20/25	19.00
132 KV GSS Babai	Jhunjhunu	132/33	40/50	37.00
		132/33	20/25	22.00
132 KV GSS Buhana	Jhunjhunu	132/33	20/25	23.00
		132/33	20/25	22.00
220 KV GSS Jhunjhunu	Jhunjhunu	132/33	40/50	25.00
		132/33	20/25	18.00
		132/33	20/25	18.00
132 KV GSS Bherunda kalan	Jhunjhunu	220/132	100	91.61
		220/132	100	93.66
		220/132	100	77.02
132 KV GSS Bissau	Jhunjhunu	132/33	20/25	10.20
		132/33	25/25	19.91
132 KV GSS Udaipurwati	Jhunjhunu	132/33	20/25	20.07
		132/33	20/25	14.69
		132/33	10/12.5	10.83
		132/33	20/25	17.60
		132/33	20/25	21.49

2

**Peak Load Reports of transformers at Various 400kV/220 KV / 132 KV GSS under Zonal CE(T&C)
Ajmer during FY 2020-21**

Name of Zone:-ZCE (T&C) RVPNL, Ajmer

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5
132 KV GSS Malsisar	Jhunjhunu	132/33	20/25	9.48
		132/33	10/12.5	7.14
132 KV GSS Jhunjhunu	Jhunjhunu	132/33	40/50	42.00
		132/33	20/25	24.36
132 KV GSS Kumawas	Jhunjhunu	132/33	20/25	22.44
		132/33	20/25	21.17
132 KV GSS Mandawa	Jhunjhunu	132/33	20/25	24.26
		132/33	10/12.5	11.54
132 KV GSS Baggar	Jhunjhunu	132/33	20/25	16.89
		132/33	10/12.5	8.39
132 KV GSS Mandrella	Jhunjhunu	132/33	20/25	17.89
		132/33	20/25	15.39
Name of Circle:-SE(T&C) RVPN, Bhilwara				
400 KV GSS Bhilwara	Bhilwara	400/220	315	Out of ckt since 12.05.2019 due to internal gas formation
		400/220	315	289.00
220 KV GSS Bhilwara	Bhilwara	220/132	160	125.48
		220/132	160	125.48
		220/132	100	80.75
		132/33	40/50	35.00
		132/33	20/25	18.45
		132/33	20/25	22.00
132 KV GSS Gangapur	Bhilwara	132/33	20/25	21.00
		132/33	20/25	18.00
132 KV GSS RIICO Bhl	Bhilwara	132/33	40/50	42.00
		132/33	20/25	19.00
132 KV GSS Danta	Bhilwara	132/33	20/25	19.67
		132/33	20/25	18.53
132 KV GSS Karera	Bhilwara	132/33	20/25	20.82
		132/33	20/25	20.82
132 KV GSS Raipur	Bhilwara	132/33	20/25	18.30
220 KV GSS Mandalgarh	Bhilwara	220/132	100	90.91
		220/132	100	0.00
		132/33	20/25	5.49
132 KV GSS Mandalgarh	Bhilwara	132/33	20/25	16.14
		132/33	20/25	19.12
132 KV GSS Bigod	Bhilwara	132/33	20/25	22.55
		132/33	20/25	21.62
132 KV GSS Bijoliya	Bhilwara	132/33	20/25	21.19
		132/33	20/25	22.51
132 KV GSS Kachola	Bhilwara	132/33	20/25	23.12
132 KV GSS Asind	Bhilwara	132/33	20/25	20.59
		132/33	20/25	22.65
132 KV GSS Pratapura	Bhilwara	132/33	20/25	14.41
132 KV GSS Raila	Bhilwara	132/33	20/25	13.50
		132/33	10/12.5	8.01
220 KV GSS Gulabpura	Bhilwara	220/132	100	82.40
		220/132	100	85.01
		132/33	20/25	18.57
		132/33	20/25	19.02
132 KV GSS Jahajpur	Bhilwara	132/33	20/25	4.07
132 KV GSS Shahpura	Bhilwara	132/33	20/25	14.68
132 KV GSS Shahpura	Bhilwara	132/33	20/25	18.98

M

**Peak Load Reports of transformers at Various 400kV/220 KV / 132 KV GSS under Zonal CE(T&C)
Ajmer during FY 2020-21**

Name of Zone:-ZCE (T&C) RVPNL, Ajmer

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5
220 KV GSS Hamirgarh	Bhilwara	220/132	100	78.55
		220/132	100	85.74
		132/33	40/50	36.26
		132/33	20/25	23.12
		132/33	20/25	24.72
132 KV GSS Suwana	Bhilwara	132/33	40/50	30.89
		132/33	20/25	18.89
132 KV GSS RIICO Growth Centre Hamirgarh	Bhilwara	132/33	40/50	23.00
132 KV GSS Kotri	Bhilwara	132/33	20/25	22.57
Name of Circle:- SE (T&C) RVPNL, Sikar				
220 KV GSS Sikar	Sikar	220/132	160	138.80
		220/132	160	112.64
		220/132	100	76.65
		132/33	40/50	34.68
		132/33	40/50	39.70
		132/33	20/25	21.27
132 KV GSS Ranoli	Sikar	132/33	20/25	21.57
		132/33	20/25	23.00
132 KV GSS Piprali	Sikar	132/33	20/25	20.00
		132/33	40/50	34.29
132 KV GSS Kudan	Sikar	132/33	20/25	22.63
		132/33	20/25	23.42
132 KV GSS Neem Ka Thana	Sikar	132/33	20/25	23.44
		132/33	40/50	29.40
132 KV GSS, Water Works, Sikar	Sikar	132/33	20/25	23.12
		132/33	40/50	22.14
220 KV GSS Dhod	Sikar	132/33	20/25	20.50
		220/132	100	68.09
		220/132	100	68.09
		132/33	40/50	24.69
		132/33	20/25	22.63
132 KV Losal	Sikar	132/33	20/25	17.63
		132/33	20/25	12.57
132 KV GSS Patan	Sikar	132/33	20/25	12.57
		132/33	20/25	20.04
132 KV GSS Khood	Sikar	132/33	20/25	20.04
		132/33	20/25	12.34
132 KV GSS Kachawa	Sikar	132/33	20/25	12.11
		132/33	20/25	21.57
220 KV GSS Reengus	Sikar	132/33	20/25	22.34
		220/132	160	141.47
		220/132	160	156.47
		132/33	20/25	20.09
		132/33	20/25	20.09
132 KV Ricco Reengus	Sikar	132/33	20/25	20.09
		132/33	20/25	19.96
132 KV Shrimadhapur	Sikar	132/33	20/25	22.13
		132/33	20/25	13.24
132 KV GSS Ajeetgarh	Sikar	132/33	20/25	14.34
		132/33	20/25	18.06
132 KV GSS Thoi	Sikar	132/33	20/25	17.62
		132/33	20/25	20.34
		132/33	20/25	10.17

Handwritten mark

**Peak Load Reports of transformers at Various 400kV/220 KV / 132 KV GSS under Zonal CE(T&C)
Ajmer during FY 2020-21**

Name of Zone:-ZCE (T&C) RVPNL, Ajmer

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5
132 KV GSS Sanwalpura	Sikar	132/33	20/25	0.00
		132/33	10/12.5	11.75
132 KV GSS Khandelamod	Sikar	132/33	20/25	14.87
		132/33	10/12.5	12.29
220 KV GSS Laxmangarh	Sikar	220/132	100	88.00
		132/33	40/50	24.42
132 KV GSS Fatehpur	Sikar	132/33	20/25	23.32
		132/33	20/25	20.33
132 KV GSS Antroli	Sikar	132/33	20/25	21.96
		132/33	10/12.5	20.78
220 KV GSS DantaRamgarh	Sikar	220/132	100	7.72
		132/33	40/50	73.70
132 KV GSS Khatushyamji	Sikar	132/33	20/25	31.50
		132/33	20/25	21.20
132 KV GSS Khachariyawas	Sikar	132/33	20/25	20.57
		132/33	10/12.5	20.57
				14.86
				8.00

Name of Circle:- SE (T&C) RVPN, Udaipur

220 KV GSS Amberi	Udaipur	220/132	160	142.27
		220/132	160	Out of ckt since 12.05.2019 due to internal gas formation & under repair
132 KV GSS Jhadol	Udaipur	132/33	20/25	17.89
		132/33	10/12.5	8.99
132 KV GSS Gogunda	Udaipur	132/33	20/25	19.38
		132/33	40/50	37.15
132 KV GSS Sisarama	Udaipur	132/33	20/25	17.70
		132/33	40/50	30.22
132 KV GSS Sukher	Udaipur	132/33	20/25	17.40
		132/33	20/25	87.14
220 KV GSS Kankroli	Rajsamand	220/132	100	72.68
		220/132	100	35.40
132 KV GSS Kankroli	Rajsamand	132/33	40/50	19.95
		132/33	20/25	20.13
132 KV GSS Nathdwara	Rajsamand	132/33	20/25	18.09
		132/33	20/25	42.48
132 KV GSS Mokhampura	Rajsamand	132/33	40/50	19.29
		132/33	20/25	22.29
132 KV GSS Sanwad	Udaipur	132/33	20/25	10.92
132 KV GSS Sapol	Rajsamand	132/33	20/25	96.70
220 KV GSS Aspur	Dungarpur	220/132	100	19.40
		132/33	20/25	35.49
132 KV GSS Dungarpur	Dungarpur	132/33	40/50	20.43
		132/33	20/25	14.35
132 KV GSS Sagwara	Dungarpur	132/33	20/25	14.35
		132/33	20/25	24.39
132 KV GSS Salumber	Udaipur	132/33	10/12.5	12.31
		132/33	20/25	24.00
220 KV GSS Debari	Udaipur	132/33	20/25	116.00
		220/132	160	106.00
		220/132	100	61.00
		220/132	100	92.00
		220/132	50	31.00
		132/33	16/20	13.00
		132/33	14.6/20	14.00
		132/33	10/12.5	10.00
132 KV GSS Pratapnagar	Udaipur	132/33	40/50	38.35
		132/33	20/25	23.28

(Handwritten signature)

**Peak Load Reports of transformers at Various 400kV/220 KV / 132 KV GSS under Zonal CE(T&C)
Ajmer during FY 2020-21**

Name of Zone:-ZCE (T&C) RVPNL, Ajmer

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5
132 KV GSS Mavli	Udaipur	132 /33	20/25	21.17
		132 /33	10/12.5	11.48
132 KV GSS Dariba	Rajsamand	132 /33	20/25	21.74
		132 /33	20/25	22.23
132 KV GSS Bhinder	Udaipur	132 /33	20/25	23.33
132 KV GSS Bhatewar	Udaipur	132 /33	20/25	20.72
		132 /33	20/25	23.11
220 KV GSS Bamantukda	Rajsamand	220/132	160	92.89
		132/33	20/25	17.64
132 KV GSS Amet	Rajsamand	132/33	20/25	22.27
		132/33	20/25	19.48
132 KV GSS Bheem	Rajsamand	132/33	20/25	9.95
132 KV GSS Devgarh	Rajsamand	132/33	20/25	18.26
		132/33	10/12.5	0.00
220 KV GSS Madri	Udaipur	220/132	160	93.80
		220/132	100	55.71
		132/33	40/50	35.24
		132/33	20/25	19.96
		132/33	20/25	15.21
132 KV GSS Dakankotda	Udaipur	132/33	20/25	17.89
		132/33	10/12.5	8.83
132 KV GSS Balicha	Udaipur	132/33	20/25	15.85
132 KV GSS Zawar Mines	Udaipur	132/33	16/20	10.74
		132/33	16/20	17.04
132 KV GSS Kherwara	Udaipur	132/33	20/25	20.90
132 KV GSS Bichhiwara	Dungarpur	132/33	20/25	12.38
132 KV GSS Rishabhdeo	Udaipur	132/33	20/25	13.42
		132/33	16/20	12.61

* NC indicate GSS commissioned in FY 2020-21

②