

**Peak Load Reports of transformers at Various 765kV/400kV/220 kV / 132 kV GSS under Zonal CE(T&C)  
Jaipur during FY 2020-21**

**Name of Zone:-ZCE(T&C) RVPN , Jaipur**

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5

**Name of Circle:-SE(T&C) RVPN, Jaipur City**

400 kV GSS Heerapura	Jaipur	400/220	315	248.00
		400/220	250	187.00
		400/220	250	191.00
		400/220	250	195.00
220 kV GSS Mansarover	Jaipur	220/132	160	101.30
		220/132	160	101.30
		132/33	40/50	47.60
		132/33	40/50	42.00
132 kV GSS SMS Stadium	Jaipur	132/33	40/50	49.20
		132/33	37.5/50	31.00
		132/33	37.5/50	33.00
132 kV GSS Chambal	Jaipur	132/33	40/50	41.15
		132/33	40/50	40.92
		132/11	2x16/20	23.48
		132/11	10/12.5+16/20	18.17
220 kV GSS Heerapura	Jaipur	220/132	160	110.88
		220/132	160	106.69
		220/132	160	102.88
		220/132	100	81.92
132 kV GSS Vaishali Nagar	Jaipur	132/33	40/50	38.00
		132/33	40/50	39.00
132 kV GSS Bhankrota	Jaipur	132/33	20/25	20.06
		132/33	20/25	19.83
220 kV GSS IG Nagar	Jaipur	220/132	100	97.83
		220/132	100	97.07
		132/33	40/50	42.32
		132/33	40/50	41.01
132 kV GSS Puranaghat	Jaipur	132/33	40/50	31.65
		132/33	40/50	28.77
132 kV GIS MNIT	Jaipur	132/33	37.5/50	44.68
		132/33	37.5/50	37.44
132 kV GSS Jawahar Nagar	Jaipur	132/33	40/50	40.96
		132/33	40/50	32.72
		132/33	40/50	34.10
		132/33	20/25	4.35
220 kV GSS Sitapura	Jaipur	220/132	160	85.73
		132/33	40/50	28.86
132 kV GSS Sitapura	Jaipur	132/33	40/50	35.89
		132/33	40/50	36.89
		132/33	20/25	23.02
220 kV GSS NPH	Jaipur	220/132	160	95.53
		220/132	160	93.24
		132/33	40/50	35.80
		132/33	40/50	44.14
		132/33	40/50	31.74
		132/11	10/12.5	9.81
132 kV GSS PWD Bunglow	Jaipur	132/11	10/12.5	10.15
		132/33	37.5/50	29.49
220 kV GSS VKIA	Jaipur	132/33	37.5/50	34.89
		220/132	160	108.16
		220/132	100	92.23
		132/33	40/50	41.50
		132/33	40/50	41.18
132 kV GSS Champapura	Jaipur	132/33	40/50	45.71
		132/33	20/25	16.30
		132/33	20/25	14.25
132 kV GSS Sarna Dungar	Jaipur	132/33	20/25	22.29
		132/33	20/25	22.01
132 kV GSS New Jhotwara	Jaipur	132/33	40/50	34.45
		132/33	40/50	13.33
132 kV GSS VKIA	Jaipur	132/33	40/50	37.08
		132/33	40/50	38.04
		132/33	20/25	19.86
		132/33	20/25	18.30
		132/11	10/12.5	7.90
		132/11	10/12.5	6.43

②

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5

**Name of Circle:-SE(T&C) RVPN, Jaipur Rural**

220 kV GSS Chaksu	Jaipur	220/132	160	115.00
		132/33	2x20/25	46.00
132 kV GSS Toonga	Jaipur	132/33	20/25	24.92
		132/33	20/25	23.11
132 kV GSS Bassi	Jaipur	132/33	40/50	37.14
		132/33	20/25	22.86
220 kV GSS Chomu	Jaipur	220/132	160	82.24
		220/132	160	82.24
		132/33	40/50	26.54
		132/33	20/25	19.24
		132/11	10/12.5	7.13
132 kV GSS Jatawali	Jaipur	132/33	20/25	7.13
		132/33	20/25	21.95
132 kV GSS Rampura	Jaipur	132/33	20/25	23.32
		132/33	40/50	23.32
220 kV GSS Goner	Jaipur	220/132	100	95.00
		132/33	40/50	16.00
220 kV GSS Kunda Ki Dhani	Jaipur	220/132	160	108.89
		132/33	20/25	19.43
		132/33	20/25	19.66
		132/33	10/12.5	9.37
		132/11	6	4.97
220 kV GSS Manoharpur	Jaipur	220/132	100	93.11
		220/132	100	88.46
		132/33	40/50	42.62
		132/33	40/50	42.58
132 kV GSS Bilwadi	Jaipur	132/33	20/25	23.04
		132/33	20/25	21.63
132 kV GSS Shahpura	Jaipur	132/33	40/50	23.51
		132/33	20/25	13.59
		132/11	10/12.5	5.49
220 kV GSS Niwana	Jaipur	220/132	160	134.85
		220/132	160	130.70
		132/33	20/25	20.12
132 kV GSS Markhi	Jaipur	132/33	40/50	19.13
		132/33	20/25	17.78
132 kV GSS Govindgarh	Jaipur	132/33	40/50	27.67
		132/33	20/25	18.29
		132/33	20/25	18.29
220 kV GSS Phulera	Jaipur	220/132	100	80.87
		220/132	100	80.87
		132/33	20/25	12.75
		132/33	20/25	12.75
132 kV GSS Jobner	Jaipur	132/33	20/25	15.52
		132/33	10/12.5	10.93
220 kV GSS Bagru	Jaipur	220/132	100	44.96
		220/132	100	52.58
		132/33	40/50	32.94
		132/33	40/50	41.69
132 kV GSS Bagru	Jaipur	132/33	20/25	19.65
		132/33	20/25	22.83
		132/33	20/25	9.54
		132/11	16/20	4.55
132 kV GSS Dudu	Jaipur	132/33	20/25	17.00
		132/33	10/12.5	11.00
220 kV GSS Sanganer	Jaipur	220/132	100	83.83
		220/132	100	62.67
		132/33	40/50	43.31
		132/33	40/50	35.17
132 kV GSS Balawala	Jaipur	132/33	40/50	47.32
		132/33	20/25	4.15
		132/33	20/25	4.12
220 kV GSS SEZ-I	Jaipur	220/132	100	21.46
		132/33	20/25	13.16
		132/33	20/25	12.14
132 kV GSS Sirsi	Jaipur	132/33	40/50	35.44
		132/33	40/50	37.03
		33/11	5	0.80
		33/11	3.15	0.80

*B*

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5
220 kV GSS Vatika	Jaipur	220/132	160	110.38
		132/33	40/50	13.26
132 kV GSS Phagi	Jaipur	132/33	20/25	17.70
220 kV GSS Kukas	Jaipur	220/132	100	72.92
		220/132	100	59.08
		132/33	20/25	12.35
		132/33	10/12.5	12.35
		33/11	8	5.03
132 kV GSS Jamwaramgarh	Jaipur	132/33	20/25	18.91
		132/33	10/12.5	9.53
		33/11	5	2.63
132 kV GSS Andhi	Jaipur	132/33	20/25	13.10
		132/33	10/12.5	9.08
220 kV GSS Kotputli	Jaipur	220/132	100	90.67
		220/132	100	86.75
		220/132	100	90.67
		132/33	40/50	49.74
		132/33	40/50	46.00
		132/33	40/50	46.14
132 kV GSS Keshwana	Jaipur	132/33	20/25	23.09
		132/33	20/25	19.89
132 kV GSS Paota	Jaipur	132/33	20/25	22.86
		132/33	20/25	22.29
220 kV GSS Renwal	Jaipur	220/132	100	53.73
		220/132	100	75.75
		132/33	20/25	17.38
		132/33	20/25	18.20
		132/33	10/12.5	9.60
132 kV GSS Hingonia	Jaipur	132/33	20/25	16.00
		132/33	20/25	16.00
		132/33	20/25	16.00
132 kV GSS Kaladera	Jaipur	132/33	40/50	25.87
		132/33	40/50	29.06

**Name of Circle:-SE(T&C) RVPN , Sawaimadhopur**

220 kV GSS Sawaimadhopur	Sawaimadhopur	220/132	160	147.94
		220/132	100	78.24
		132/33	40/50	40.85
		132/33	20/25	24.96
132kV GSS Nainwa	Bundi	132/11	10/12.5	4.12
		132/33	20/25	23.28
		132/33	20/25	23.06
		132/33	10/12.5	11.43
132 kV GSS Bhadoti	Sawaimadhopur	132/33	20/25	22.75
		132/33	10/12.5	11.37
132 kV GSS Lakheri	Bundi	132/33	20/25	22.01
		132/33	10/12.5	10.89
		132/11	6	4.15
		132/33	20/25	22.11
132 kV GSS Khandar	Sawaimadhopur	132/33	10/12.5	11.28
		132/33	10/12.5	11.28
		132/33	40/50	29.48
132 kV GSS Newai	Tonk	132/33	20/25	19.73
		132/33	20/25	15.20
132 kV GSS Uniara	Tonk	132/33	20/25	15.55
		220/132	100	94.80
220 kV GSS Gangapur City	Sawaimadhopur	220/132	100	83.43
		132/33	20/25	16.00
		132/33	20/25	22.44
132 kV GSS Gangapur city	Sawaimadhopur	132/33	20/25	22.44
		132/33	20/25	2.16
		132/11	10/12.5	2.16
132 kV GSS Baroli	Sawaimadhopur	132/33	20/25	14.06
		132/33	10/12.5	9.11
132 kV GSS Batoda	Sawaimadhopur	132/33	20/25	19.06
220 kV GSS Dooni	Tonk	220/132	100	72.36
		220/132	100	91.36
		132/33	20/25	18.06
		132/33	10/12.5	8.06
132 kV GSS Thadoli	Tonk	132/33	20/25	16.40
		132/33	20/25	16.29
132 kV GSS Tadaraisingh	Tonk	132/33	20/25	19.60
		132/33	10/12.5	11.80

*M*

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5
132 kV GSS Malpura	Tonk	132/33	20/25	17.11
		132/33	10/12.5	9.47
132 kV GSS Tonk	Tonk	132/33	40/50	32.92
		132/33	20/25	21.94
132 kV GSS Hindoli	Bundi	132/11	10/12.5	7.31
		132/33	20/25	22.51
132 kV GSS Keshoraipatan	Bundi	132/33	20/25	19.81
		132/33	20/25	24.50
132 kV GSS Bundi	Sawaimadhopur	132/33	20/25	10.91
		132/33	20/25	24.00
		132/33	20/25	24.00
		132/33	20/25	23.00
220 kV GSS Bundil	Bundi	132/11	16/20	6.00
		220/132	100	91.20
132 kV GSS Talera	Bundi	220/132	100	98.70
		132/33	20/25	21.50
132 kV GSS Deoli(Tonk)	Tonk	132/33	20/25	23.91
		132/33	20/25	23.46
132 kV GSS Chauth Ka Barwara	Sawaimadhopur	132/33	20/25	20.56
		132/33	10/12.5	11.97
132 kV GSS Dablana	Bundi	132/33	20/25	23.54
		132/33	20/25	24.69
132 kV GSS Dabi	Bundi	132/33	20/25	14.18
		132/33	20/25	9.00
132 kV GSS Bamanwas	Sawaimadhopur	132/33	20/25	11.20
132 kV GSS Baler (NC)	Sawaimadhopur	132/33	20/25	17.00

**Name of Circle:-SE(T&C) RVPN , Bharatpur**

220 kV GSS Lalasot	Dausa	220/132	100	88.48
		220/132	100	85.46
		132/33	40/50	40.63
		132/33	20/25	23.88
		33/11	5	3.15
132 kV GSS Nagal Pyariwas	Dausa	132/33	20/25	16.48
		132/33	20/25	16.46
132 kV GSS Bagdi	Dausa	132/33	20/25	17.87
220 kV GSS Mandawar	Dausa	220/132	100	72.90
		220/132	100	72.90
		132/33	20/25	25.00
		132/33	20/25	25.00
132 kV GSS Mahuwa	Dausa	132/33	20/25	20.11
		132/33	20/25	12.80
132 kV GSS Dhaura Kunwa	Dausa	132/33	20/25	21.00
		132/33	14/20	14.00
132 kV GSS D.Bheem	Dausa	132/33	40/50	30.38
220 kV GSS Sikrai	Dausa	220/132	100	80.43
		220/132	100	73.95
		132/33	20/25	24.22
		132/33	20/25	19.55
132 kV GSS Sikandra	Dausa	132/33	20/25	23.08
		132/33	20/25	23.08
		132/33	10/12.5	10.29
132 kV GSS Bandikui	Dausa	132/33	20/25	20.19
		132/33	20/25	20.88
220 kV GSS Dausa	Dausa	220/132	160	89.00
		220/132	100	71.00
		132/33	40/50	33.00
		132/33	20/25	18.00
		132/11	10/12.5	10.48
220 kV GSS Nadbai	Bharatpur	220/132	160	130.00
		220/132	100	85.00
		132/33	40/50	36.00
		132/33	20/25	23.00
132 kV GSS Nagar	Bharatpur	132/33	20/25	22.00
		132/33	40/50	40.00
132 kV GSS Roopwas	Bharatpur	132/33	20/25	16.00
		132/33	20/25	24.00
132 kV GSS Pahari	Bharatpur	132/33	20/25	16.00
		132/33	20/25	24.00
132 kV GSS Pahari	Bharatpur	132/33	20/25	23.00
		132/33	20/25	21.00

12

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5
220 kV GSS Bharatpur	Bharatpur	220/132	100	88.49
		220/132	100	100.74
		220/132	100	100.74
		132/33	20/25	23.68
132 kV GSS Bharatpur	Bharatpur	132/33	20/25	23.68
		132/33	20/25	24.95
		132/33	20/25	25.95
132 kV GSS Kumher	Bharatpur	132/11	10	4.46
		132/33	20/25	18.00
132 kV GSS Deeg	Bharatpur	132/33	10/12.5	10.00
		132/33	20/25	22.29
132 kV GSS Kaman	Bharatpur	132/33	10/12.5	11.25
		132/33	20/25	21.57
		132/33	10/12.5	10.78
220 kV GSS Chhonkarwada	Bharatpur	132/33	10/12.5	10.78
		220/132	160	93.62
132 kV GSS Weir	Bharatpur	132/33	40/50	36.87
		132/33	20/25	16.00
		132/33	20/25	16.00
132 kV GSS Bayana	Bharatpur	132/33	10/12.5	8.15
		132/33	40/50	49.00
132 kV GSS Bhusawar	Bharatpur	132/33	40/50	36.00
		132/33	20/25	20.00
		132/33	20/25	19.51
		132/33	10/12.5	10.00

Name of Circle:-SE(T&C) RVPN , Kota

220 kV GSS Bhawanimandi	Jhalawar	220/132	160	95.00
		220/132	160	99.00
		132/33	20/25	23.00
132 kV GSS Dug	Jhalawar	132/33	20/25	17.00
		132/33	20/25	17.00
132 kV GSS Bhawanimandi	Jhalawar	132/33	10/12.5	8.00
		132/33	20/25	19.00
		132/33	20/25	17.00
132 kV GSS Hemda	Jhalawar	132/33	20/25	26.06
		132/33	10/12.5	13.03
		132/33	10/12.5	13.03
220 kV GSS Modak	Kota	220/132	100	84.95
		220/132	100	76.64
		132/33	20/25	20.04
		132/33	20/25	20.04
		33/11	3.15	0.00
132 kV GSS Mandana	Kota	132/33	20/25	16.84
		132/33	10/12.5	7.26
132 kV GSS Mayla Ramganjmandi	Kota	132/33	20/25	20.11
		132/33	20/25	20.11
220 kV GSS Jhalawar	Jhalawar	220/132	160	128.00
		220/132	100	96.77
		132/33	20/25	23.36
132 kV GSS Manoharthana	Jhalawar	132/33	20/25	23.36
		132/33	10/12.5	23.90
132 kV GSS Bakani	Jhalawar	132/33	10/12.5	10.45
		132/33	20/25	16.99
		132/33	10/12.5	8.61
132 kV GSS Kanwari	Jhalawar	132/33	10/12.5	8.61
		132/33	20/25	20.42
132 kV GSS Aklera	Jhalawar	132/33	10/12.5	10.21
		132/33	20/25	16.46
132 kV GSS Rooparail	Jhalawar	132/33	20/25	16.46
		132/33	40/50	20.16
220 kV GSS Baran	Baran	220/132	160	117.00
		220/132	100	91.00
		132/33	20/25	16.00
132 kV GSS Baran	Baran	132/33	40/50	27.00
		132/33	40/50	27.00
132 kV GSS Kishanganj	Baran	132/33	20/25	23.00
		132/33	20/25	20.00
132 kV GSS Kelwara	Baran	132/33	20/25	24.00
		132/33	20/25	25.00
132 kV GSS Mamoni	Baran	132/33	20/25	24.00
		132/33	20/25	23.00

B

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5
132 kV GSS Sangod	Kota	132/33	20/25	21.00
		132/33	20/25	21.00
132 kV GSS Bapawar	Kota	132/33	20/25	23.00
		132/33	10/12.5	11.00
132 kV GSS Mangrol	Baran	132/33	20/25	19.00
220 kV GSS Sakatpura, Kota	Kota	220/132	160	135.73
		220/132	100	83.03
		220/132	100	80.71
		220/132	100	84.58
		132/33	40/50	37.98
132 kV GSS I/A Kota	Kota	132/33	20/25	23.64
		132/33	40/50	37.98
		132/33	40/50	36.03
		132/33	20/25	19.14
132 kV GSS Deoli Manjhi	Kota	132/33	20/25	23.20
		132/11	16/20	8.94
132 kV GSS Dadabari	Kota	132/33	40/50	31.92
		132/33	20/25	21.34
132 kV GSS Mahaveer Nagar	Kota	132/33	40/50	28.00
		132/33	20/25	19.00
132 kV GSS Gopal Mill, Kota	Kota	132/33	40/50	39.03
		132/33	40/50	46.18
132 kV GSS Nanta	Kota	132/33	40/50	34.00
		132/33	20/25	21.00
220 kV GSS Kawai	Baran	132/33	20/25	13.67
		220/132	100	108.99
		220/132	100	108.99
		132/33	20/25	24.42
		132/33	20/25	24.42
132 kV GSS Atru	Baran	33/11	5	5.00
		132/33	40/50	38.00
132 kV GSS Kolukheri	Baran	132/33	20/25	21.00
		132/33	20/25	16.66
132 kV GSS Chipabarod	Baran	132/33	20/25	17.33
		132/33	20/25	17.84
		132/33	10/12.5	17.84
132 kV GSS Khanpur	Jhalawar	132/33	40/50	8.92
		132/33	20/25	39.59
220 kV GSS Dahra	Kota	132/33	20/25	23.03
		220/132	100	87.00
		220/132	100	65.00
		132/33	20/25	23.00
		132/33	20/25	19.00
132 kV GSS Sultanpur	Kota	132/33	10/12.5	11.00
132 kV GSS Itawa	Kota	132/33	20/25	24.64
		132/33	10/12.5	10.00
132 kV GSS Anta	Kota	132/33	20/25	22.00
		132/33	10/12.5	10.00
132 kV GSS Dhanodi	Jhalawar	132/33	40/50	24.61
132 kV GSS Gangdhar	Jhalawar	132/33	10/12.5	12.22
132 kV GSS Sarola Kalan	Kota	132/33	20/25	13.72
132 kV GSS Nahargarh(NC)	Baran	132/33	20/25	19.00
220 kV GSS Aklera (NC)	Jhalawar	220/132	20/25	21.90
			20/25	0.00
			160	47.25

**Name of Circle:-SE(T&C) RVPN, Alwar**

220 kV GSS Khushkhera	Alwar	220/132	160	151.00
		220/132	100	86.00
		132/33	40/50	34.00
		132/33	40/50	34.00
		132/33	20/25	17.00
132 kV GSS, Chopanki I/A, Alwar	Alwar	132/33	40/50	38.28
		132/33	40/50	38.96
132 kV GSSL Pinan	Alwar	132/33	20/25	22.61
		132/33	20/25	22.86
132 kV GSS Rajgarh	Alwar	132/33	40/50	31.19
		132/33	20/25	16.74
		33/11	5	5.00
132 kV GSS Thanagaji	Alwar	132/33	20/25	19.43
		132/33	20/25	19.43
		132/33	10/12.5	9.72

6

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5
132 kV GSS Bhiwadi	Alwar	132/33	40/50	31.81
		132/33	40/50	42.50
		132/33	20/25	20.90
		132/11	16/20	15.45
		132/11	16/20	13.40
		132/11	10	8.47
132 kV GSS Jakhrana	Alwar	132/33	20/25	12.80
		132/33	20/25	12.80
132 kV GSS Mandan	Alwar	132/33	20/25	16.00
		132/33	20/25	16.00
132 kV GSS Pur-Kotkasim	Alwar	132/33	20/25	21.76
		132/33	20/25	21.76
132 kV GSS Govindgarh(Alwar)	Alwar	132/33	20/25	21.47
		132/33	20/25	21.16
132 kV GSS Kherli (Alwar)	Alwar	132/33	40/50	36.02
		132/33	20/25	25.54
132 kV GSS Malakhera	Alwar	132/33	40/50	42.75
		132/33	20/25	23.55
220 kV GSS MIA Alwar	Alwar	220/132	100	94.80
		220/132	100	93.38
		132/33	40/50	38.70
		132/33	40/50	31.84
		132/33	20/25	24.90
		132/33	20/25	24.90
220 kV GSS Behror	Alwar	220/132	160	108.51
		132/33	20/25	12.76
220 kV GSS Bhiwadi	Alwar	220/132	160	118.58
		220/132	160	122.02
		220/132	100	76.19
		132/33	40/50	37.07
		132/33	40/50	37.07
		132/33	40/50	37.07
		132/11	16/20	10.87
220 kV GSS Neemrana	Alwar	132/11	10/12.5	5.72
		220/132	100	64.89
		220/132	100	64.89
		220/132	100	64.89
		132/33	40/50	27.56
		132/33	40/50	27.56
132 kV GSS Shahjahanpur	Alwar	132/33	20/25	16.67
		132/33	20/25	24.70
		132/33	20/25	23.08
		132/33	10/12.5	11.54
132 kV GSS Behror	Alwar	132/33	20/25	24.31
		132/33	20/25	24.31
		132/33	20/25	24.31
		132/11	10/12.5	9.66
132 kV GSS Laxmangarh	Alwar	132/33	40/50	40.00
		132/33	20/25	24.00
		132/33	20/25	24.00
220 kV GSS Bansur	Alwar	220/132	160	138.70
		132/33	40/50	44.57
		132/33	20/25	0.00
132 kV GSS Narainpur	Alwar	132/33	20/25	22.34
		132/33	20/25	22.72
132 kV GSS Bansur	Alwar	132/33	40/50	31.13
		132/33	20/25	19.38
		132/33	20/25	20.24
132 kV GSS Mundawar	Alwar	132/33	40/50	35.79
		132/33	20/25	22.74
		132/33	20/25	23.56
132 kV GSS Ramgarh	Alwar	132/33	40/50	40.00
		132/33	20/25	24.00
220 kV GSS Kishangarh-Bas	Alwar	220/132	160	88.76
		220/132	160	134.85
		132/33	40/50	38.47
		132/33	20/25	23.96
132 kV GSS Tizara	Alwar	132/33	20/25	23.96
		132/33	40/50	33.51
		132/33	20/25	18.54
		132/33	10/12.5	9.38

Name of GSS	Distt.	Transformer		Max. (MVA) FY 2020-21
		Voltage Ratio (kV)	Capacity (MVA)	
1	2	3	4	5
220 kV GSS Alwar	Alwar	220/132	160	134.00
		220/132	160	134.00
		220/132	100	83.00
		132/33	40/50	41.00
		132/33	40/50	41.00
		132/33	40/50	41.00
132 kV GSS BMRT Bhiwadi	Alwar	132/33	20/25	22.00
132 kV GSS Khairthal	Alwar	132/33	20/25	0.00
132 kV GSS Telco Circle	Alwar	132/33	20/25	21.15
132 kV GSS Bahadurpur (NC)	Alwar	132/33	20/25	0.00
132 kV GSS Karoli(NC)	Alwar	132/33	20/25	0.00

**Name of Circle:-SE(T&C) RVPN, Hindaun**

400 kV GSS Hindaun	Karauli	400/220	315	295.00
		400/220	315	268.00
220 kV GSS Hindaun	Karauli	220/132	160	120.74
		220/132	100	98.88
		220/132	100	98.88
		132/33	20/25	20.50
		132/33	20/25	20.40
		132/33	20/25	20.59
132 kV GSS Kailadevi	Karauli	132/33	20/25	18.27
		132/33	10/12.5	8.73
132 kV GSS Todabheem	Karauli	132/33	20/25	21.55
		132/33	20/25	21.55
132 kV GSS Nangal Sherpur	Karauli	132/33	20/25	22.30
		132/33	20/25	18.13
132 kV GSS Gudachander Ji	Karauli	132/33	20/25	24.13
132 kV GSS Sapotra	Karauli	132/33	20/25	22.97
		132/33	10/12.5	11.03
132kV GSS Karauli	Karauli	132/33	40/50	36.84
		132/33	20/25	21.71
		132/33	20/25	21.26
132 kV GSS SMVJ	Karauli	132/33	20/25	21.26
		132/33	20/25	21.26
220 kV GSS Dholpur	Dholpur	220/132	100	83.65
		220/132	100	80.15
		132/33	40/50	28.86
		132/33	20/25	18.63
		132/33	20/25	18.69
		132/11	6.3/8	4.56
132 kV GSS Rajakhera	Dholpur	132/33	10/12.5	4.96
		132/33	20/25	19.84
132 kV GSS Baseri	Dholpur	132/33	20/25	19.84
		132/33	20/25	23.89
132 kV GSS Sarmathura	Dholpur	132/33	10/12.5	11.95
132 kV GSS Sarmathura	Dholpur	132/33	20/25	14.40
132 kV GSS Maniya	Dholpur	132/33	20/25	22.84
132 kV GSS Marena	Dholpur	132/33	20/25	19.84
132 kV GSS RIICO Dholpur	Dholpur	132/33	20/25	19.36
132 kV GSS Mandrayl	Karauli	132/33	20/25	20.77
132 kV GSS Bari	Dholpur	132/33	20/25	21.95

**Name of Circle:-SE(765 kV GSS) RVPN, Anta**

765 kV GSS Anta	Baran	765/400	1500	1005.00
		765/400	1500	1059.00
		765/400	1500	1052.00

**Name of Circle:-SE(765 kV GSS) RVPN, Phagi**

765 kV GSS Phagi	Jaipur	765/400	1500	1309.00
		765/400	1500	1287.00

\* NC indicate GSS commissioned in FY 2020-21

*(Handwritten mark)*