

**Peak Load Reports of transformers at Various 400kV/220 KV /132 KV GSS under Zonal CE(T&C)
Jodhpur during FY 2020-21**

Name of Zone:-ZCE (T&C) RVPNL, Jodhpur

Name of GSS	Distt.	Transformer		
		Voltage Ratio (kV)	Capacity (MVA)	Max. (MVA) FY 2020-21
1	2	3	4	5
Name of Circle:-SE (T&C) RVPNL, Jodhpur				
400 kV GSS Jodhpur	Jodhpur	400/220	315	304.00
		400/220	315	290.00
220 kV GSS Aau	Jodhpur	220/132	100	93.21
		220/132	160	137.49
		220/132	160	60.11
		132/33	40/50	33.86
132 kV GSS Aau	Jodhpur	132/33	20/25	22.86
		132/33	20/25	23.14
132 kV GSS Lohawat	Jodhpur	132/33	20/25	23.14
		132/33	40/50	46.21
132 kV GSS Matora	Jodhpur	132/33	40/50	46.21
		132/33	40/50	47.21
132 kV GSS Balesar	Jodhpur	132/33	40/50	47.21
		132/33	20/25	21.00
132 kV GSS Setrawa	Jodhpur	132/33	20/25	21.23
		132/33	20/25	22.17
132 kV GSS Kalau	Jodhpur	132/33	20/25	20.17
		132/33	40/50	33.32
220 kV GSS Basni, Jodhpur	Jodhpur	220/132	160	20.04
		220/132	160	134.00
		220/132	100	73.00
		220/132	100	65.00
		132/33	40/50	39.00
		132/33	20/25	22.00
132 kV GSS Kuri Bhagtasani	Jodhpur	132/33	20/25	20.00
		132/33	37.5/50	30.86
132 kV GSS NPH JU	Jodhpur	132/33	37.5/50	26.02
		132/33	20/25	18.43
		132/33	20/25	19.60
		132/33	20/25	19.58
		132/33	20/25	19.35
		132/11	12.5/20	3.22
132 kV GSS Pratap Nagar	Jodhpur	132/11	10/12.5	0.69
		132/33	37.5/50	38.40
132 kV GSS Soorsagar	Jodhpur	132/33	37.5/50	37.10
		132/33	20/25	19.73
132 kV GSS Chamu	Jodhpur	132/33	20/25	19.66
		132/33	40/50	47.51
132 kV GSS Dechu	Jodhpur	132/33	40/50	47.51
		132/33	20/25	20.50
132 kV GSS Sanwreej	Jodhpur	132/33	20/25	21.01
		132/33	20/25	21.01
132 kV GSS MBM	Jodhpur	132/33	40/50	35.70
		132/33	20/25	20.50
220 kV GSS Dechu	Jodhpur	132/33	37.5/50	16.13
		132/33	37.5/50	19.58
132 kV GSS Mandor	Jodhpur	220/132	100	91.43
		220/132	100	99.00
133 kV GSS CHB	Jodhpur	132/33	20/25	20.60
		132/33	10/12.5	10.30
132 kV GSS Banar	Jodhpur	132/33	40/50	36.00
		132/33	20/25	21.09
132 kV GSS Bhikamkor	Jodhpur	132/33	40/50	36.33
		132/33	40/50	35.89
132 kV GSS Bapini	Jodhpur	132/33	20/25	15.67
		132/33	20/25	21.73
132 kV GSS OPH Jodhpur	Jodhpur	132/33	20/25	21.26
		132/33	37.5/50	20.82
220 kV GSS Baithwasia	Jodhpur	132/33	37.5/50	23.23
		220/132	160	123.96
		220/132	160	120.27
		132/33	20/25	19.79
132 kV GSS Kirmarsariya	Jodhpur	132/33	20/25	19.79
		132/33	20/25	19.79
132 kV GSS Osian	Jodhpur	132/33	20/25	22.58
		132/33	20/25	20.59
132 kV GSS S S Nagar	Jodhpur	132/33	40/50	40.05
		132/33	20/25	20.82
132 kV GSS PS-8	Jodhpur	132/33	20/25	19.91
		132/33	20/25	20.35
220 kV GSS Boranada	Jodhpur	132/33	10/12.5	2.97
		132/33	10/12.5	0.00
		220/132	100	66.00
		220/132	100	44.00
220 kV GSS Tinwari	Jodhpur	132/33	40/50	38.00
		132/33	20/25	15.00
		220/132	160	131.93
		220/132	160	110.35
220 kV GSS Barli	Jodhpur	132/33	40/50	38.95
		132/33	20/25	22.09
		220/132	160	22.04
		132/33	40/50	119.00
		132/33	40/50	27.00

2

Name of GSS	Distt.	Transformer		
		Voltage Ratio (kV)	Capacity (MVA)	Max. (MVA) FY 2020-21
1	2	3	4	5
Name of Circle:-SE (T&C) RVPN, Kankani				
400 kV GSS Kankani	Jodhpur	400/220	500	469.93
220 kV GSS Pali	Pali	220/132	100	67.10
		220/132	100	79.64
		132/33	10/12.5	4.45
132 kV GSS Sojat City	Pali	132/33	20/25	22.08
		132/33	10/12.5	11.69
		132/33	10/12.5	11.69
132 kV GSS Tagore Nagar Pali	Pali	132/33	20/25	16.00
		132/33	20/25	16.00
132 kV GSS Pali	Pali	132/33	40/50	37.71
		132/33	20/25	22.94
132 kV GSS Kharchi	Pali	132/33	10/12.5	10.00
		132/33	10/12.5	10.00
132 kV GSS Jojwar	Pali	132/33	20/25	17.00
		132/33	10/12.5	9.00
220 kV GSS Bilara	Jodhpur	220/132	100	78.11
		220/132	100	81.18
		132/33	20/25	21.23
		132/33	20/25	20.78
132 kV GSS Borunda	Jodhpur	132/33	20/25	20.00
		132/33	10/12.5	10.00
132 kV GSS Piparcity	Jodhpur	132/33	20/25	19.00
		132/33	10/12.5	12.00
132 kV GSS Jaitaran	Jodhpur	132/33	20/25	14.92
		132/33	10/12.5	7.67
132 kV GSS Pipaliya	Jodhpur	132/33	20/25	14.75
		132/33	10/12.5	10.72
132 kV GSS Anandpur Kalu	Jodhpur	132/33	20/25	20.72
132 kV GSS Mathania	Jodhpur	132/33	20/25	21.41
		132/33	20/25	22.45
220 kV GSS Bhawad	Jodhpur	220/132	160	65.70
		220/132	100	53.96
		132/33	20/25	5.22
132 kV GSS Baori	Jodhpur	132/33	20/25	18.84
		132/33	20/25	19.97
		132/33	20/25	19.97
132 kV GSS Soyla	Jodhpur	132/33	40/50	34.30
		132/33	20/25	18.92
220 kV GSS Bali	Pali	220/132	100	76.23
		220/132	100	59.98
		132/33	20/25	16.73
132 kV GSS Sumerpur	Pali	132/33	10/12.5	8.27
		132/33	20/25	17.70
132 kV GSS Falna	Pali	132/33	20/25	16.79
		132/33	10/12.5	9.83
132 kV GSS Rani	Pali	132/33	7.5/10	9.89
		132/33	20/25	17.00
220 kV GSS Bhopalgarh	Jodhpur	132/33	16/20	9.00
		220/132	100	55.55
220 kV GSS Jhalamand	Jodhpur	220/132	50	34.72
		132/33	20/25	22.07
		132/33	20/25	21.59
		220/132	160	92.45
132 kV GSS Bhopalgarh	Jodhpur	132/33	40/50	9.00
		132/33	20/25	23.77
132 kV GSS Hatundi	Jodhpur	132/33	14/20	18.74
		132/33	20/25	20.11
132 kV GSS Nathrau	Jodhpur	132/33	20/25	20.34
		132/33	20/25	21.84
132 kV GSS Bera	Jodhpur	132/33	20/25	11.84
132 kV GSS Bana Ka Bas	Jodhpur	132/33	20/25	23.48
132 kV GSS Desuri	Jodhpur	132/33	20/25	19.00
Name of Circle:-SE (T&C) RVPN, Jaisalmer				
400 kV GSS Akal	Jaisalmer	400/220	500	471.00
		400/220	500	495.00
		400/220	315	315.00
400 kV GSS Jaisalmer -2	Jaisalmer	400/220	500	249.00
132 kV GSS Pokaran	Jaisalmer	132/33	20/25	16.34
		132/33	20/25	17.78
132 kV GSS Aiasar	Jaisalmer	132/33	20/25	20.49
132 kV GSS Sangarh	Jaisalmer	132/33	20/25	24.77
		132/33	20/25	24.77
132 kV GSS Chandan	Jaisalmer	132/33	40/50	45.40
		132/33	20/25	24.76
		132/33	20/25	24.76

12

Name of GSS	Distt.	Transformer		
		Voltage Ratio (kV)	Capacity (MVA)	Max. (MVA) FY 2020-21
1	2	3	4	5
132 kV GSS Jaisalmer	Jaisalmer	132/33	40/50	45.64
		132/33	40/50	43.23
		220/132	160	122.14
		220/132	100	76.33
		220/132	100	76.33
220 kV GSS Amarsagar	Jaisalmer	132/33	40/50	20.83
		132/33	20/25	13.08
		132/33	20/25	13.08
		132/33	20/25	13.08
		132/33	20/25	13.08
132 KV GSS MES	Jaisalmer	132/33	20/25	3.25
		132/33	20/25	4.11
132 KV GSS Jhinhivali (NC)	Jaisalmer	132/33	20/25	27.20
Name of Circle:- SE (T&C) RVPN, Hanumangarh				
220 kV GSS Udyogvihar	Sri Ganganagar	220/132	160	100.00
		220/132	100	97.00
		132/33	40/50	35.00
		132/33	20/25	23.00
132 kV GSS Sri Ganganagar	Sri Ganganagar	132/33	40/50	40.75
		132/33	40/50	43.74
		132/33	20/25	20.93
132 kV GSS Sadulsahar	Sri Ganganagar	132/33	20/25	18.69
		132/33	16/20	18.18
		220/132	160	113.00
220 kV GSS Padampur	Sri Ganganagar	220/132	100	96.00
		132/33	20/25	24.00
		132/33	20/25	23.00
132 kV GSS Raisingh Nagar	Sri Ganganagar	132/33	20/25	19.55
		132/33	10/12.5	12.46
132 kV GSS Kaminpura	Sri Ganganagar	132/33	20/25	16.21
		132/33	10/12.5	9.75
132kV GSS Sri Karanpur	Sri Ganganagar	132/33	20/25	20.00
		132/33	10/12.5	7.80
220 kV GSS Bhadra	Hanumangarh	220/132	100	72.04
		220/132	100	87.00
		132/33	20/25	15.00
132 kV GSS Bhadra	Hanumangarh	132/33	20/25	21.96
		132/33	20/25	19.90
132 kV GSS Nohar	Hanumangarh	132/33	20/25	23.36
		132/33	20/25	23.14
132 kV GSS Jokhasar	Hanumangarh	132/33	10/12.5	11.38
		132/33	10/12.5	12.67
132 kV GSS Rajiasar	Sri Ganganagar	132/33	20/25	22.84
		132/33	10/12.5	13.39
132 kV GSS Anoopgarh	Sri Ganganagar	132/33	20/25	22.33
		132/33	10/12.5	10.58
132 kV GSS Srivijaynagar	Sri Ganganagar	132/33	20/25	21.16
		132/33	20/25	23.86
132 kV GSS Gharsana	Sri Ganganagar	132/33	20/25	23.45
		132/33	10/12.5	11.61
220 kV GSS Suratgarh	Sri Ganganagar	220/132	100	98.08
		220/132	100	85.00
		220/132	50	51.92
		132/33	40/50	35.22
		132/33	20/25	22.61
220 kV GSS Hanumangarh	Hanumangarh	220/132	160	155.20
		220/132	100	95.00
132 kV GSS Hanumangarh	Hanumangarh	132/33	40/50	41.00
		132/33	40/50	43.00
		132/33	20/25	23.10
		132/11	10/12.5	9.00
132 kV GSS Amarpurathedi	Hanumangarh	132/33	40/50	33.16
		132/33	40/50	32.95
132 kV GSS Goluwala	Hanumangarh	132/33	20/25	24.95
		132/33	10/12.5	9.50
132 kV GSS Pilibanga	Hanumangarh	132/33	40/50	41.20
		132/33	40/50	34.80
		132/11	10/12.5	5.90
132 kV GSS Rawatsar	Hanumangarh	132/33	20/25	21.66
		132/33	20/25	20.26
132 kV GSS Sangaria	Hanumangarh	132/33	40/50	38.17
		132/33	20/25	24.41
132 kV GSS Fatehgarh	Hanumangarh	132/33	20/25	22.88
132 KV GSS Pallu	Hanumangarh	132/33	20/25	21.64
132 KV GSS Tatrassar	Hanumangarh	132/33	20/25	5.04
220 KV GSS Rawatsar (NC)	Hanumangarh	220/132	160	104.00
132 KV GSS Tibbi (NC)	Hanumangarh	132/33	20/25	24.08

@

Name of GSS	Distt.	Transformer		
		Voltage Ratio (kV)	Capacity (MVA)	Max. (MVA) FY 2020-21
1	2	3	4	5
Name of Circle:- SE (T&C) RVPN, Barmer				
400 kV GSS Barmer	Barmer	400/220	315	203.33
		400/220	315	183.33
		220/132	100	99.00
		220/132	100	90.00
132 kV GSS Sheo	Barmer	132/33	10/12.5	11.54
		132/33	40/50	47.00
132 kV GSS Undoo	Barmer	132/33	20/25	23.00
		132/33	20/25	22.00
		132/33	20/25	22.00
132 kV GSS Gadra Road	Barmer	132/33	20/25	16.00
		132/33	20/25	20.72
		132/33	10/12.5	12.12
132 kV GSS Barmer	Barmer	132/33	10/12.5	12.12
		132/33	20/25	22.45
		132/33	10/12.5	11.23
220 kV GSS Dhorimanna	Barmer	220/132	10/12.5	11.23
		220/132	160	146.03
		220/132	100	98.59
		132/33	40/50	36.20
132 kV GSS Sedwa	Barmer	132/33	20/25	23.44
		132/33	20/25	19.33
132 kV GSS Sata	Barmer	132/33	20/25	19.74
		132/33	10/12.5	20.19
132 kV GSS Ranasar	Barmer	132/33	20/25	10.61
		132/33	10/12.5	19.81
132 kV GSS Mahloo	Barmer	132/33	10/12.5	9.31
		132/33	20/25	24.14
132 kV GSS Sawa	Barmer	132/33	10/12.5	11.43
		132/33	20/25	22.29
132 kV GSS Sindhari	Barmer	132/33	20/25	20.72
		132/33	20/25	22.29
220 kV GSS Balotra	Barmer	132/33	10/12.5	0.00
		220/132	100	91.70
		220/132	100	78.50
		132/33	40/50	29.90
		132/33	20/25	20.70
132 KV GSS Siwana	Barmer	132/33	20/25	20.70
		132/33	10/12.5	20.72
		132/33	10/12.5	12.15
132 kV GSS Samdari	Barmer	132/33	10/12.5	10.64
		132/33	20/25	16.47
132 kV GSS Juna Meetha Khera	Barmer	132/33	10/12.5	0.00
132 kV GSS Padroo	Barmer	132/33	20/25	24.02
		132/33	20/25	17.79
132 kV GSS Gudamalani	Barmer	132/33	20/25	17.79
		132/33	20/25	23.03
132 kV GSS Sayla	Jalore	132/33	10/12.5	10.75
		132/33	20/25	21.88
132 KV GSS Chotan	Barmer	132/33	20/25	19.45
		132/33	20/25	19.50
Name of Circle:- SE (T&C) RVPN, Bhadala				
400 kV GSS Bhadla	Jodhpur	400/220	500	448.00
		400/220	500	446.00
		400/220	500	446.00
220 kV GSS Phalodi	Jodhpur	220/132	160	110.00
		220/132	100	72.00
		220/132	100	72.00
		132/33	20/25	21.30
		132/33	20/25	21.30
220 kV GSS Badisid	Jodhpur	132/33	20/25	21.30
		220/132	160	124.04
		220/132	160	159.10
220 kV GSS Bap	Jodhpur	132/33	20/25	16.34
		132/33	20/25	16.34
		220/132	160	117.00
		132/33	40/50	48.00
		132/33	40/50	47.00
		132/33	40/50	29.00

22

Name of GSS	Distt.	Transformer		
		Voltage Ratio (kV)	Capacity (MVA)	Max. (MVA) FY 2020-21
1	2	3	4	5
220 kV GSS Bhadla	Jodhpur	220/132	160	113.06
		220/132	160	100.00
		132/33	40/50	51.00
		132/33	40/50	42.65
220 kV GSS Kanasar	Jodhpur	220/132	160	144.69
		220/132	160	101.65
		132/33	40/50	41.15
132 kV GSS PS-1 BAP	Jodhpur	132/33	20/25	11.44
132 kV GSS PS-2 BAP	Jodhpur	132/33	20/25	9.46
132 kV GSS PS-3 BAP	Jodhpur	132/33	20/25	19.52
132 kV GSS PS-4	Jodhpur	132/33	40/50	32.76
132 kV GSS PS-5	Jodhpur	132/33	40/50	25.77
		132/33	20/25	2.00
		132/33	20/25	20.00
132 kV GSS Khetusar	Jodhpur	132/33	20/25	20.39
		132/33	20/25	22.07
Name of Circle:- SE (T&C) RVPN, Bikaner				
400 kV GSS Bikaner	Bikaner	400/220	315	307.00
		400/220	315	305.00
220 kV GSS Badnu	Bikaner	220/132	160	153.40
		220/132	160	159.96
		132/33	40/50	37.22
		132/33	20/25	21.55
		132/33	20/25	21.60
132 kV GSS Mundsar	Bikaner	132/33	20/25	22.98
132 kV GSS Lalamdesar	Bikaner	132/33	20/25	21.28
		132/33	20/25	21.06
132 kV GSS Upani	Bikaner	132/33	20/25	21.23
		132/33	20/25	22.86
220 kV GSS Bikaner	Bikaner	220/132	160	128.08
		220/132	100	94.32
		220/132	100	80.00
		132/33	40/50	48.56
		132/33	40/50	47.21
		132/33	40/50	23.42
220 kV GSS Gajner	Bikaner	220/132	160	144.15
		220/132	100	85.72
		132/33	40/50	32.50
		132/33	20/25	20.50
		132/33	20/25	20.50
220 kV GSS Sri Dungargarh	Bikaner	220/132	100	97.52
		220/132	100	98.97
		132/33	40/50	48.77
		132/33	20/25	24.96
220 kV GSS Nokha	Bikaner	220/132	160	127.98
		220/132	160	133.50
		132/33	40/50	40.87
		132/33	40/50	42.19
		132/33	20/25	21.21
132 kV GSS Deshnok	Bikaner	132/33	20/25	22.09
		132/33	20/25	23.96
132 kV GSS Jasrasar	Bikaner	132/33	20/25	22.70
		132/33	20/25	21.01
132 kV GSS Panchu	Bikaner	132/33	20/25	21.01
		132/33	20/25	23.00
132 kV GSS Pugal Road	Bikaner	132/33	40/50	23.00
		132/33	40/50	32.20
132 kV GSS Kolayat	Bikaner	33/11	5	33.60
		132/33	40/50	3.17
		132/33	20/25	35.33
132 kV GSS Khaiuwala	Bikaner	132/33	20/25	22.30
		132/33	20/25	22.08
132 kV GSS Bajju	Bikaner	132/33	20/25	21.30
		132/33	20/25	23.28
132 kV GSS Napasar	Bikaner	132/33	20/25	23.28
		132/33	20/25	21.62
		132/33	20/25	22.51
132 kV GSS Bhinasar	Bikaner	132/33	20/25	21.84
		132/33	20/25	20.03
		132/33	40/50	31.60
132 kV GSS Sherera	Bikaner	132/33	20/25	24.60
		132/33	20/25	24.80
132 kV GSS Loonkaransar	Bikaner	132/33	20/25	21.19
		132/33	20/25	21.19
132 kV GSS Nokha Daiya	Bikaner	132/33	20/25	17.29
		132/33	20/25	16.85
132 kV GSS Dulcharar	Bikaner	132/33	10/12.5	8.11
		132/33	10/12.5	8.11
132kV GSS Sri Dungargarh	Bikaner	132/33	40/50	39.92
		132/33	20/25	23.28
		132/33	20/25	23.06
		132/33	20/25	23.06

Name of GSS	Distt.	Transformer		
		Voltage Ratio (kV)	Capacity (MVA)	Max. (MVA) FY 2020-21
1	2	3	4	5
132 kV GSS Riri	Bikaner	132/33	20/25	20.61
		132/33	20/25	20.61
		132/33	20/25	20.61
132 kV GSS Kitasar	Bikaner	132/33	20/25	21.73
		132/33	20/25	21.07
		132/33	20/25	21.70
132 kV GSS Momasar	Bikaner	132/33	20/25	22.86
		132/33	20/25	22.41
		132/33	20/25	17.67
132 kV GSS Bamatsar	Bikaner	132/33	20/25	12.98
132 kV GSS RD 710	Bikaner	132/33	20/25	0.00
220 kV GSS Chhatargarh (NC) upgrade	Bikaner	220/132	160	20.45
		132/33	20/25	17.21
		132/33	20/25	
Name of Circle:- SE(T&C) RVPN, Ramgarh Circle				
400 kV GSS Ramgarh	Jaisalmer	400/220	500	229.35
		400/220	500	228.90
		400/220	500	225.64
		220/132	160	118.00
		132/33	20/25	16.00
Name of Circle:- SE(T&C) RVPN, Ratangarh				
400kV GSS Ratangarh	Churu	400/220	315	241.00
		400/220	315	241.00
		400/220	315	241.00
220 kV GSS Ratangarh	Churu	220/132	160	138.50
		220/132	100	84.70
		132/33	20/25	16.60
		132/33	20/25	17.70
		132/33	20/25	21.10
132 kV GSS Chandgothi	Churu	132/33	20/25	13.82
132 kV GSS Ratangarh	Churu	132/33	20/25	20.59
132 kV GSS Taranagar	Churu	132/33	10/12.5	11.27
		132/33	20/25	21.60
		132/33	10/12.5	10.50
132 kV GSS Sardarshahar	Churu	132/33	20/25	22.34
		132/33	20/25	22.34
		132/33	20/25	22.34
132 kV GSS Churu	Churu	132/33	40/50	22.08
		132/33	20/25	21.80
		220/132	100	85.33
220 kV GSS Tehendesar	Churu	220/132	100	78.19
		132/33	40/50	38.85
		132/33	20/25	24.05
		132/33	20/25	21.71
		132/33	20/25	23.70
132 kV GSS Bidasar	Churu	132/33	20/25	23.70
		132/33	20/25	16.50
132 kV GSS Parewara	Churu	132/33	20/25	16.50
		132/33	20/25	16.50
132 kV GSS Bhasina	Churu	132/33	20/25	21.73
132 kV GSS Salasar	Churu	132/33	10/12.5	11.84
		132/33	10/12.5	11.84
132 kV GSS Sadulpur	Churu	132/33	20/25	25.19
		132/33	20/25	25.19
220 kV GSS Sujangarh	Churu	220/132	100	95.00
		220/132	100	99.00
132 kV GSS Parasneu	Churu	132/33	20/25	23.55
		132/33	20/25	14.41
132 kV GSS Patlisar fanta	Churu	132/33	40/50	37.27
		132/33	20/25	25.15
132 kV GSS Bhanipura	Churu	132/33	20/25	23.00
		132/33	20/25	23.00
132 kV GSS Sujangarh	Churu	132/33	20/25	21.95
		132/33	10/12.5	11.43
220 kV GSS Halasar	Churu	220/132	160	159.00
		132/33	20/25	19.00
Name of Circle:-SE (T&C) RVPN, Sirahi				
220 kV GSS Sanchoore	Jalore	220/132	100	92.70
		220/132	100	97.20
		132/33	20/25	8.20
132 kV GSS Sanchoore	Jalore	132/33	2x10/12.5	24.23
		132/33	16/20	17.79
132 kV GSS Paladar	Jalore	132/33	20/25	23.83
132 kV GSS Galifa	Jalore	132/33	20/25	12.47
132 kV GSS Sankad	Jalore	132/33	20/25	22.63
		132/33	20/25	22.41

Name of GSS	Distt.	Transformer		
		Voltage Ratio (kV)	Capacity (MVA)	Max. (MVA) FY 2020-21
1	2	3	4	5
220 kV GSS Sayla	Jalore	220/132	160	143.07
		132/33	20/25	20.74
		132/33	20/25	21.49
220 kV GSS Sirohi	Sirohi	220/132	100	91.00
		220/132	50	49.00
		132/33	20/25 + 10/12.5	32.00
132 kV GSS Raniwara	Jalore	132/33	20/25	18.00
		132/33	20/25 + 10/12.5	27.21
		132/33	10/12.5	11.24
132 kV GSS Reodar	Sirohi	132/33	40/50	37.14
		132/33	20/25	18.31
		220/132	100	89.85
220 kV GSS Pindwara	Sirohi	132/33	10/12.5	10.50
		132/33	10/12.5	11.34
132 kV GSS RIICO Abu Road	Sirohi	132/33	20/25	20.64
132 kV GSS Abu Road	Sirohi	132/33	20/25	21.30
132 kV GSS Swaroongani	Sirohi	132/33	20/25	21.05
220 kV GSS Jalore	Jalore	220/132	160	138.40
		220/132	100	84.00
		132/33	10/12.5	9.60
132 kV GSS Jalore	Jalore	132/33	20/25	15.65
		132/33	10/12.5	7.82
132 kV GSS Mandawala	Jalore	132/33	20/25	21.06
		132/33	20/25	16.27
133 kV GSS Ramseen	Jalore	132/33	20/25	19.16
		132/33	10/12.5	10.09
132 kV GSS Daspan	Jalore	132/33	20/25	21.82
		132/33	20/25	20.73
132 kV GSS Bagra	Jalore	132/33	20/25	21.49
		132/33	20/25	21.49
132 kV GSS Umaidpur	Jalore	132/33	10/12.5	6.31
		132/33	10/12.5	6.31
132 kV GSS Jeewana	Jalore	132/33	20/25	23.87
		132/33	20/25	23.87
132 kV GSS Posaliva	Jalore	132/33	20/25	24.50
132 kV GSS Badroona	Jalore	132/33	40/50	45.72
		132/33	10/12.5	9.68
132 kV GSS Bagora	Jalore	132/33	40/50	46.02
		132/33	20/25	22.22
132 kV GSS Badgaon	Jalore	132/33	20/25	17.68
		132/33	20/25	14.49
220 kV GSS Bhinmal	Jalore	220/132	160	117.00
		220/132	100	93.00
		132/33	40/50	39.00
		132/33	20/25	24.00
132 kV GSS Poonasa	Jalore	132/33	40/50	43.96
		132/33	20/25	24.78
132 kV GSS Bakra	Jalore	132/33	20/25	12.19
132 kV GSS Jeran (NC)	Jalore	132/33	20/25	0.00

* NC indicate GSS commissioned in FY 2020-21

7