

<b>Peak Load Reports of Transformers at various 400kV/220 kV / 132 kV PPP Mode GSS for FY 2020-21</b>				
<b>Name of GSS</b>	<b>District</b>	<b>Transformer</b>		<b>Max. (MVA) FY 2020-21</b>
		<b>Voltage Ratio (kV)</b>	<b>Capacity (MVA)</b>	
400 kV GSS Alwar	Alwar	400/220	315	239.00
		400/220	315	198.00
220 kV GSS Ranpur	Kota	220/132	160	157.91
		132/33	40/50	20.00
132 kV GSS Peeplu	Tonk	132/33	20/25	8.60
132 kV GSS Khatoti	Bharatpur	132/33	20/25	21.00
400 kV GSS Deedwana	Deedwana	400/220	315	209.00
		400/220	315	209.00
		220/132	100	49.00
132 kV GSS Bambora	Udaipur	132/33	20/25	13.03
132 kV GSS Chitri	Dungarpur	132/33	20/25	14.00
132 kV GSS Riyabari	Nagaur	132/33	20/25	15.88
132 kV GSS Bar	Pali	132/33	20/25	11.97
132 kV GSS Ghumati	Pali	132/33	20/25	7.72
132 kV GSS Ahore	Jalore	132/33	20/25	13.70
132 kV GSS Baytu	Barmer	132/33	20/25	17.82
132 kV GSS Ramji ki Gol	Barmer	132/33	20/25	18.30
132 kV GSS Rajmatai	Jaisalmer	132/33	20/25	21.91
132 kV GSS Bengatikallan	Jodhpur	132/33	20/25	24.70
132 kV GSS Ghamurwali	Sri Ganganagar	132/33	20/25	12.13
132 kV GSS Shekhsar	Bikaner	132/33	20/25	24.70
132 kV GSS Sorda	Sirohi	132/33	20/25	20.62

12