



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LTD
LOAD DESPATCH CENTER ,HEERAPURA JAIPUR.

Power Position 07-Jun-19	Point No.
Date-wise Energy Availability, Consumption, Peak Load & Average Frequency	1
Energy Availability / Generation from different Sources	2
System Parameters	3
Water Level of major Reservoirs	4
Position of Coal Stock at KTPS,STPS & CHHABRA	5
Outage of major Generating Units	6

1. Date-Wise Energy Availability, Consumption,OD(+)/UD(-), Peak Load, Avg. Frequency,Wind Gen. –JUNE- 2019

Date	Anticipated Availability (In LU)		Consumption (In LU)		OD(+)/UD(-) (In LU)		Peak Load (In MW)		Average freq. (In Hz)	WIND (in LU)
	2019	2018	2019	2018	2019	2018	2019	2018	2019	2019
01-Jun-19	2615.18	2449.51	2615.85	2457.71	14.12	-6.23	11854	11218	49.99	222.97
02-Jun-19	2588.10	2619.13	2599.94	2467.43	16.11	52.12	11780	11373	50.03	220.54
03-Jun-19	2840.16	2655.80	2646.66	2413.63	7.91	18.33	11897	11148	50.02	315.51
04-Jun-19	2787.06	2680.80	2687.17	2497.74	-1.48	2.26	12159	11384	49.96	327.04
05-Jun-19	2769.49	2581.81	2713.76	2549.75	7.44	45.91	12382	11698	49.94	220.03
06-Jun-19	2788.19	2335.99	2705.26	2348.56	-29.64	44.00	12225	10685	49.98	146.53
07-Jun-19	2874.90	2513.27								
08-Jun-19										
09-Jun-19										
10-Jun-19										
11-Jun-19										
12-Jun-19										
13-Jun-19										
14-Jun-19										
15-Jun-19										
16-Jun-19										
17-Jun-19										
18-Jun-19										
19-Jun-19										
20-Jun-19										
21-Jun-19										
22-Jun-19										
23-Jun-19										
24-Jun-19										
25-Jun-19										
26-Jun-19										
27-Jun-19										
28-Jun-19										
29-Jun-19										
30-Jun-19										
01-Jul-19										
MAXIMUM OF THE MONTH	2874.90	2680.80	2713.76	2549.75	16.11	52.12	12382.00	11698.00	50.03	327.04
MIN OF THE MONTH	2588.10	2335.99	2599.94	2348.56	-29.64	-6.23	11780.00	10685.00	49.94	146.53
AVERAGE	2751.87	2548.04	2661.44	2455.80	2.41	26.07	12049.50	11251.00	49.99	242.10
MAX.CONSUMPTION TILL DATE DURING THE FY 2019-20 (L.U.)							2713.76	05-Jun-19		
MAX.PEAK LOAD TILL DATE DURING THE FY 2019-20 (MW)							12382	(07.30-07.45 Hrs.)	05-Jun-19	
MAX.CONSUMPTION DURING THE FY 2018-19 (L.U.)							2549.75	05-Jun-18		
MAX.PEAK LOAD DURING THE FY 2018-19 (MW)							13276	(09.30-09.45Hrs.)	28-Dec-18	
MAX.WIND TILL DATE DURING THE YEAR 2019-20 (L.U.)							487.20	08-May-19		
MAX.WIND DURING THE YEAR 2018-19 (L.U.)							565.54	13-Jun-18		

2. Anticipated Availability/Generation From Different Sources

(In LU)

S.No.	Sources Available to Rajasthan / Installed Capacity as on 31.08.2018 (In MW)	Prior assessment of Avail. For next Day	Prior assessment of Avail.	Actual Energy Received	Prior assessment of Avail. For next Day	Prior assessment of Avail.	Actual Energy Received	Prior assessment of Avail. For next Day	Prior assessment of Avail.	Actual Energy Received
1	KTPS (1240/1240)	252.00	252.00	230.96	252.00	252.00	239.76	252.00	252.00	235.66
2	STPS (1500/1500)	325.00	325.00	283.00	325.00	325.00	309.81	325.00	325.00	302.86
3	DHOLPUR GAS CCPP (330/330)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4	RAMGARH (273.5/273.5)	22.00	22.00	20.17	22.00	22.00	20.19	22.00	22.00	20.01
5	RAPP-A(200/200)	36.00	36.00	39.67	36.00	36.00	40.15	36.00	36.00	40.30
6	MAHI (140/140)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	CHAMBAL (RPS+JS) (135.5/271)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.00
8	SSCTPS#7	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9	CHHABRA TPS (1000/1000)+CSCTPP (660/660)	354.00	260.00	278.05	353.00	354.00	318.01	353.00	353.00	341.90
10	ADANI (TPS) + KALISINDH (TPS) (1200+1200/1320+1200)	389.00	423.00	369.96	420.00	389.00	367.47	556.00	420.00	418.61
11	WIND FARM (4139.20/4292.95)	176.00	269.00	327.04	120.00	176.00	220.03	23.75	120.00	146.53
12	SOLAR POWER(1661.70/2250.16)	171.72	177.65	173.15	173.15	171.72	179.06	179.06	173.15	171.08
13	CAPTIVE POWER PLANTS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
14	REGIONAL (INTRA STATE) O.A.(VLTPS)	0.00	0.00	24.49	0.00	0.00	24.54	0.00	0.00	24.55
15	OPEN ACCESS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
16	BIOMASS – (101.95/119.25)	6.00	6.00	5.50	7.00	6.00	6.67	7.00	7.00	6.65
17	BARSINGHSAR LTPS(250/250)	26.00	26.00	26.34	26.00	26.00	26.49	26.00	26.00	26.50
18	RAJWEST (1080/1080)	172.00	172.00	147.33	143.00	172.00	153.99	143.00	143.00	143.00
	TOTAL (A) : 1-18	1929.72	1968.65	1925.66	1877.15	1929.72	1906.17	1921.81	1877.15	1878.65
19	BBMB COMPLEX									
	a) BHAKRA(230.79/1516.3)	45.64	45.03	44.87	45.49	45.64	45.51	45.49	45.49	45.17
	b) DEHAR (198/ 990)	28.35	27.90	27.73	28.21	28.35	27.84	28.21	28.21	27.42
	c) PONG (231.66/396)	18.03	17.95	17.85	17.86	18.03	18.03	17.88	17.86	17.86
	TOTAL : a TO c	92.03	90.88	90.45	91.56	92.03	91.38	91.57	91.56	90.45
20	CENTRAL STATIONS									
	d) SINGRAULI (300/2000)+SINGRAULI SHEP (1.87/8.00)	90.57	80.75	85.24	91.97	90.57	91.52	92.33	91.97	89.22
	e) RIHAND (310.24/3000)	123.76	123.76	130.94	123.76	123.76	125.14	123.76	123.76	123.06
	f) UNCHAHAR-I(20/420)	6.42	5.74	4.18	6.08	6.42	5.85	5.31	6.08	5.52
	g) UNCHAHAR-II& III & IV(135.09/1130)	45.56	43.63	28.94	46.10	45.56	35.27	33.91	46.10	33.77
	h) INDIRA GANDHI STPS(JHAJHAR) 0.00/1500)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	i) NCTPS DADRI St-II (43.22/980) + DADRI-TH	17.79	14.95	8.75	16.85	17.79	17.90	12.15	16.85	9.84
	j) DADRI GAS (77/830)	2.81	2.74	2.31	2.81	2.81	3.83	2.81	2.81	2.31
	k) ANTA (83.07/419)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	l) AURAIYA (61.03/663)	0.00	0.00	0.00	0.00	0.00	0.17	0.00	0.00	0.00
	m) NAPP (44/440)	8.81	8.70	8.70	8.79	8.81	8.81	8.77	8.79	8.79
	n) RAPP-B (125/440)	27.21	27.95	27.95	26.31	27.21	27.21	28.02	26.31	26.31
	o) RAPP-C (88/440)	18.90	18.90	18.90	18.90	18.90	18.90	18.90	18.90	18.90
	p) SALAL (20.36/690)	4.80	4.74	4.58	4.78	4.80	4.46	4.80	4.78	4.76
	q) URI (70.37/720)	16.37	16.37	16.35	16.37	16.37	16.37	16.37	16.37	16.37
	r) TANAKPUR (10.86/94)	2.21	1.84	2.22	2.18	2.21	2.19	2.19	2.18	2.14
	s) CHAMERA –I (105.84/540)	24.25	24.25	24.25	21.97	24.25	24.25	21.97	21.97	21.97
	t) CHAMERA-II (29.01/300)	6.70	6.70	6.72	6.72	6.70	6.72	6.72	6.72	6.72
	u) CHAMERA-III (25.21/231)	5.86	5.78	5.82	5.86	5.86	5.86	5.86	5.86	5.86
	v) DHAULIGANGA (27/280)	6.17	6.17	6.17	6.17	6.17	6.17	6.17	6.17	6.17
	w) DULHASTI (42.42/390)	7.84	7.84	7.84	7.84	7.84	7.84	7.84	7.84	7.84
	x) SEWA (13/120)	2.90	2.51	1.57	2.99	2.90	2.90	2.09	2.99	2.30
	y) NJPC (112.00/1500)+RAMPUR(31.808/412.02)	35.71	35.71	35.71	35.71	35.71	32.03	35.71	35.71	35.71
	z) TEHRI (75/1000)	5.06	4.62	4.70	5.67	5.06	5.06	5.67	5.67	5.31
aa)	KOTESHWAR (33.44/400) + PARBATI3 (56.73/520)+KOLDAM (85.73/800)	23.96	25.43	24.33	23.96	23.96	22.97	24.16	23.96	24.24
	ab) TALA	0.68	0.68	0.65	0.68	0.68	0.61	0.67	0.68	0.69
	ac) MUNDRA UMPP (380/4000)	69.20	80.71	75.92	69.02	69.20	69.20	68.06	69.02	67.61
	ad) SASAN (372/3960)	68.74	84.65	76.61	68.74	68.74	68.74	83.29	68.74	69.56
	ae) FRKKA+KHLGN+TLCHR (70.18/3940)	30.76	28.94	26.23	30.32	30.76	30.72	30.55	30.32	28.05
	af) URS POWER(DADRI TH-I)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	TOTAL SCHEDULED(a TO af)	745.06	754.94	726.04	742.07	745.06	732.06	739.65	742.07	713.45
	LOSSES	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	NET SCHEDULED	745.06	754.94	726.04	742.07	745.06	732.06	739.65	742.07	713.45
21	BILATERAL (REG.) EXCL. BANKING	29.47	29.13	25.48	29.24	29.47	27.57	26.52	29.24	27.75
22	BANKING	-85.28	-85.28	-84.47	-85.28	-85.28	-85.28	-85.28	-85.28	-85.28
23	BILATERAL (INTER-REG.) EXCLUDING (ISOA & BANKING)	136.66	131.80	134.14	134.37	131.80	134.06	135.79	129.51	136.42
24	INTER STATE OPEN ACCESS (BILATERAL+IEX)	0.00	0.00	-21.17	0.00	0.00	-22.11	0.00	0.00	-26.73
25	INDIAN ENERGY EXCHANGE	13.85	-17.03	-17.03	90.64	13.85	13.85	136.40	90.64	90.64
	TOTAL(B): (19 TO 25)	839.77	818.42	762.99	911.04	839.77	800.15	953.09	911.04	856.25
	TOTAL GENERATION (A + B) : 1 TO 25			2688.65			2706.32			2734.90
	OVER DRAWAL (+)/UNDER DRAWAL (-)			-1.48			7.44			-29.64
	GRAND TOTAL	2769.49	2787.06	2687.17	2788.19	2769.49	2713.76	2874.90	2788.19	2705.26
	LAST YEAR	2581.81	2680.80	2497.74	2335.99	2581.81	2549.75	2513.27	2335.99	2348.56

3. SYSTEM PARAMETERS AS ON 06-Jun-19

MAXIMUM DRAWL ON 06-Jun-19	12225 MW at 09.45-10.00 HRS 50.05 HZ
MINIMUM DRAWL ON 06-Jun-19	8972 MW at 18.45-19.00 Hrs 49.92 HZ
Max U/D of the day	894 MW at 18.00-18.15 HRS 50.08 HZ
Max. O/D below 49.7 Hz	MW at
No. of Blocks Freq. < 49.7 Hz	0
No. of Violation Blocks Freq. < 49.7 Hz	0
No. of Blocks in which Freq. >= 49.7 & <49.9 Hz	8
NO. OF VIOLATION (OD BLOCKS) IN WHICH FREQ. >= 49.7 & <49.9 Hz	0
No. of Blocks in which Freq. >= 49.9 & <50.00 Hz	48
NO. OF BLOCKS(OD ABOVE 250 MW) IN WHICH FREQ. >= 49.9 & <50.00 Hz	2
NO. OF BLOCKS(UD ABOVE 250 MW) IN WHICH FREQ. >= 49.9 & <50.00 Hz	12
No. of Blocks in which Freq. >= 50.00 & <50.05 Hz	34
NO. OF BLOCKS(OD ABOVE 250 MW) IN WHICH FREQ. >= 50.00 & <50.05 Hz	4
NO. OF BLOCKS(UD ABOVE 250 MW) IN WHICH FREQ. >= 50.00 & <50.05 Hz	14
No. of Blocks in which Freq. >= 50.05 & <50.10 Hz	6
NO. OF UD BLOCKS IN WHICH FREQ. >= 50.05 & <50.10 Hz	3
No. of Blocks in which Freq. >= 50.10	0
NO. OF VIOLATION(UD BLOCKS) IN WHICH FREQ. >= 50.10	0
AVERAGE FREQ. FOR THE DAY 6-Jun-19	49.98 Hz
Max O/D of the day	433 MW at 08.30-08.45 Hrs 50.01 HZ
Frequency Profile	% of Time
LESS THAN 49.7 HZ	NA
LESS THAN 49.90 HZ	NA
OPERATING RANGE (49.90 HZ TO 50.05 HZ)	NA
ABOVE 50.05 HZ	#VALUE!
No. of 220 KV GSS advised to switch off 33 KV Urban Feeders	0
No. of 220 KV GSS advised to switch off 33 KV Rural Feeders	0
No. of 132 KV Feeders Disconnected	0

4. WATER LEVEL OF MAJOR RESERVOIR

Name of reservoir	Capacity level		Actual Level as on		Discharge (cusecs)	Inflow (cusecs)
	Max.	Min.	7-Jun-19	7-Jun-18		
Gandhi Sagar (Ft.)	1312	1250	1248.89	1269.62	NIL	85
R.P.Sagar (Ft.)	1157.5	1128	1135.67	1138.70	NIL	NIL
Jawahar Sagar (Ft.)	980	970.4	975.50	975.60	NIL	104
Kota Barrage(Ft.)	854.5	852.3	850.00	851.60		
RMC					15	
LMC					NIL	
Bhakra(Ft.)	1690	1462	1611.77	1493.63	35247	32600
Dehar (Ft.)	2941	2900	2936.67	2934.44	8257	9651
Pong(Ft.)	1421	1260	1344.14	1285.60	8006	3814
Mahi-I (Mts.)	281.5	259	267.90	269.20	NIL	NIL
Mahi-II (Mts.)	220.5	217	216.35	217.25	NIL	NIL

5. POSITION OF COAL STOCK (In MT)

Date	Name of Station	Stock at 00.00 hrs. (MT)	Coal stock sufficient for No. of days
7-Jun-19	KTPS	78040	4 DAYS
	STPS	255743	11 DAYS
	CHHABRA	194341	15 DAYS
	KALISINDH	266306	16.5 DAYS

6. GENERATING UNIT OUTAGE REPORT UP TO 8.00 HRS OF DT.

7-Jun-19

(A) PLANNED OUTAGE

NAME OF STATION	UNIT OUT	INSTALLED CAPACITY	NET ALLOC/ AVAIL. (MW)		OUTAGE		EXPECT./REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
STATE SECTOR									
GIRAL	1	125.00	60	14.40	60	11-Jul-14	8.20		BED MATERIAL LEAKAGE (SD W.E.F.15.07.14)
DCCPP	HRSG02	55.00	50	12.00	50	08-Oct-18	12.08		BOXED UP
DCCPP	HRSG01	55.00	50	12.00	50	08-Oct-18	12.08		BOXED UP
DCCPP	GT#2	110.00	100	24.00	100	08-Oct-18	12.28		BOXED UP
DCCPP	GT#1	110.00	100	24.00	100	08-Oct-18	12.29		BOXED UP
BTFS	1	125.00	110	26.40	110	23-May-19	7.46		ANNUAL SHUTDOWN FOR 30 DAY
CSCPP	5	600.00	600	144.00	600	27-May-19	0.10		ANNUAL SHUTDOWN FOR 30 DAY
Total(A)STATE SECTOR-PLANNED OUTAGE		1240.00	1070.00	256.80	1070.00				

CENTRAL SECTOR

AURAIYA GPS	3	111.19	18	4.40	18	01-Jun-19	6.17		RESERVE SHUTDOWN
AURAIYA GPS	6	109.30	12	2.90	12	01-Jun-19	6.22		RESERVE SHUTDOWN
AURAIYA GPS	4	111.19	18	4.40	18	01-Jun-19	6.33		RESERVE SHUTDOWN
ANTA GPS	3	88.71	31	7.50	31	31-May-19	4.26		NON AVAILABILITY OF CHEAP GAS
ANTA GPS	1	88.71	31	7.50	31	31-May-19	4.57		NON AVAILABILITY OF CHEAP GAS
ANTA GPS	4	153.20	34	8.20	34	31-May-19	5.18		NON AVAILABILITY OF CHEAP GAS
ANTA GPS	2	88.71	31	7.50	31	31-May-19	5.52		NON AVAILABILITY OF CHEAP GAS
AURAIYA GPS	2	111.19	18	4.40	18	30-May-19	18.01		NON AVAILABILITY OF CHEAP GAS
ANTA GPS	4	153.20	34	8.20	34	06-Jun-19	6.23		RESERVE SHUTDOWN
Total(A)CENTRAL SECTOR-PLANNED OUTAGE		1015.40	227.00	55.00	227.00				

(B) FORCE OUTAGE

STATE SECTOR										
NAME OF STATION	UNIT OUT	INSTALLED CAPACITY	NET ALLOC/ AVAIL. (MW)		OUTAGE		EXPECT./REVIVAL		REASON OF OUTAGE	
CENTRAL SECTOR										
GIRAL	2	125.00	70	16.80	70	27-Jan-16	15.27		DESYNCHRONIZED DUE TO ATTEND TUBE LEAKAGE IN ASH COOLAR-1	
RAMGARH	GT3	110.00	100	24.00	100	07-Dec-18	20.45		INSUFFICIENT AVAILABILITY OF GAS	
RAMGARH	STG#2	50.00	40	9.60	40	05-Oct-18	10.58		NON AVAILABILITY OF SUFFICIENT GAS	
KALISINDH	2	600.00	565	0.00	0	04-Apr-19	14.01	06-Jun-19	13.13	ELECTRICAL FAULT
RAJWEST	7	135.00	120	28.68	120	03-Jun-19	14.00		BED MATERIAL LEAKAGE	
RAJWEST	8	135.00	120	28.68	120	04-Jun-19	17.40		BED MATERIAL LEAKAGE	
RAJWEST	1	135.00	120	28.68	120	05-Jun-19	7.56		BED MATERIAL LEAKAGE	
Total(B)STATE SECTOR-FORCED OUTAGE		1290.00	1135.00	136.44	570.00					
CENTRAL SECTOR										
SINGRAULI STPS	6	500.00	85	20.50	85	01-Jun-19	23.02		BOILER TUBE LEAKAGE	
AURAIYA GPS	5	109.30	12	2.90	12	30-May-19	16.42		AVR PROBLEM	
AURAIYA GPS	1	111.19	18	4.40	18	05-Jun-19	22.50		NON AVAILABILITY OF CHEAP GAS	
Total(B)CENTRAL SECTOR-FORCED OUTAGE		720.49	115.00	27.80	115.00					
G.TOTAL				164.24	685.00					

Note :- Loss of Generation shall not be considered in case unit is boxed up due to low demand (*), planned annual shut down (@) and COD is not declared (\$).