



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LTD
LOAD DESPATCH CENTER ,HEERAPURA JAIPUR.

Power Position 25-Mar-19	Point No.
Date-wise Energy Availability, Consumption, Peak Load & Average Frequency	1
Energy Availability / Generation from different Sources	2
System Parameters	3
Water Level of major Reservoirs	4
Position of Coal Stock at KTPS,STPS & CHHABRA	5
Outage of major Generating Units	6

1. Date-Wise Energy Availability, Consumption,OD(+)/UD(-), Peak Load, Avg. Frequency,Wind Gen. –MARCH- 2019

Date	Anticipated Availability (In LU)		Consumption (In LU)		OD(+)/UD(-) (In LU)		Peak Load (In MW)		Average freq. (In Hz)	WIND (in LU)
	2019	2018	2019	2018	2019	2018	2019	2018	2019	2019
01-Mar-19	2433.11	2019.86	2305.32	2030.20	7.42	35.23	11601	10138	50.01	170.81
02-Mar-19	2580.65	2017.00	2236.43	1815.97	-2.36	-10.81	11268	9407	50.00	259.32
03-Mar-19	2372.66	1988.84	2117.52	1843.58	-25.04	28.42	11409	9766	49.99	157.16
04-Mar-19	2267.54	2007.70	2249.44	1872.10	-9.86	13.60	11885	9743	49.99	109.08
05-Mar-19	2216.85	1960.55	2266.97	1893.32	-1.08	25.94	11429	9807	49.96	38.16
06-Mar-19	2380.48	2043.31	2259.49	1969.54	-3.44	22.22	11283	9957	49.98	44.22
07-Mar-19	2403.91	2112.58	2329.87	2083.64	-21.76	25.30	11477	10626	49.96	42.83
08-Mar-19	2440.87	2065.31	2278.25	2098.94	-44.10	55.81	11498	10284	49.97	317.51
09-Mar-19	2423.65	2043.13	2284.16	2087.96	-12.16	17.52	11173	10723	49.94	147.26
10-Mar-19	2456.73	1980.92	2172.67	2042.02	-19.26	40.08	10873	10409	49.97	173.73
11-Mar-19	2449.73	1955.52	2226.39	1991.79	-6.48	16.19	10940	10348	49.97	118.70
12-Mar-19	2473.20	1970.91	2293.91	2004.98	-10.26	28.49	11348	10111	49.98	136.49
13-Mar-19	2529.10	2046.72	2249.67	2006.29	-18.59	19.06	11130	10574	49.99	131.66
14-Mar-19	2508.90	2028.48	2194.60	1998.19	-23.37	13.31	11005	10290	49.98	132.76
15-Mar-19	2411.46	1948.74	2183.19	1973.15	-9.27	32.36	10973	9816	50.00	123.71
16-Mar-19	2363.73	1979.68	2212.17	1959.29	1.28	19.56	11040	9969	50.01	141.69
17-Mar-19	2378.53	1975.86	2144.05	1908.86	-13.85	-4.41	10831	9951	50.00	65.95
18-Mar-19	2384.06	2113.96	2205.88	1872.47	-5.11	10.93	11002	9681	50.01	43.27
19-Mar-19	2498.82	1939.70	2182.89	1908.81	-2.05	-7.27	10875	9771	50.00	189.97
20-Mar-19	2288.11	1987.82	2117.45	1865.27	-19.63	13.38	10695	9475	50.00	136.15
21-Mar-19	2220.34	1949.60	1878.27	1859.32	-11.01	12.03	9418	9664	50.02	202.37
22-Mar-19	2178.99	1861.05	1990.32	1863.84	-18.70	27.59	9619	9684	50.01	191.94
23-Mar-19	2184.56	1874.47	2090.04	1859.06	-23.74	15.33	9986	9672	49.99	235.80
24-Mar-19	2255.19	1915.74	2109.15	1838.63	-0.69	-2.74	10231	9644	50.01	150.95
25-Mar-19	2238.81	1876.98								
26-Mar-19										
27-Mar-19										
28-Mar-19										
29-Mar-19										
30-Mar-19										
31-Mar-19										
MAXIMUM OF THE MONTH	2580.65	2113.96	2329.87	2098.94	7.42	55.81	11885.00	10723.00	50.02	317.51
MIN OF THE MONTH	2178.99	1861.05	1878.27	1815.97	-44.10	-10.81	9418.00	9407.00	49.94	38.16
AVERAGE	2373.60	1986.58	2190.75	1943.63	-12.21	18.63	10957.88	9979.58	49.99	144.23
MAX.CONSUMPTION TILL DATE DURING THE FY 2018-19 (L.U.)							2549.75	05-Jun-18		
MAX.PEAK LOAD TILL DATE DURING THE FY 2018-19 (MW)							13276	(09.30-09.45Hrs.)	28-Dec-18	
MAX.CONSUMPTION DURING THE FY 2017-18 (L.U.)							2222.22	18-Aug-17		
MAX.PEAK LOAD DURING THE FY 2017-18 (MW)							11564	(08.00-8.15Hrs.)	13-Jan-18	
MAX.WIND TILL DATE DURING THE YEAR 2018-19 (L.U.)							565.54	13-Jun-18		
MAX.WIND DURING THE YEAR 2017-18 (L.U.)							482.76	04-Jul-17		

2. Anticipated Availability/Generation From Different Sources

(In LU)

S.No.	Sources Available to Rajasthan / Installed Capacity as on 31.08.2018 (In MW)	Prior assessment of Avail. For next Day	Prior assessment of Avail.	Actual Energy Received
		24-Mar-19		
1	KTPS (1240/1240)	42.00	42.00	39.48
2	STPS (1500/1500)	55.00	55.00	45.94
3	DHOLPUR GAS CCPP (330/330)	0.00	0.00	0.00
4	RAMGARH (273.5/273.5)	22.00	21.00	22.10
5	RAPP-A(200/200)	40.00	40.00	43.07
6	MAHI (140/140)	0.00	0.00	3.93
7	CHAMBAL (RPS+JS) (135.5/271)	23.00	23.00	26.58
8	GIRAL LIGNITE (250/250)	0.00	0.00	0.00
9	CHHABRA TPS (1000/1000)+CSCTPP (660/660)	334.00	334.00	322.40
10	ADANI (TPS) + KALISINDH (TPS) (1200+1200/1320+1200)	423.00	423.00	353.46
11	WIND FARM (4139.20/4292.95)	148.00	156.00	150.95
12	SOLAR POWER(1661.70/2250.16)	168.69	185.42	164.94
13	CAPTIVE POWER PLANTS	0.00	0.00	0.00
14	REGIONAL (INTRA STATE) O.A.(VLTPS)	0.00	0.00	0.12
15	OPEN ACCESS	0.00	0.00	0.00
16	BIOMASS – (101.95/119.25)	6.00	6.00	6.29
17	BARSINGHSAR LTPS(250/250)	52.00	52.00	51.28
18	RAJWEST (1080/1080)	201.00	201.00	165.40
	TOTAL (A) : 1-18	1514.69	1538.42	1395.94
19	BBMB COMPLEX			
a)	BHAKRA(230.79/1516.3)	26.28	27.19	26.83
b)	DEHAR (198/ 990)	13.36	10.74	13.63
c)	PONG (231.66/396)	1.39	5.11	4.67
	TOTAL : a TO c	41.02	43.04	45.14
20	CENTRAL STATIONS			
d)	SINGRAULI (300/ 2000)+SINGRAULI SHEP (1.87/8.00)	94.93	95.20	94.57
e)	RIHAND (310.24/3000)	122.40	122.68	122.68
f)	UNCHAHAHAR-I(20/420)	4.92	5.74	3.56
g)	UNCHAHAHAR-II& III & IV(135.09/1130)	18.10	19.97	10.50
h)	INDIRA GANDHI STPS(JHAJHAR) 0.00/1500)	0.00	0.00	0.00
i)	NCTPS DADRI St-II (43.22/980) + DADRI-TH	6.87	8.01	3.54
j)	DADRI GAS (77/830)	5.67	6.75	4.56
k)	ANTA (83.07/419)	0.00	0.00	0.00
l)	AURAIYA (61.03/663)	0.00	0.00	0.00
m)	NAPP (44/440)	9.07	9.07	9.07
n)	RAPP-B (125/440)	29.45	29.51	29.51
o)	RAPP-C (88/440)	9.49	9.51	9.51
p)	SALAL (20.36/690)	1.81	1.75	2.07
q)	URI (70.37/720)	15.08	16.31	15.53
r)	TANAKPUR (10.86/94)	0.39	0.39	0.38
s)	CHAMERA –I (105.84/540)	9.83	9.85	9.85
t)	CHAMERA-II (29.01/300)	2.29	2.53	2.48
u)	CHAMERA-III (25.21/231)	1.58	1.60	1.79
v)	DHAULIGANGA (27/280)	0.96	0.96	0.96
w)	DULHASTI (42.42/390)	3.45	3.51	3.55
x)	SEWA (13/120)	3.14	2.98	2.98
y)	NJPC (112.00/1500)+RAMPUR(31.808/412.02)	6.28	6.47	6.47
z)	TEHRI (75/1000)	5.73	5.88	5.88
aa)	KOTESHWR (33.44/400) + PARBATI3 (56.73/520)+KOLDAM (85.73/800)	6.04	6.05	6.05
ab)	TALA	0.24	0.24	0.24
ac)	MUNDRA UMPP (380/4000)	81.97	83.76	78.37
ad)	SASAN (372/3960)	85.01	85.62	85.62
ae)	FRKKA+KHLGN+TLCHR (70.18/3940)	26.66	27.06	23.15
af)	URS POWER(DADRI TH-I)	0.00	0.00	0.00
	TOTAL SCHEDULE(a TO af)	592.37	604.44	578.00
	LOSSES	0.00	0.00	0.00
	NET SCHEDULED	592.37	604.44	578.00
21	BILATERAL (REG.) EXCL. BANKING	3.24	3.54	3.54
22	BANKING	-16.00	-15.98	-15.98
23	BILATERAL(INTER-REG.) EXCLUDING (ISOA & BANKING)	119.59	103.74	119.72
24	INTER STATE OPEN ACCESS (BILATERAL+IEX)	0.00	0.00	23.56
25	INDIAN ENERGY EXCHANGE	24.92	5.06	5.06
	TOTAL(B): (19 TO 25)	724.12	716.77	713.90
	TOTAL GENERATION (A +B) : 1 TO 25			2109.84
	OVER DRAWAL (+)/UNDER DRAWAL (-)			-0.69
	GRAND TOTAL	2238.81	2255.19	2109.15
	LAST YEAR	1876.98	1915.74	1838.63

3. SYSTEM PARAMETERS AS ON 24-Mar-19

MAXIMUM DRAWL ON 24-Mar-19	10231 MW at 7.45-8.00 HRS 50.05 HZ
MINIMUM DRAWL ON 24-Mar-19	7019 MW at 4.00 -4.15 Hrs 50.01 HZ
Max U/D of the day	476 MW at 10.30-10.45Hrs 50.08 HZ.
Max. O/D below 49.7 Hz	MW at
No. of Blocks Freq. < 49.7 Hz	0
No. of Violation Blocks Freq. < 49.7 Hz	0
No. of Blocks in which Freq. >= 49.7 & <49.9 Hz	1
NO. OF VIOLATION (OD BLOCKS) IN WHICH FREQ. >= 49.7 & <49.9 Hz	0
No. of Blocks in which Freq. >= 49.9 & <50.00 Hz	25
NO. OF BLOCKS(OD ABOVE 250 MW) IN WHICH FREQ. >= 49.9 & <50.00 Hz	7
NO. OF BLOCKS(UD ABOVE 250 MW) IN WHICH FREQ. >= 49.9 & <50.00 Hz	0
No. of Blocks in which Freq. >= 50.00 & <50.05 Hz	55
NO. OF BLOCKS(OD ABOVE 250 MW) IN WHICH FREQ. >= 50.00 & <50.05 Hz	6
NO. OF BLOCKS(UD ABOVE 250 MW) IN WHICH FREQ. >= 50.00 & <50.05 Hz	8
No. of Blocks in which Freq. >= 50.05 & <50.10 Hz	14
NO. OF UD BLOCKS IN WHICH FREQ. >= 50.05 & <50.10 Hz	10
No. of Blocks in which Freq. >= 50.10	1
NO. OF VIOLATION(UD BLOCKS) IN WHICH FREQ. >= 50.10	1
AVERAGE FREQ. FOR THE DAY 24-Mar-19	50.01 Hz
Max O/D of the day	428 MW at 08.45-09.00 Hrs 50.04HZ
Frequency Profile	% of Time
LESS THAN 49.7 HZ	0.00
LESS THAN 49.90 HZ	2.90
OPERATING RANGE (49.90 HZ TO 50.05 HZ)	71.50
ABOVE 50.05 HZ	25.60
No. of 220 KV GSS advised to switch off 33 KV Urban Feeders	0
No. of 220 KV GSS advised to switch off 33 KV Rural Feeders	0
No. of 132 KV Feeders Disconnected	0

6. GENERATING UNIT OUTAGE REPORT UP TO 8.00 HRS OF DT. 25-Mar-19

(A) PLANNED OUTAGE

NAME OF STATION	UNIT OUT	INSTALLED CAPACITY	NET ALLOC./ AVAIL. (MW)		OUTAGE		EXPECT./REVIVAL		REASON OF OUTAGE	
					DATE	TIME	DATE	TIME		
STATE SECTOR										
GIRAL	1	125.00	60	14.40	60	11-Jul-14	8.20		BED MATERIAL LEAKAGE (SD W.E.F.15.07.14)	
DCCPP	HRSG#2	55.00	50	12.00	50	08-Oct-18	12.08		BOXED UP	
DCCPP	HRSG#1	55.00	50	12.00	50	08-Oct-18	12.08		BOXED UP	
DCCPP	GT#2	110.00	100	24.00	100	08-Oct-18	12.28		BOXED UP	
DCCPP	GT#1	110.00	100	24.00	100	08-Oct-18	12.29		BOXED UP	
STPS	6	250.00	229	55.00	229	16-Feb-19	13.48		BOXED UP	
STPS	4	250.00	229	55.00	229	17-Feb-19	14.31		BOXED UP	
STPS	5	250.00	229	55.00	229	08-Mar-19	1.58		BOXED UP	
STPS	2	250.00	229	55.00	229	14-Mar-19	12.47		BOXED UP	
STPS	3	250.00	229	55.00	229	14-Mar-19	15.58		BOXED UP	
KTPS	4	210.00	192	46.00	192	19-Mar-19	11.30		BOXED UP	
KTPS	1	110.00	95	23.00	95	19-Mar-19	21.18		BOXED UP	
KTPS	2	110.00	95	23.00	95	19-Mar-19	21.32		BOXED UP	
KTPS	5	210.00	192	46.00	192	20-Mar-19	10.47		BOXED UP	
KTPS	3	210.00	192	46.00	192	20-Mar-19	10.54		BOXED UP	
KTPS	7	195.00	175	42.00	175	20-Mar-19	12.10		BOXED UP	
Total(A)STATE SECTOR-PLANNED OUTAGE		2750.00	2446.00	587.40	2446.00					
CENTRAL SECTOR										
AURAIYA GPS	6	109.30	12	2.90	12	30-Nov-18	5.47		RESERVE SHUTDOWN-NON AVAILABILITY OF GAS	
AURAIYA GPS	2	111.19	18	4.40	18	12-Jan-19	9.53		RESERVE SHUTDOWN	
AURAIYA GPS	4	111.19	18	4.40	18	05-Jan-19	10.42		RESERVE SHUTDOWN	
AURAIYA GPS	5	109.30	12	2.90	12	08-Jan-19	5.54		RESERVE SHUTDOWN	
AURAIYA GPS	1	111.19	18	4.40	18	11-Jan-19	10.06		RESERVE SHUTDOWN	
DADRI GPS	3	130.19	22	0.00	0	12-Jan-19	10.05	08-Mar-19	8.17	RESERVE SHUTDOWN
ANTA GPS	1	88.71	31	7.50	31	05-Feb-19	9.10		RESERVE SHUTDOWN	
ANTA GPS	2	88.71	31	7.50	31	05-Feb-19	10.44		RESERVE SHUTDOWN	
ANTA GPS	4	153.20	34	8.20	34	05-Feb-19	11.20		RESERVE SHUTDOWN	
AURAIYA GPS	3	111.19	18	4.40	18	11-Feb-19	20.45		RESERVE SHUTDOWN	
DADRI GPS	6	154.51	16	3.90	16	08-Mar-19	17.52		RESERVE SHUTDOWN	
DADRI GPS	2	130.19	22	5.30	22	08-Mar-19	18.20		RESERVE SHUTDOWN	
DADRI GPS	1	130.19	22	5.30	22	08-Mar-19	20.45		RESERVE SHUTDOWN	
Total(A)CENTRAL SECTOR-PLANNED OUTAGE		1539.06	274.00	61.10	252.00					
(B) FORCE OUTAGE										
STATE SECTOR										
STATE SECTOR										
GIRAL	2	125.00	70	16.80	70	27-Jan-16	15.27		DESYNCHRONIZED DUE TO ATTEND TUBE LEAKAGE IN ASH COOLAR-I	
RAMGARH	GT3	110.00	100	24.00	100	07-Dec-18	20.45		INSUFFICIENT AVAILABILITY OF GAS	
RAMGARH	STG#2	50.00	40	9.60	40	05-Oct-18	10.58		NON AVAILABILITY OF SUFFICIENT GAS	
KALISINDBI	2	600.00	565	135.60	565	20-Mar-19	21.49		BTL	
RAJWEST	5	135.00	120	28.67	120	23-Mar-19	0.14		BED MATERIAL LEAKAGE	
Total(B)STATE SECTOR-FORCED OUTAGE		1020.00	895.00	214.67	895.00					
CENTRAL SECTOR										
DADRI-II TPS	1	490.00	15	3.59	15	06-Feb-19	17.37		ROTOR EARTH FAULT	
RAPP-C	5	220.00	44	10.50	44	18-Mar-19	1.31		MANUALLY OPENED DUE TO HIGH VOLTAGE TURBINE FEEDING PROBLEM (HYDROGEN COOLER LEAKAGE)	
UNCHAHAR TPS	6	500.00	NA	NA	NA	23-Mar-19	14.28		BOILER TUBE LEAKAGE	
Total(B)CENTRAL SECTOR-FORCED OUTAGE		1210.00	59.00	14.09	59.00					
G.TOTAL				228.76	954.00					

Note :- Loss of Generation shall not be considered in case unit is boxed up due to low demand (*), planned annual shut down (@) and COD is not declared (\$).