



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LTD
LOAD DESPATCH CENTER ,HEERAPURA JAIPUR.

Power Position 23-Oct-17	Point No.
Date-wise Energy Availability, Consumption, Peak Load & Average Frequency	1
Energy Availability / Generation from different Sources	2
System Parameters	3
Water Level of major Reservoirs	4
Position of Coal Stock at KTPS,STPS & CHHABRA	5
Outage of major Generating Units	6

1. Date-Wise Energy Availability, Consumption,OD(+)/UD(-), Peak Load, Avg. Frequency,Wind Gen. -OCT- 2017

Date	Anticipated Availability (In LU)		Consumption (In LU)		OD(+)/UD(-) (In LU)		Peak Load (In MW)		Average freq. (In Hz)	WIND (in LU)
	2017	2016	2017	2016	2017	2016	2017	2016		
Oct-17										
1-Oct-17	2052.07	2034.37	1961.11	1990.31	24.09	22.57	9517	8968	50.00	144.93
2-Oct-17	1955.19	2042.94	2012.63	1890.88	39.62	8.14	9262	9016	49.97	162.66
3-Oct-17	1952.76	1977.65	1967.29	1867.72	40.89	1.81	9222	8471	49.93	90.25
4-Oct-17	1938.48	1989.21	1982.51	1796.01	24.27	-2.17	9115	8390	49.94	56.48
5-Oct-17	1959.56	1870.85	2039.94	1606.02	28.82	10.63	9061	7492	49.94	40.02
6-Oct-17	1914.81	1826.04	2025.64	1603.07	63.07	7.90	9252	7559	49.97	35.22
7-Oct-17	1895.69	1890.13	2028.58	1655.87	59.34	-2.91	8991	7844	49.95	40.98
8-Oct-17	1946.49	1895.40	2001.50	1672.43	21.65	20.49	9273	7812	49.98	25.02
9-Oct-17	1950.06	1841.42	2008.78	1620.28	48.23	7.92	9303	7566	49.98	52.10
10-Oct-17	1949.14	1794.15	2039.56	1591.97	61.02	30.32	9736	7572	49.97	55.92
11-Oct-17	2069.25	1743.44	2087.98	1612.83	14.62	28.33	9714	7336	49.96	49.30
12-Oct-17	2121.39	1677.86	2086.36	1663.90	9.99	31.90	10367	7852	49.96	35.37
13-Oct-17	1980.25	1685.28	2045.16	1685.45	48.44	37.61	9737	7521	49.94	35.18
14-Oct-17	1997.02	1598.00	2062.21	1697.62	17.68	38.99	10284	7823	49.97	101.33
15-Oct-17	2016.51	1714.81	2009.55	1753.49	16.98	23.71	10188	8156	49.99	80.83
16-Oct-17	1978.73	1877.15	2035.93	1727.21	-8.03	36.09	9800	7920	49.97	62.01
17-Oct-17	1910.15	1815.13	2045.05	1788.48	3.50	29.00	9965	8198	49.99	43.25
18-Oct-17	1997.65	1775.40	2008.80	1808.05	16.01	16.32	9754	8385	50.01	21.61
19-Oct-17	1988.87	1914.83	1857.71	1821.01	13.98	12.20	9453	8385	50.01	61.81
20-Oct-17	1943.79	1739.27	1796.29	1850.07	5.13	8.20	8964	9263	49.98	28.73
21-Oct-17	1869.32	1974.59	1881.70	1815.76	13.99	12.52	9113	8440	49.96	47.46
22-Oct-17	2016.69	1819.09	1837.33	1832.41	7.75	16.93	9138	8326	49.97	113.01
23-Oct-17	1928.80	1788.88								
24-Oct-17										
25-Oct-17										
26-Oct-17										
27-Oct-17										
28-Oct-17										
29-Oct-17										
30-Oct-17										
31-Oct-17										
MAXIMUM OF THE MONTH	2121.39	2042.94	2087.98	1990.31	63.07	38.99	10367.00	9263.00	50.01	162.66
MIN OF THE MONTH	1869.32	1598.00	1796.29	1591.97	-8.03	-2.91	8964.00	7336.00	49.93	21.61
AVERAGE	1972.90	1845.91	1991.89	1743.22	25.96	18.02	9509.50	8104.32	49.97	62.89
MAX.CONSUMPTION TILL DATE DURING THE FY 2017-18 (L.U.)							2222.22	18-Aug-17		
MAX.PEAK LOAD TILL DATE DURING THE FY 2017-18 (MW)							10367	(07.00-07.15 Hrs.)	12-Oct-17	
MAX.CONSUMPTION DURING THE FY 2016-17 (L.U.)							2114.62	20-Sep-16		
MAX.PEAK LOAD DURING THE FY 2016-17 (MW)							10367	(07.00-07.15Hrs.)	12-Oct-17	
MAX.WIND TILL DATE DURING THE YEAR 2017-18 (L.U.)							482.76	4-Jul-17		
MAX.WIND DURING THE YEAR 2016-17 (L.U.)							448.85	4-Aug-17		

2. Anticipated Availability/Generation From Different Sources

(In LU)

S.No.	Sources Available to Rajasthan / Installed Capacity as on 30.09.2016 (In MW)	Prior assessment of Avail. For next Day	Prior assessment of Avail.	Actual Energy Received
		22-Oct-17		
1	KTPS (1240/1240)	224.00	224.00	180.09
2	STPS (1500/1500)	110.00	110.00	86.46
3	DHOLPUR GAS CCPP (330/330)	0.00	0.00	16.62
4	RAMGARH (273.5/273.5)	37.00	47.00	32.96
5	RAPP-A(200/200)	41.00	41.00	41.50
6	MAHI (140/140)	0.00	0.00	0.00
7	CHAMBAL (RPS+JS) (135.5/271)	37.50	37.50	39.05
8	GIRAL LIGNITE (250/250)	0.00	0.00	0.00
9	CHHABRA TPS 1000/1000)	219.00	219.00	310.74
10	ADANI (TPS) + KALISINDH (TPS) (1200+1200/1320+1200)	284.00	284.00	228.23
11	WIND FARM (3980.40/4119.15)	40.00	106.50	113.01
12	SOLAR POWER(737.70/1295.70)	0.00	0.00	2.22
13	CAPTIVE POWER PLANTS	0.00	0.00	0.00
14	REGIONAL (INTRA STATE) O.A.(VLTPS)	0.00	0.00	0.00
15	OPEN ACCESS	24.15	20.29	20.29
16	BIOMASS – (101.95/119.25)	5.00	6.00	4.87
17	BARSINGHAR LTPS(250/250)	53.00	53.00	51.26
18	RAJWEST (1080/1080)	172.00	172.00	118.61
	TOTAL (A) : 1-18	1246.65	1320.29	1245.91
19	BBMB COMPLEX			
a)	BHAKRA(230.79/1516.3)	21.06	21.11	20.76
b)	DEHAR (198/ 990)	11.40	12.40	13.31
c)	PONG (231.66/396)	36.61	31.96	36.61
	TOTAL : a TO c	69.08	65.46	70.68
20	CENTRAL STATIONS			
d)	SINGRAULI (300/ 2000)	80.71	79.48	53.58
e)	RIHAND (310.24/3000)	118.40	118.40	116.07
f)	UNCHAHAHAR-I(20/420)	2.58	2.79	0.45
g)	UNCHAHAHAR-II& III(61/630)	36.99	39.03	7.43
h)	INDIRA GANDHI STPS(JHAJHAR) 0.00/1500)	0.00	0.00	0.00
i)	NCTPS DADRI St-II (43.22/980) + DADRI-TH	11.11	9.09	2.90
j)	DADRI GAS (77/830)	2.98	3.32	3.53
k)	ANTA (83.07/419)	0.00	0.00	0.00
l)	AURAIYA (61.03/663)	0.00	0.00	0.00
m)	NAPP (44/440)	9.50	9.38	9.38
n)	RAPP-B (125/440)	33.50	37.79	37.79
o)	RAPP-C (88/440)	19.86	19.86	19.86
p)	SALAL (20.36/690)	1.06	1.03	1.32
q)	URI (70.37/720)	2.90	2.92	2.89
r)	TANAKPUR (10.86/94)	1.61	1.65	1.64
s)	CHAMERA –I (105.84/540)	5.10	5.10	5.10
t)	CHAMERA-II (29.01/300)	2.06	2.22	2.34
u)	CHAMERA-III (25.21/231)	1.51	1.90	1.82
v)	DHAULIGANGA (27/280)	2.62	2.68	2.52
w)	DULHASTI (42.42/390)	6.74	7.07	7.07
x)	SEWA (13/120)	0.39	0.39	0.39
y)	NJPC (112.00/1500)+RAMPUR(31.808/412.02)	13.36	12.99	12.22
z)	TEHRI (75/1000)	5.18	5.18	5.18
aa)	KOTESHWR (33.44/400) + PARBATI3 (56.73/520)	4.83	5.36	7.71
ab)	TALA	1.78	1.62	1.62
ac)	MUNDRA UMPP (380/4000)	60.42	62.59	44.43
ad)	SASAN (372/3960)	86.11	87.48	69.00
ae)	FRKKA+KHLGN+TLCHR (70.18/3940)	22.90	23.79	7.71
af)	URS POWER(DADRI TH-I)	0.00	0.00	0.00
	TOTAL SCHEDULED(a TO af)	603.26	608.59	494.62
	LOSSES	-22.22	-22.37	-20.51
	NET SCHEDULED	581.04	586.22	474.10
21	BILATERAL (REG.) EXCL. BANKING	6.99	6.74	6.13
22	BANKING	0.00	0.00	0.00
23	BILATERAL(INTER-REG.). EXCLUDING (ISOA & BANKING)	114.70	88.49	114.71
24	INTER STATE OPEN ACCESS (BILATERAL+IEX)	-24.15	-20.29	-20.29
25	INDIAN ENERGY EXCHANGE	3.57	9.02	9.02
	TOTAL(B): (19 TO 25)	682.16	696.40	583.67
	TOTAL GENERATION (A +B) : 1 TO 25			1829.58
	OVER DRAWAL (+)/UNDER DRAWAL (-)			7.75
	GRAND TOTAL	1928.80	2016.69	1837.33
	LAST YEAR	1788.88	1819.09	1832.41

3. SYSTEM PARAMETERS AS ON 22-Oct-17

MAXIMUM DRAWL ON 22-Oct-17	9138 MW at 07.15-07.30 Hrs 49.99 Hz
MINIMUM DRAWL ON 22-Oct-17	6808 MW at 21.45-22.00 Hrs 50.00Hz
Max U/D of the day	528 MW at 04.00-04.15 HRS. 50.03 Hz
Max. O/D below 49.7 Hz	MW at
No. of Blocks Freq. < 49.7 Hz	0
No. of Violation Blocks Freq. < 49.7 Hz	0
No. of Blocks in which Freq. >= 49.7 & <49.9 Hz	3
NO. OF VIOLATION (OD BLOCKS) IN WHICH FREQ. >= 49.7 & <49.9 Hz	2
No. of Blocks in which Freq. >= 49.9 & <50.00 Hz	63
NO. OF BLOCKS(OD ABOVE 250 MW) IN WHICH FREQ. >= 49.9 & <50.00 Hz	15
NO. OF BLOCKS(UD ABOVE 250 MW) IN WHICH FREQ. >= 49.9 & <50.00 Hz	4
No. of Blocks in which Freq. >= 50.00 & <50.05 Hz	30
NO. OF BLOCKS(OD ABOVE 250 MW) IN WHICH FREQ. >= 50.00 & <50.05 Hz	2
NO. OF BLOCKS(UD ABOVE 250 MW) IN WHICH FREQ. >= 50.00 & <50.05 Hz	5
No. of Blocks in which Freq. >= 50.05 & <50.10 Hz	0
NO. OF UD BLOCKS IN WHICH FREQ. >= 50.05 & <50.10 Hz	0
No. of Blocks in which Freq. >= 50.10	0
NO. OF VIOLATION(UD BLOCKS) IN WHICH FREQ. >= 50.10	0
AVERAGE FREQ. FOR THE DAY 22-Oct-17	49.97 Hz
Max O/D of the day	553 MW at 05.45-06.00 Hrs 50.03 Hz
Frequency Profile	% of Time
LESS THAN 49.7 HZ	0.00
LESS THAN 49.90 HZ	8.61
OPERATING RANGE (49.90 HZ TO 50.05 HZ)	82.75
ABOVE 50.05 HZ	8.64
No. of 220 KV GSS advised to switch off 33 KV Urban Feeders	0
No. of 220 KV GSS advised to switch off 33 KV Rural Feeders	0
No. of 132 KV Feeders Disconnected	0

4. WATER LEVEL OF MAJOR RESERVOIR

Name of reservoir	Capacity level		Actual Level as on		Discharge (cusecs)	Inflow (cusecs)
	Max.	Min.	23-Oct-17	23-Oct-16		
Gandhi Sagar (Ft.)	1312	1250	1300.67	1311.79	2584	269
R.P.Sagar (Ft.)	1157.5	1128	1142.25	1155.86	7596	1257
Jawahar Sagar (Ft.)	980	970.4	976.10	974.50	8337	5794
Kota Barrage(Ft.)	854.5	852.3	853.30	853.70		
RMC					6075	
LMC					1300	
Bhakra(Ft.)	1690	1462	1664.76	1640.06	12189	11606
Dehar (Ft.)	2941	2900	2922.83	2918.04	3521	3753
Pong(Ft.)	1421	1260	1372.23	1362.67	11511	2381
Mahi-I (Mts.)	281.5	259	281.45	281.50	NA	NIL
Mahi-II (Mts.)	220.5	217	216.90	217.15	NA	NIL

5. POSITION OF COAL STOCK (In MT)

Date	Name of Station	Stock at 00.00 hrs. (MT)	Coal stock sufficient for No. of days
23/Oct/17	KTPS	54971	3 DAYS
	STPS	60281	2.5 DAYS
	CHHABRA	29940	4 DAYS
	KALISINDH	50106	3.5 DAYS

6. GENERATING UNIT OUTAGE REPORT UP TO 8.00 HRS OF DT.

23/Oct/17

(A) PLANNED OUTAGE

NAME OF STATION	UNIT OUT	INSTALLED CAPACITY	NET ALLOC./AVAIL. (MW)		OUTAGE		EXPECT./REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
STATE SECTOR									
GIRAL	1	125.00	70	16.80	70	11-Jul-14	8.20		BED MATERIAL LEAKAGE (SD W.E.F.15.07.14)
DCCPP	HRSG#2*	55.00	50	12.00	50	13-Jul-16	16.35		BOXED UP/PERMISSION GIVEN BY RUVNL ON DATE 17.08.17 BUT PROBLEM IN DCCPP END)
DCCPP	GT#2*	110.00	100	24.00	100	13-Jul-16	16.40		BOXED UP/PERMISSION GIVEN BY RUVNL ON DATE 17.08.17 BUT PROBLEM IN DCCPP END)
KALISINDH	2	600.00	565	135.60	565	17-Oct-17	12.55		DESYNCHRONIZED DUE TO TECHNICAL PROBLEM/PERMISSION PENDING AT RUVNL. END LD MNO. OP/10/783/19.10.17)
STPS	4	250.00	229	55.00	229	19-Oct-17	20.35		BOXED UP
STPS	2	250.00	229	55.00	229	9-Oct-17	13.83	23-Oct-17	DESYNCHRONIZED DUE TO NON AVAILABILITY OF COAL STOCK
STPS	3	250.00	229	55.00	229	10-Sep-17	22.15	23-Oct-17	INSUFFICIENT COAL STOCK
Total(A) STATE SECTOR- PLANNED OUTAGE		1640.00	1472.00	353.40	1472.00				

CENTRAL SECTOR

DADRI	GT#2	130.19	22	5.30	22	9-Sep-17	23.45		EOH INSPECTION FOR 4000HRS
STPP(JHAJARI)	2	500.00	5	1.20	5	30-Sep-17	21.10		COAL SHORTAGE
UNCHAHAR	2	210.00	11	2.70	11	8-Oct-17	12.22		COAL SHORTAGE
Total(A) CENTRAL SECTOR- PLANNED OUTAGE		840.19	38.00	9.20	38.00				

(B) FORCE OUTAGE

STATE SECTOR

STATE SECTOR										
NAME OF STATION	UNIT OUT	INSTALLED CAPACITY	NET ALLOC./AVAIL. (MW)		OUTAGE		EXPECT./REVIVAL		REASON OF OUTAGE	
					DATE	TIME	DATE	TIME		
GIRAL	2	125.00	70	16.80	70	27-Jan-16	15.27	31-Oct-17	DESYNCHRONIZED DUE TO ATTEND TUBE LEAKAGE IN ASH COOLAR-4	
STPS	6	250.00	229	55.00	229	11-Sep-17	0.10	23-Oct-17	INSUFFICIENT COAL STOCK	
ADANI	1	600.00	600	144.00	600	23-Sep-17	5.45	23-Oct-17	INSUFFICIENT COAL STOCK	
KTPS	1	110.00	100	23.00	100	27-Sep-17	12.59	23-Oct-17	COAL SHORTAGE	
KTPS	2	110.00	100	23.00	100	27-Sep-17	18.30	23-Oct-17	COAL SHORTAGE	
RAJWEST	2	135.00	120	28.68	120	19-Oct-17	9.21	23-Oct-17	HEAVY BED MATERIAL LEAKAGE	
RAJWEST	7	135.00	120	28.68	120	20-Oct-17	23.00		HEAVY BED MATERIAL LEAKAGE	
RAMGARH	STG#2	50.00	40	9.60	40	21-Oct-17	15.54		DESYNCHRONIZED DUE TO TUBE LEAKAGE IN HRSG3 & DM CONSUMPTION	
DCCPP	HRSG#1	55.00	50	12.00	50	22-Oct-17	13.55		DESYNCHRONIZED DUE TO HEAVY FIRE OCCURRED AT NEAR PLANT SWITCHYARD	
DCCPP	GT#1	110.00	100	0.00	0	22-Oct-17	13.58	22-Oct-17	17.20	DESYNCHRONIZED DUE TO HEAVY FIRE OCCURRED AT NEAR PLANT SWITCHYARD
DCCPP	GT#1	110.00	100	0.00	0	22-Oct-17	18.16	22-Oct-17	20.08	DESYNCHRONIZED DUE TO BLEED VALVE NOT CLOSE
Total(B) STATE SECTOR-FORCED OUTAGE		1850.00	1629.00	340.76	1429.00					

CENTRAL SECTOR

AURIYA	GT#6	109.30	12	2.90	12	14-Oct-17	14.23		DUE TO SHOTAGE OF GAS/FUEL
AURIYA	GT#4	111.19	18	4.40	18	14-Oct-17	14.29		DUE TO SHOTAGE OF GAS/FUEL
AURIYA	GT#1	111.19	18	4.40	18	14-Oct-17	16.59		DUE TO SHOTAGE OF GAS/FUEL
DADRI	GT#4	130.19	22	5.30	22	17-Oct-17	18.40		AWAITED
Total(B) CENTRAL SECTOR- FORCED OUTAGE		461.87	70.00	17.00	70.00				
G.TOTAL			357.76	1499.00					

Note :- Loss of Generation shall not be considered in case unit is boxed up due to low demand (*), planned annual shut down (@) and COD is not declared (\$).