



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LTD
LOAD DESPATCH CENTER ,HEERAPURA JAIPUR.

Power Position 30-Oct-17	Point No.
Date-wise Energy Availability, Consumption, Peak Load & Average Frequency	1
Energy Availability / Generation from different Sources	2
System Parameters	3
Water Level of major Reservoirs	4
Position of Coal Stock at KTPS,STPS & CHHABRA	5
Outage of major Generating Units	6

1. Date-Wise Energy Availability, Consumption,OD(+)/UD(-), Peak Load, Avg. Frequency,Wind Gen. –OCT- 2017

Date	Anticipated Availability (In LU)		Consumption (In LU)		OD(+)/UD(-) (In LU)		Peak Load (In MW)		Average freq. (In Hz)	WIND (in LU)
	2017	2016	2017	2016	2017	2016	2017	2016	2017	2017
Oct-17										
1-Oct-17	2052.07	2034.37	1961.11	1990.31	24.09	22.57	9517	8968	50.00	144.93
2-Oct-17	1955.19	2042.94	2012.63	1890.88	39.62	8.14	9262	9016	49.97	162.66
3-Oct-17	1952.76	1977.65	1967.29	1867.72	40.89	1.81	9222	8471	49.93	90.25
4-Oct-17	1938.48	1989.21	1982.51	1796.01	24.27	-2.17	9115	8390	49.94	56.48
5-Oct-17	1959.56	1870.85	2039.94	1606.02	28.82	10.63	9061	7492	49.94	40.02
6-Oct-17	1914.81	1826.04	2025.64	1603.07	63.07	7.90	9252	7559	49.97	35.22
7-Oct-17	1895.69	1890.13	2028.58	1655.87	59.34	-2.91	8991	7844	49.95	40.98
8-Oct-17	1946.49	1895.40	2001.50	1672.43	21.65	20.49	9273	7812	49.98	25.02
9-Oct-17	1950.06	1841.42	2008.78	1620.28	48.23	7.92	9303	7566	49.98	52.10
10-Oct-17	1949.14	1794.15	2039.56	1591.97	61.02	30.32	9736	7572	49.97	55.92
11-Oct-17	2069.25	1743.44	2087.98	1612.83	14.62	28.33	9714	7336	49.96	49.30
12-Oct-17	2121.39	1677.86	2086.36	1663.90	9.99	31.90	10367	7852	49.96	35.37
13-Oct-17	1980.25	1685.28	2045.16	1685.45	48.44	37.61	9737	7521	49.94	35.18
14-Oct-17	1997.02	1598.00	2062.21	1697.62	17.68	38.99	10284	7823	49.97	101.33
15-Oct-17	2016.51	1714.81	2009.55	1753.49	16.98	23.71	10188	8156	49.99	80.83
16-Oct-17	1978.73	1877.15	2035.93	1727.21	-8.03	36.09	9800	7920	49.97	62.01
17-Oct-17	1910.15	1815.13	2045.05	1788.48	3.50	29.00	9965	8198	49.99	43.25
18-Oct-17	1997.65	1775.40	2008.80	1808.05	16.01	16.32	9754	8385	50.01	21.61
19-Oct-17	1988.87	1914.83	1857.71	1821.01	13.98	12.20	9453	8385	50.01	61.81
20-Oct-17	1943.79	1739.27	1796.29	1850.07	5.13	8.20	8964	9263	49.98	28.73
21-Oct-17	1869.32	1974.59	1881.70	1815.76	13.99	12.52	9113	8440	49.96	47.46
22-Oct-17	2016.69	1819.09	1837.33	1832.41	7.75	16.93	9138	8326	49.97	113.01
23-Oct-17	1928.80	1788.88	1927.21	1821.26	12.13	24.43	9956	8470	49.96	59.23
24-Oct-17	2018.40	1848.53	1975.36	1850.46	9.78	17.00	9374	8452	49.95	21.79
25-Oct-17	2021.52	1854.45	1998.44	1863.69	5.87	28.06	9811	8791	49.94	27.47
26-Oct-17	2060.76	1859.53	2011.35	1893.01	7.90	13.56	10098.00	8857	49.94	108.24
27-Oct-17	2057.48	1848.84	2029.63	1892.51	-7.36	25.31	9693.00	8759.00	49.92	46.54
28-Oct-17	1960.83	1852.75	2032.82	1861.74	-1.05	34.23	9976.00	8746.00	49.95	22.41
29-Oct-17	1986.13	1984.41	1960.97	1879.90	29.90	1.00	9534.00	8858.00	49.95	20.40
30-Oct-17	2001.00	1959.29								
31-Oct-17										
MAXIMUM OF THE MONTH	2121.39	2042.94	2087.98	1990.31	63.07	38.99	10367.00	9263.00	50.01	162.66
MIN OF THE MONTH	1869.32	1598.00	1796.29	1591.97	-8.03	-2.91	8964.00	7336.00	49.93	21.61
AVERAGE	1972.90	1845.91	1988.90	1755.45	23.95	18.64	9534.00	8160.32	49.97	59.68
MAX.CONSUMPTION TILL DATE DURING THE FY 2017-18 (L.U.)							2222.22	18-Aug-17		
MAX.PEAK LOAD TILL DATE DURING THE FY 2017-18 (MW)							10367	(07.00-07.15 Hrs.)	12-Oct-17	
MAX.CONSUMPTION DURING THE FY 2016-17 (L.U.)							2114.62	20-Sep-16		
MAX.PEAK LOAD DURING THE FY 2016-17 (MW)							10367	(07.00-07.15Hrs.)	12-Oct-17	
MAX.WIND TILL DATE DURING THE YEAR 2017-18 (L.U.)							482.76	4-Jul-17		
MAX.WIND DURING THE YEAR 2016-17 (L.U.)							448.85	4-Aug-17		

2. Anticipated Availability/Generation From Different Sources

(In LU)

S.No.	Sources Available to Rajasthan / Installed Capacity as on 30.09.2016 (In MW)	Prior assessment of Avail. For next Day	Prior assessment of Avail.	Actual Energy Received	Prior assessment of Avail. For next Day	Prior assessment of Avail.	Actual Energy Received	Prior assessment of Avail. For next Day	Prior assessment of Avail.	Actual Energy Received
1	KTPS (1240/1240)	258.00	224.00	205.55	272.00	258.00	258.33	272.00	272.00	267.38
2	STPS (1500/1500)	110.00	55.00	52.43	110.00	110.00	100.69	110.00	110.00	103.32
3	DHOLPUR GAS CCPP (330/330)	0.00	0.00	26.53	0.00	0.00	26.94	0.00	0.00	27.45
4	RAMGARH (273.5/273.5)	35.00	35.00	38.28	36.00	35.00	33.05	37.00	36.00	34.42
5	RAPP-A(200/200)	41.00	41.00	41.89	41.00	41.00	41.90	41.00	41.00	42.07
6	MAHI (140/140)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	CHAMBAL (RPS+JS) (135.5/271)	37.50	37.50	44.45	37.50	37.50	30.82	37.50	37.50	35.38
8	GIRAL LIGNITE (250/250)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9	CHHABRA TPS 1000/1000	219.00	219.00	316.82	219.00	219.00	282.74	219.00	219.00	209.03
10	ADANI (TPS) + KALISINDH (TPS) (1200+1200/1320+1200)	358.00	420.00	338.55	359.00	358.00	356.96	359.00	359.00	333.59
11	WIND FARM (3980.40/4119.15)	33.25	73.00	46.54	24.50	33.25	22.41	29.50	24.50	20.40
12	SOLAR POWER(737.70/1295.70)	0.00	0.00	0.00	0.00	0.00	1.71	0.00	0.00	1.71
13	CAPTIVE POWER PLANTS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
14	REGIONAL (INTRA STATE) O.A.(VLTPS)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
15	OPEN ACCESS	31.67	23.07	22.94	32.56	31.67	31.67	33.25	32.56	32.11
16	BIOMASS – (101.95/119.25)	6.00	5.00	6.11	6.00	6.00	6.34	7.00	6.00	6.84
17	BARSINGHSAR LTPS(250/250)	53.00	53.00	51.45	51.00	53.00	45.49	0.00	51.00	8.15
18	RAJWEST (1080/1080)	200.00	201.00	202.16	200.00	200.00	203.82	172.00	200.00	189.07
	TOTAL (A) : 1-18	1382.42	1386.57	1393.70	1388.56	1382.42	1442.87	1317.25	1388.56	1310.92
19	BBMB COMPLEX									
a)	BHAKRA(230.79/1516.3)	20.73	20.35	20.59	19.93	20.73	20.44	19.40	19.93	19.78
b)	DEHAR (198/ 990)	10.72	12.64	10.30	10.88	10.72	10.46	10.08	10.88	10.45
c)	PONG (231.66/396)	40.13	37.66	37.85	42.03	40.13	40.80	39.56	42.03	40.89
	TOTAL : a TO c	71.59	70.65	68.74	72.84	71.59	71.70	69.04	72.84	71.12
20	CENTRAL STATIONS									
d)	SINGRAULI (300/ 2000)	91.14	91.35	91.01	92.65	91.14	93.21	81.36	92.65	93.52
e)	RIHAND (310.24/3000)	123.61	122.48	122.72	127.41	123.61	127.77	121.40	127.41	135.75
f)	UNCHAHAR-I(20/420)	2.58	2.56	2.06	2.84	2.58	3.45	2.59	2.84	5.82
g)	UNCHAHAR-II& III(61/630)	41.30	40.57	32.05	43.60	41.30	44.35	41.02	43.60	49.50
h)	INDIRA GANDHI STPS(JHAJHAR) 0.00/1500)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
i)	NCTPS DADRI St-II (43.22/980) + DADRI-TH	14.00	14.99	13.19	16.80	14.00	14.05	14.73	16.80	22.51
j)	DADRI GAS (77/830)	3.31	3.35	3.29	3.56	3.31	3.82	3.59	3.56	3.72
k)	ANTA (83.07/419)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
l)	AURAIYA (61.03/663)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
m)	NAPP (44/440)	9.60	9.62	9.62	9.60	9.60	9.60	10.54	9.60	9.60
n)	RAPP-B (125/440)	33.93	33.93	33.93	34.01	33.93	33.93	33.93	34.01	34.01
o)	RAPP-C (88/440)	20.58	20.58	20.58	20.58	20.58	20.58	20.58	20.58	20.58
p)	SALAL (20.36/690)	1.08	1.09	1.06	1.01	1.08	1.03	0.99	1.01	0.97
q)	URI (70.37/720)	2.72	2.66	2.82	2.85	2.72	2.71	2.68	2.85	2.79
r)	TANAKPUR (10.86/94)	1.32	1.45	1.39	1.35	1.32	1.38	1.40	1.35	1.40
s)	CHAMERA –I (105.84/540)	4.51	5.10	5.10	4.51	4.51	4.51	4.51	4.51	4.51
t)	CHAMERA-II (29.01/300)	1.93	2.13	1.98	1.93	1.93	1.89	1.93	1.93	1.91
u)	CHAMERA-III (25.21/231)	1.45	1.45	1.45	1.45	1.45	1.45	1.41	1.45	1.45
v)	DHAULIGANGA (27/280)	2.06	2.23	2.16	1.96	2.06	2.06	1.96	1.96	1.81
w)	DULHASTI (42.42/390)	5.98	5.44	5.44	5.77	5.98	5.98	5.98	5.77	5.77
x)	SEWA (13/120)	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39	0.39
y)	NJPC (112.00/1500)+RAMPUR(31.808/412.02)	11.54	11.73	10.78	11.54	11.54	11.68	11.54	11.54	11.54
z)	TEHRI (75/1000)	4.99	4.99	4.99	4.99	4.99	4.99	4.99	4.99	4.76
aa)	KOTESHWR (33.44/400) + PARBATI3 (56.73/520)	4.29	4.29	7.23	4.29	4.29	7.24	4.29	4.29	6.97
ab)	TALA	1.40	1.45	1.45	1.29	1.40	1.40	1.29	1.29	1.29
ac)	MUNDRA UMPP (380/4000)	77.33	60.00	60.00	78.96	77.33	77.33	78.96	78.96	80.97
ad)	SASAN (372/3960)	88.44	88.20	88.20	88.44	88.44	88.44	88.44	88.44	88.44
ae)	FRKKA+KHLGN+TLCHR (70.18/3940)	29.42	30.47	29.56	29.34	29.42	29.15	25.63	29.34	28.60
af)	URS POWER(DADRI TH-I)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	TOTAL SCHEDULED(a TO af)	650.48	633.13	621.20	663.94	650.48	664.07	635.17	663.94	689.70
	LOSSES	-24.33	-23.42	-25.73	-24.87	-24.33	-27.48	-28.35	-24.87	-28.49
	NET SCHEDULED	626.15	609.71	595.47	639.07	626.15	636.60	606.82	639.07	661.21
21	BILATERAL (REG.) EXCL. BANKING	6.40	6.40	6.40	6.28	6.40	6.40	6.10	6.28	6.28
22	BANKING	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
23	BILATERAL(INTER-REG.) EXCLUDING (ISOA & BANKING)	112.07	90.32	101.19	114.70	89.12	114.22	114.26	90.96	114.70
24	INTER STATE OPEN ACCESS (BILATERAL+IEX)	-31.67	-23.07	-22.94	-32.56	-31.67	-31.67	-33.25	-32.56	-32.11
25	INDIAN ENERGY EXCHANGE	-134.54	-36.83	-36.83	-129.92	-134.54	-134.54	-10.19	-129.92	-129.92
	TOTAL(B): (19 TO 25)	578.40	670.91	643.29	597.57	578.40	591.00	683.75	597.57	620.15
	TOTAL GENERATION (A + B) : 1 TO 25			2036.99			2033.87			1931.07
	OVER DRAWAL (+)/UNDER DRAWAL (-)			-7.36			-1.05			29.90
	GRAND TOTAL	1960.83	2057.48	2029.63	1986.13	1960.83	2032.82	2001.00	1986.13	1960.97
	LAST YEAR	1852.75	1848.84	1892.52	1984.41	1852.75	1859.70	1959.29	1984.41	1879.92

3. SYSTEM PARAMETERS AS ON 29-Oct-17

MAXIMUM DRAWL ON 29-Oct-17	9534 MW at 06.15-06.30 Hrs 49.96 Hz
MINIMUM DRAWL ON 29-Oct-17	6851 MW at 21.45-22.00 Hrs 50.05 Hz
Max U/D of the day	178 MW at 02.15-02.30 HRS. 49.96 Hz
Max. O/D below 49.7 Hz	MW at
No. of Blocks Freq. < 49.7 Hz	0
No. of Violation Blocks Freq. < 49.7 Hz	0
No. of Blocks in which Freq. >= 49.7 & <49.9 Hz	20
NO. OF VIOLATION (OD BLOCKS) IN WHICH FREQ. >= 49.7 & <49.9 Hz	15
No. of Blocks in which Freq. >= 49.9 & <50.00 Hz	54
NO. OF BLOCKS(OD ABOVE 250 MW) IN WHICH FREQ. >= 49.9 & <50.00 Hz	19
NO. OF BLOCKS(UD ABOVE 250 MW) IN WHICH FREQ. >= 49.9 & <50.00 Hz	0
No. of Blocks in which Freq. >= 50.00 & <50.05 Hz	20
NO. OF BLOCKS(OD ABOVE 250 MW) IN WHICH FREQ. >= 50.00 & <50.05 Hz	4
NO. OF BLOCKS(UD ABOVE 250 MW) IN WHICH FREQ. >= 50.00 & <50.05 Hz	0
No. of Blocks in which Freq. >= 50.05 & <50.10 Hz	2
NO. OF UD BLOCKS IN WHICH FREQ. >= 50.05 & <50.10 Hz	0
No. of Blocks in which Freq. >= 50.10	0
NO. OF VIOLATION(UD BLOCKS) IN WHICH FREQ. >= 50.10	0
AVERAGE FREQ. FOR THE DAY 29-Oct-17	49.95 Hz
Max O/D of the day	528 MW at 20.00-20.15 Hrs 50.01 Hz
Frequency Profile	% of Time
LESS THAN 49.7 HZ	0.00
LESS THAN 49.90 HZ	22.03
OPERATING RANGE (49.90 HZ TO 50.05 HZ)	69.68
ABOVE 50.05 HZ	8.29
No. of 220 KV GSS advised to switch off 33 KV Urban Feeders	0
No. of 220 KV GSS advised to switch off 33 KV Rural Feeders	87
No. of 132 KV Feeders Disconnected	0

4. WATER LEVEL OF MAJOR RESERVOIR

Name of reservoir	Capacity level		Actual Level as on		Discharge (cusecs)	Inflow (cusecs)
	Max.	Min.	30-Oct-17	30-Oct-16		
Gandhi Sagar (Ft.)	1312	1250	1300.51	1311.72	1759	389
R.P.Sagar (Ft.)	1157.5	1128	1139.63	1153.33	7536	1296
Jawahar Sagar (Ft.)	980	970.4	975.50	978.30	8194	NA
Kota Barrage(Ft.)	854.5	852.3	854.50	854.10		
RMC					6150	
LMC					1500	
Bhakra(Ft.)	1690	1462	NA	1636.80	NA	NA
Dehar (Ft.)	2941	2900	NA	2918.83	NA	NA
Pong(Ft.)	1421	1260	NA	1361.17	NA	NA
Mahi-I (Mts.)	281.5	259	281.45	281.50	NA	NIL
Mahi-II (Mts.)	220.5	217	216.90	217.00	NA	NIL

5. POSITION OF COAL STOCK (In MT)

Date	Name of Station	Stock at 00.00 hrs. (MT)	Coal stock sufficient for No. of days
30/Oct/17	KTPS	71363	3.5 days
30/Oct/17	STPS	119532	5 days
30/Oct/17	CHHABRA	6017	1 days
	OUTAGE	38272	3 days

6. GENERATING UNIT OUTAGE REPORT UP TO 8.00 HRS OF DT.

30/Oct/17

(A) PLANNED OUTAGE

NAME OF STATION	UNIT OUT	INSTALLED CAPACITY	NET ALLOC/ AVAIL. (MW)			OUTAGE		EXPECT./REVIVAL		REASON OF OUTAGE
						DATE	TIME	DATE	TIME	
STATE SECTOR										
GIRAL	1	125.00	70	16.80	70	11-Jul-14	8.20			BED MATERIAL LEAKAGE (SD W.E.F.15.07.14)
DCCPP	HRSG#2*	55.00	50	12.00	50	13-Jul-16	16.35			BOXED UP/PERMISSION GIVEN BY RVNLI ON DATE 17.08.17 BUT PROBLEM IN DCCPP END)
DCCPP	GT#2*	110.00	100	24.00	100	13-Jul-16	16.40			BOXED UP/PERMISSION GIVEN BY RVNLI ON DATE 17.08.17 BUT PROBLEM IN DCCPP END)
STPS	4	250.00	229	55.00	229	19-Oct-17	20.35			BOXED UP
STPS	2	250.00	229	55.00	229	9-Oct-17	13.03			DESYNCHRONIZED DUE TO NON AVAILABILITY OF COAL STOCK
STPS	3	250.00	229	55.00	229	10-Sep-17	22.15			INSUFFICIENT COAL STOCK
STPS	6	250.00	229	55.00	229	11-Sep-17	0.10			INSUFFICIENT COAL STOCK (permission pending)
Total(A) STATE SECTOR- PLANNED OUTAGE										
		1290.00	1136.00	272.80	1136.00					

CENTRAL SECTOR

DADRI	GT#2	130.19	22	5.30	22	9-Sep-17	23.45			EOH INSPECTION FOR 4000HRS
ISTPP(JHAIJAR)	2	500.00	5	1.20	5	30-Sep-17	21.10			COAL SHORTAGE
ANTA GPS	2	88.71	20	7.50	20	24-Oct-17	21.49			RESERVE SHUTDOWN
ANTA GPS	3	88.71	16	3.90	16	25-Oct-17	22.21			RESERVE SHUTDOWN
DADRI GPS	6	154.00	22	5.30	22	25-Oct-17	22.22			RESERVE SHUTDOWN
ANTA GPS	4	153.00	16	3.90	16	25-Oct-17	22.26			RESERVE SHUTDOWN
DADRI GPS	3	130.00	22	5.30	22	25-Oct-17	22.30			RESERVE SHUTDOWN
AURAIYA GPS	4	111.00	18	4.40	18	25-Oct-17	22.43			RESERVE SHUTDOWN
ANTA GPS	1	88.00	16	3.90	16	25-Oct-17	22.57			RESERVE SHUTDOWN
DADRI GPS	1	130.00	22	5.30	22	25-Oct-17	23.00			RESERVE SHUTDOWN
AURAIYA GPS	6	109.00	18	4.40	18	25-Oct-17	23.09			RESERVE SHUTDOWN
AURAIYA GPS	3	111.00	18	4.40	18	25-Oct-17	23.12			RESERVE SHUTDOWN
Total(B) CENTRAL SECTOR- PLANNED OUTAGE										
		1793.61	215.00	54.80	215.00					

(B) FORCE OUTAGE

STATE SECTOR											
NAME OF STATION	UNIT OUT	INSTALLED CAPACITY	NET ALLOC/ AVAIL. (MW)			DATE	TIME				REASON OF OUTAGE
STATE SECTOR											
GIRAL	2	125.00	70	16.80	70	27-Jan-16	15.27		31-Oct-17		DESYNCHRONIZED DUE TO ATTEND TUBE LEAKAGE IN ASH COOLAR-I
ADANI	1	600.00	600	144.00	600	23-Sep-17	5.45				INSUFFICIENT COAL STOCK
RAJWEST	7	135.00	120	28.68	120	20-Oct-17	23.00				HEAVY BED MATERIAL LEAKAGE
RAMGARH	GT#1	35.50	29	0.00	0	24-Oct-17	7.00		29-Oct-17	22.34	FORCED SD DUE TO LOW GAS AVAILABILITY
RAMGARH	STG#1	37.50	10	3.00	10	28-Oct-17	4.38				LOAD REDUCE ON GT#2
RAMGARH	GT#2	37.50	29	7.00	29	28-Oct-17	4.50				DESYNCHRONIZED DUE TO GAS RESTRICTION BY GAIL INDIA AND UNDER SD FOR TWO DAYS FOR REVOLVOR CLEANING BY GAIL
KALISINDHI	1	600.00	565	0.00	0	29-Oct-17	8.21		29-Oct-17	14.58	ELECTRICAL FAULT
BARSINGSAR	2	125.00	110	26.40	110	29-Oct-17	10.05				LIGNITE FEEDING SYSTEM PROBLEM
BARSINGSAR	1	125.00	110	26.40	110	29-Oct-17	11.11				LIGNITE FEEDING SYSTEM PROBLEM
RAJWEST	1	135.00	120	28.68	120	29-Oct-17	11.45				BAD MATERIAL LEAKAGE
RAMGARH	STG#2	50.00	40	0.00	0	29-Oct-17	14.25		29-Oct-17	17.24	HEAVY VOLTAGE JERK
Total(B) STATE SECTOR-FORCED OUTAGE											
		2065.50	1803.00	280.96	1169.00						
CENTRAL SECTOR											
DADRI	GT#4	130.19	22	5.30	22	17-Oct-17	18.40				AWAITED
SINGRAULI	3	200.00	34	8.20	34	29-Oct-17	20.21				EXCITATION PROBLEM
Total(B) CENTRAL SECTOR- FORCED OUTAGE											
		330.19	56.00	13.50	56.00						
G.TOTAL			294.46	1225.00							

Note :- Loss of Generation shall not be considered in case unit is boxed up due to low demand (*), planned annual shut down (@) and COD is not declared (\$).