

**G-Schedule for Maintenance of Power Transformers, Bay Equipments and Bus-Bar at 132 KV GSS RVPN Udaipurwati for the Year 2017-18 (01 Frq.)**

S.No	Particulars	Frequency	Unit	BSR Rates	Qty.	Amount
1.	<p><b>(A)</b> Maintenance of Power Transformer for the following types of Power Transformer (All spares, Lubricating material and only special T&amp;P shall be provided by RVPN Cleaning material and general T&amp;P shall be arrange by the contractor.)</p> <p>a) Cleaning of porcelain of bushing.  b) Checking of tightness of clamps &amp; connectors.  c) Cleaning of Buchlolz &amp; oil surge relays.  d) Cleaning of glasses of all oil level indicators.  e) Cleaning of marshalling box, cooler control cubicle, thermometer, etc., as provided.  f) Assistance to RVPN in attending to oil leakage fromTr. Body &amp; Bushings.  g) Checking of oil level in oil filled bushing.  h) Checking of Dry col air drying system.  i) Assistance to RVPN in measurement of IR values.  j) Assistance to RVPN in measurement of earth resistance.  k) Assistance to RVPN in testing of PRD.  l) Assistance to RVPN in checking of tripping circuit of Buchloz &amp; WDG, oil temperature controls and protection scheme.  m) Checking of OLTC gear operations.  n) Assistance to RVPN in checking of auto circuit of cooling bank.  o) Assistance to RVPN in Taking of oil samples for testing.  p) Assistance to RVPN in carrying out other special measurements as may be required  q) Providing of other related work assistance as may be required by work in charges.</p> <p>132/33 kV, 2X 20/25MVA Transformer ( 5Nos. workmen)  33/11 kV, 5 MVA &amp; 3.15 MVA Tr &amp; .33/0.4 KV,100 KVA Station Tr.  ( 3 Nos. workman )</p>	01	No. No	1220 774	2 3	2440 2322
2.	<p><b>(B)</b> Maintenance work of following bay equipments such as Circuit-Breakers, Current Transformers, Lightening Arrestors, Isolators, CVTs, PLCC Equipment and corresponding control and Relay Panels,(All spares, Lubricating material and only special T&amp;P shall be provided by RVPN Cleaning material and general T&amp;P shall be arranged by the contractor.)</p> <p>a) Checking of lightness of clamps &amp; connections..  b) Cleaning of all Insulators.  c) Assistance to RVPN in attending oil leakage, if any.  d) Cleaning of all Junction Boxes and secondary terminal boxes.  e) Assistance to RVPN in checking of operation of CB through relays &amp; verifying various logic and control circuit &amp;annunciation circuits.  f) Assistance to RVPN in measurement of CB operation timings.  G)Checking of Isolator operation and its alignments.  h) Checking of gas pressures like SF6, N2 in cikt. breakers/CTs, etc.  i) Assistance to RVPN in measurement of IR values of LAs, CTs, CVTs.  j) Lubrication of defined parts of all equipment at all requiredpoints.  k) Washing the equipment, in case oil stains are present, then washing is to be done with use of detergent.  l) Cleaning of C &amp; R panel from inside.  m)Tightening of clamps &amp; connectors and spacers on overhead bus conductors and gantries(at maximum height of 25 meters using safety belts)  n) Providing other related work assistance as may be required by Incharge.</p> <p>132 KV Bay (1 No. supervisor+6 Nos. workmen)  33 KV Bay (1 No. supervisor+5 Nos. workmen)  11 KV Bay (1 No. supervisor+5 Nos. workmen)</p>	01	No. No No.	1892 1666 1666	3 11 10	5676 18326 16660


3.	<p>( C ) Providing work assistance as given below in Maintenance work of Bus Bars of Various Voltage levels. (All spares,lubricating material and only special T&amp;P shall be provided by RVPN Cleaning material and general T&amp;P shall be arranged by the contractor.)</p> <p>a) Tightening of clamps &amp; connectors on overhead bus conductors and gantiers (at a maximum height of 25 meters using safety belts.) Also tightening of clamps / connectors of all bus side associated equipment.</p> <p>b) Replacement of worn out clamp &amp; connectors of bus during work under item No. (a)</p> <p>c) Cleaning of all insulators of suspension and tension string of bus bars and insulators of bus isolators, Bus CVT,s /PT's</p> <p>d) checking of operations of Bus isolators and their alignment including motorized operation.</p> <p>e) Maintenance of operating mechanism &amp; switches, etc.,</p> <p>f) Lubrication of all moving parts.</p> <p>g) Providing of other related work assistance as may be required by Work-Incharge</p> <p>132 KV Bus Section (1No. supervisor+4 Nos.workmen)  33 KV Bus Section (1No. supervisor+4 Nos.workmen)  11 kV Bus Section (1No. supervisor+4 Nos.workmen)</p>	01	No. No. No.	1446 1351 1351	4 4 4	5784 5404 5404
<b>Total (A+B+C) in Rs.</b> <b>Add Premium @ 60% on amount Rs. 62016</b>						<b>62016.00</b> <b>37209.60</b>
<b>GRAND TOTAL AMOUNT IN Rs.</b>						<b>99225.60</b>

**Rs. 99225.60**

**Say Rs. 99226.00**

**( Rupees Ninety nine thousands two hundred and twenty six only )**

  
*Assistant Engineer*  
132 KV G.S.S. R.V.P.N.  
UDIPURWATI



# RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

( An ISO 9001:2008 Certified Company)

Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302 005

[ Corporate Identity Number (CIN): U40109RJ2000SGC016485 ]

## OFFICE OF THE ASSISTANT ENGINEER 132 KV GSS UDAIPURWATI

Telephone: +91-1594-234265; +91-9413393993; e-mail: [aen.132.udaipurwati@rvpn.co.in](mailto:aen.132.udaipurwati@rvpn.co.in); Website: <https://mail.rajasthan.gov.in>

No. RVPN / AEn / 132 KV GSS / UPW /F. Estt. / D- 7 DATE 12.04.2017

All Registered Contractors

Under Ajmer Zone, Ajmer

**Sub:** To convey consent for execution of "Maintenance work of Power Transformer Bay Equipments and Bus-Bar" at 132 KV GSS RVPN Udaipurwati.

Dear Sir,

With reference to subject cited above, it is intimated that Maintenance work of Power Transformer Bay Equipments and Bus-Bar is to be executed at 132 KV GSS RVPN udaipurwati for FY 2017-18(one freq.) on CLRC basis as per details mentioned in the G-Schedule.

Therefore you are requested to convey your consent for execution of above work on CLRC during above mentioned period at 132 KV GSS RVPN udaipurwati at the earliest possible. So that further necessary action may be initiated.

Thanking you sir,

Encl: G-Schedule

Yours faithfully

  
*Assistant Engineer*  
132 KV G.S.S. R.V.P.N.  
UDIPURWATI