



**RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED**  
(CORPORATE IDENTITY NO. L40109RJ2000SGC016485)

REGD. OFFICE: VIDYUT BHAWAN, JYOTI NAGAR, JAIPUR.

**OFFICE OF THE ASSISTANT ENGINEER (132 KV GSS) SRIMADHOPUR**

Telephone No. 1575-250079; e-mail Id: aen.132.srimadhopur@rvpn.co.in Website:  
www.rvpn.co.in

NO. RVPN/AEN/GSS/SMPR/STR. PAINT./TECH - CLRC/ F. /D. 206

Dated: 29.11.2017

To,

**All Registered Contractors,  
Under TCC, RVPN**


Sub: Consent to carry out the work of Painting of structures and equipments at 132 kV GSS, Srimadhopur on CLRC contract basis under SE (T&C), RVPN, Sikar.

Dear Sir (s),

With reference to above cited subject, it is to intimate to all registered contractors that work of cleaning works of work of Painting of structures and equipments at 132 kV GSS, Srimadhopur on CLRC contract basis under SE (T&C), RVPN, Sikar is to be carried out through any of registered contractor.


Therefore, the consent from interested contractors is invited upto **11.12.2017** at **2:00P.M.**, so that process of painting works may be initiated.

Encl- "G" Schedule

  
Assistant Engineer,  
132 KV GSS, RVPN,  
Srimadhopur - Sikar

CC: to the followings:

- 1) Superintending Engineer (T&C), RVPN, Sikar, it is intimated that earlier it has been issued twice, but no response have been received.
- 2) Executive Engineer (220 kV GSS), RVPN, Reengus.
- 3) The Feeder Manager (T&C), RVPN, Sikar, with the request to please arrange to place on web portal of RVPN's associated link [www.energy.rajasthan.gov.in/rvpnl](http://www.energy.rajasthan.gov.in/rvpnl), so that same may be processed.

  
Assistant Engineer,  
132 kV GSS, RVPN,  
Srimadhopur - Sikar



**RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED**  
(CORPORATE IDENTITY NO. L40109RJ20009GCO16485)  
REGD. OFFICE: VIDYUT BHAWAN, JYOTI NAGAR, JAIPUR.  
**OFFICE OF THE ASSISTANT ENGINEER (132 KV GSS) SRIMADHOPUR**  
Telephone No. 1575-250079; e-mail Id: aen.132.srimadhopur@rvpn.co.in  
Website: [www.rvpn.co.in](http://www.rvpn.co.in)

CODE NO.	DESCRIPTION	UNIT	QUANTITY	RATE	AMOUNT
2.0	PAINTING OF STRUCTURE & EQUIPMENTS			(Rupees)	(Rupees)
2.2	PAINTING OF OLD PAINTED STEEL STRUCTURES:-				
	Aluminium painting of old painted steel structure at the GSS including supply of paint and painting brush, emery paper, cloth & solvents etc. The surface shall be first cleaned with wire brush/emery paper and thereafter wiped with cloth to remove rust and dust or any other deposits on erected M.S. steel structures. Two coat of aluminum paint shall be applied. Each subsequent coat shall be applied only after the previous coat has dried up. The paints used shall be from any of the following recognized manufacturers, namely Asian/ Nerolac/ Berger/Johnson Nicholson	SqM	3245.76	24.00	77898.24
	<b>Add 60% above on BSR Price</b>				46738.94
	<b>TOTAL (A)</b>				<b>124637.18</b>
2.3	PAINTING OF TRANSFORMERS & EQUIPMENTS:-				
	Enamel painting on power transformer and other equipments including supply of paints and spray painting set, emery paper, cloth & solvents etc. The surface shall be cleaned thoroughly with soda/ caustic solution to clean oily surface and thereafter washing with water. Thereafter two coats of smoke gray synthetic enamel paint shall be applied by spray method. Each subsequent coat shall be applied only after the previous coat has dried up. The paints used shall be from any of the following recognized manufacturers, namely Asian/ Nerolac/Berger/Johnson Nicholson. In case of surface area of radiators, those fins will only be considered which are actually feasible and approachable for painting by spray or by brush.	SqM	980	25.00	24500
	<b>Add 60% above on BSR Price</b>				14700.00
	<b>TOTAL (B)</b>				<b>39200.00</b>
	<b>G. TOTAL (A+B)</b>				<b>163837.18</b>

*awte*  
**JUNIOR ENGINEER**  
132 KV GSS RVPN  
Shrimadhapur

*13/11*  
**ASSISTANT ENGINEER**  
132 KV GSS, RVPNL  
SHRIMADHOPUR