



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

(Corporate Identity Number (CIN):U40109RJ2000SGC016485)

Regd. Office :VidyutBhawan, Jyoti Nagar, Jaipur-302005

Office of the Assistant Engineer (132 KV GSS), Saradhana

E-MAIL:- a.en.132.saradhana@rvpn.co.in; Website:- www.energy.rajasthan.gov.in

(An ISO 9001-2008 Certified Company)

No./RVPN/AEN/132 KV GSS/ SRD/F. works /CLRC/2017-18/ D. 183 Dt. 30.08.2017

To

All Registered Contractors
RVPNL

Subject:- Consent to carry out the painting work of structure and transformers & Equipments at 132 KV GSS, RVPN, Saradhana for the FY-2017-18.

Dear Sir,

Consent from all registered contractors of RVPN have been invited to carry out the painting work of structure and transformers & Equipments at 132 KV GSS, RVPN, Saradhana for the FY-2017-18 on terms and conditions of CLRC. The work shall be completed before 31.10.2017.

The consent by interested contractors shall be received on dt. 11.09.2017 up to 2.00 PM and opened at 2.30 PM.

Copy of valid registration and signed copy of G-Schedule should also be submitted with the consent letter.

Encl.:- Copy of G - Schedule

Assistant Engineer (132 KV GSS)
RVPNL, Saradhana

Copy submitted to the following for information & necessary action please :-

- 1 The Superintending Engineer (T&C), RVPN, Ajmer for uploading on the portal.
- 2 The Executive Engineer (220 KV GSS), RVPN, Jethana.

Assistant Engineer (132 KV GSS)
RVPNL, Saradhana


RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LTD.

OFFICE OF THE ASSISTANT ENGINEER (132 KV GSS), SARADHANA

'G' SCHEDULE**NAME OF WORK: - Painting of Old painted structure & Transformers at 132 KV GSS Saradhana****Ref.:- 1.No. RVPN /SE/SSPC /TK/TN-2957/CLRC /D.501 Dated 24-05-2013**

Sr. No.	BSR item No.	Item of Supplies	Unit	QTY	Rate as per BSR	Amount
1	2.2	Painting of Old Painted Steel Structure	Sq. Mtr	3717.284	24	89214.816
		Aluminium painting of unpainted steel structures of the GSS including paint, painting brush emery paper, cloth and solvents etc. The surface shall be first cleaned with the wire brush/emery paper and thereafter wiped with cloth to remove the rust and dust or any other deposits on erected MS steel structures & beams. One coat of red oxide paint shall be applied after carrying out cleaning and allowing to dry. Thereafter two coats of aluminium paint shall be applied. Each subsequent coat shall be applied only after the previous coat has dried up. The paints used shall be only of the following recognized manufactures namely Asain/Nerolac /Berger / Johnson & Nicholason				
2	2.3	PAINTING OF TRANSFORMERS & EQUIPMENTS	Sq. Mtr	420.506	25	10512.650
		Enamel painting on One.power transformers and other equipments including supply of paint and spray painting set, emery paper, cloth and solvents, etc 'at GSS by cleaning surface thoroughly with soda/caustic solution to clean oily surface and thereafter washing with water. Thereafter, two coats of smoke, gray synthetic enamel paint shall be applied by spray method. Each subsequent coat shall be applied after the previous coat has fully dried up. The paints used shall be from any of the following recognised manufacturers, namely Asian- Nerolac /Berger/Johnson Nocholsan . In case of surface area of radiators, those fins will only be considered which are actually leasable and approachable for painting by spray or by brush.				
		Total				99727.466
		Rates above 60% of BSR				59836.480
		Grand total				159563.946
		Grand total(Round Off)				159564.00

(Say Rupees One Lakh Fifty Nine thousand Five hundred Sixty Four only)


Assistant Engineer (132 KV GSS)
RRVPL, Saradhana