



RAJASTHAN RAJYA VIDHYUT PRASARAN NIGAM LTD.

(An ISO 9001: 2008 Certified Company)

(Registered Office Vidhyut Bhawan, Jan Path, Jyoti Nagar, Jaipur)

OFFICE OF THE EXECUTIVE ENGINEER

(220KV GSS) RVPNL, NIMBAHERA. Ph. 01477-220084

E-mail: xen.220.nimbahera@rvpn.co.in

Website: www.rvpn.co.in

No. RVPN / XEN /220KV/ Tech /F (2016-17) /D 733 Date 03.01.2017

All registered contractors (class E I & E II/G I & G II)
(T&C) Ajmer zone.

Subject:- Consent for structure Painting work at 132 KV GSS Mangalwar.

Reference:- CLRC order No. RVPNL/SE/TK/A.-1/TN-2975/CLRC/D.303 dt.
18.05.2015 and CLRC Extension order No. RVPN/SE/SSPC/TK/A.1/TN-
2975/CLRC/D.1151 dt. 11.09.2015

In reference to above, all registered contractors of T&C wing Ajmer Zone are requested to submit their consent for the following work within ten days from date of issue of this letter along with copy of registration certificate as registered contractor in T&C wing Ajmer Zone and copy of tax clearance certificate to this office within stipulated time period.

S.no.	Name of Work	Tentative Amount	Remarks
1.	Structure Painting work at 132 KV GSS Mangalwar.	Rs. 55834.00	

The G- Schedule of work is enclosed herewith for your reference with request to submit your consent before scheduled date.

(P. C. Padlia)
Executive Engineer
220KVGSS, RVPNL
Nimbahera

RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED
DIO ASSISTANT ENGINEER, 132 KV GSS MANGALWAR

G-SCHEDULE

Supply of paint & painting of already erected structures at 132 KV GSS Mangalwar, District Chittorgarh(Raj.)

Sr. No.	Work to be Executed	Quantity(Sq. Mtrs)	Rate per Sq.Met(Rs.)	Amount(Rs.)
1	Aluminium Paining of old Steel structure at the GSS Incuding paint and Painting brush,emery paper,cloth & solvant etc.The Surface shall be first rubbed free of dust or any other deposit on erected M.S. Steel structure.One coat of red oxide paint shall be applied after carrying out cleaning and allowed to dry already erected steel structures columns and beams.Thereafter two coats Aluminium paint shall be applied. Each subsequent coat shall be applied only after previous coat has dried.The Paint shall be out of the following recognized manufacturer namely-Asian/Nerolac/Berger/JohnsonNikolson/Dulux	1454	24	34896
	Total			34896
	Add 60% above on the BSR Rate			20938
	Grand Total			55834

(Rupees Fifty five thousand eight hundred thirty four only)

Signature of contractor

J. Meena
JFM

Aakash
Assistant Engineer
132KV GSS Mangalwar

c/s

पु. २
अधिशायी अभियन्ता
220 के.वी. जी.एस.एस.
रा.रा.वि.प्र.नि. निम्बाहेडा