



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

[Corporate Identity Number (CIN): L40109RJ2000SGC016485]

Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302 005

OFFICE OF THE ASSISTANT ENGINEER 132 KV GSS UDAIPURWATI

Telephone: +91-1594-234265; +91-9413393993; e-mail: aen.132.udaipurwati@rvpn.co.in; Website: <https://mail.rajasthan.gov.in>

No. RVPN / AEn / 132 KV GSS / UPW /F. Estt. / D- 111

DATE 22.08.2017

All Registered Contractor

Under Ajmer Zone,Ajmer

Sub: To convey consent for execution of “ painting of Structures” work at 132 KV GSS RVPN Udaipurwati.

Dear Sir,

With reference to subject cited above, it is intimated that “painting of structure” work is to be executed at 132 KV GSS RVPN Udaipurwati on CLRC basis as per details mentioned in the G-Schedule.

Therefore you are requested to convey your consent for execution of Above work on CLRC at 132 KV GSS Udaipurwati within 10 days positively. So That further necessary action may be initiated.

Thanking you sir,

Yours faithfully


Assistant Engineer
132 KV G.S.S. R.V.P.N.
UDIPURWATI

Encl: G-Schedule

Copy submitted to the following for uploaging the same on “RVPN” and “SPPP” portal

1. The TA to SE(T&C) RVPN, Babai
2. The Feeder Manager RVPN, Sikar


Assistant Engineer
132 KV G.S.S. R.V.P.N.
UDIPURWATI

G-Schedule for Alluminium painting of old structures at 132KV GSS RVPN UDAIPURWATI

S.No.	Description of work	Unit	App. Qty.	BSR Rate	Amount
1.	<u>PAINING OF OLD PAINTED STEEL STRUCTURE</u> Aluminium painting of old painted steel structures at the 132 KV GSS Udaipurwati including supply of paint and painting brush,emeryPaper,cloth & solvents, etc. The surface shall be first Cleaned with wire brush/emery paper and thereafter wipe with cloth to remove rust and dust or any other deposits On erected M.S steel structures. Two coats of aluminium paint shall be applied. Each subsequent coat shall be applied only after the previous coat has dried up. The paints used shall be from any of the following recognized Manufactures, namely Asian/Nerolac/Berger/Jenson Nicholson.	Sqr. Meter	3600	24	86400.00
2.	<u>PAINING OF TRANSFORMERS & EQUIPMENTS</u> Enamel painting on power transformers and other equipments including supply of paint and spray painting set, Emery paper, cloth & solvents,etc. at GSS by cleaning surface thoroughly with soda/castic solution to clean oily surface and there after,two coats of smoke gray synthetic enamel paint shall be applied by spray method. Each subsequent coat shall be applied after the previous coat has fully dried up. The paints used shall be from any of the following recognized Manufactures, namely Asian/ Nerolac/ Berger/Jenson Nicholson. In case of surface area of Radiators, those fins will only be considered which are actually feasible and approachable for painting by spray Or by brush.	Sqr. Meter	700	25	17500.00
	TOTAL				103900.00
	Add 60 % premium on amount 1,03,900.00				62340.00
	Grand Total				166240.00

Rs. 1,66,240.00 (One lac sixty six thousand two hundred forty only)


Assistant Engineer
 132 KV G.S.S. R.V.P.N.
 UDIPURWATI