



**RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED**

(An ISO 9001 : 2008 Certified Company)

[ Corporate Identity Number (CIN) : U40109RJ2000SGC016485]

**OFFICE OF THE EXECUTIVE ENGINEER, 220 KV GSS, MANSAROVAR, JAIPUR**

Regd. Office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur-302017

Phone: 0141-2393802, email: xen.220.mansorovar@rvpn.co.in

**NO. RVPN/ XEN/220 KV GSS/ MNSR/TECH/F./D 504 Dated 03.03.2017**

To,

All Enlisted Contractors

T&C Zone Jaipur.

Sub.- NIT Regarding Aluminum paint work at switchyard & structure at 220 KV  
GSS, Mansorovar, RVPN, Jaipur

Dear Sir,

In reference to above cited subject this is informed all enlisted contractors that painting of steel structures and various equipments at 220 KV GSS, Mansorovar with material to be executed as per CLRC rate at 220 KV GSS Mansorovar, Jaipur. The G-Schedule is enclosed for your reference. Consent of interested contractors with signed copy of G-Schedule should reach this office up to the last date i.e.10.03.2017 before 03.00 PM..

Enclosure:- G-Schedule

*[Signature]*  
3/3/2017  
Executive Engineer  
220 kv GSS Mansorovar  
RVPN, Jaipur

Copy submitted/forwarded to the following for information & n.a.


1. The Chief Engineer(T&C),RVPN, Jaipur with request to upload on Nigam's portal
2. The Supertending Engineer(T&C Jaipur City) RVPN Heerapura with request to upload on SPPP. Govt of Rajasthan.)
3. The Account Officer (T&C), Jaipur city, RVPN, Jaipur.
4. Notice Board.


*[Signature]*  
Executive Engineer  
220 kv GSS, Mansorovar  
RVPN, Jaipur

**"G" Schedule for painting work at 220KV GSS, Mansarovar**

S.No.	Description of Work	Area (m <sup>2</sup> )	Rate/m <sup>2</sup>	Amount
01	Supply of paint & painting of sub-station erected structures at 220KV GSS, Mansarovar. The surface shall be first ruffed with wire brush/emery paper to remove the dust & rust deposited on the structure surface then two coats of aluminium paints shall be applied one after another. The second coat will be applied after the first is dried completely. The paint used must be of an ISI brand i.e. Shalimar/Asian/Burger or equivalent.	3400 m <sup>2</sup>	Rs. 24.00	81600/-
02	Supply of paint & painting of sub-station equipments at 220KV GSS, Mansarovar The surface shall be first ruffed with wire brush/emery paper to remove the dust & rust deposited on the structure surface then two coats of enamel paints shall be applied one after another. The second coat will be applied after the first is dried completely. The paint used must be of an ISI brand i.e. Shalimar/Asian/Burger or equivalent.	200 m <sup>2</sup>	Rs. 25.00	5000/-
03	Supply of paint & painting of erected earth strips at 220KV GSS, Mansarovar. The surface shall be first ruffed with wire brush/emery paper to remove the dust & rust deposited on the structure surface then two coats of enamel paints shall be applied one after another. The second coat will be applied after the first is dried completely. The paint used must be of an ISI brand i.e. Shalimar/Asian/Burger or equivalent.	150 m <sup>2</sup>	Rs. 25.00	3750/-
	TOTAL			90350/-
	Add 60% above CLRC Rate			54210/-
	<b>Grand Total (Rs. One Lakh Forty Four Thousand Five Hundred Sixty Only)</b>			<b>1,44,560/-</b>

  
Junior Engineer (M)

  
Assistant Engineer(M)

  
Executive Engineer  
220 KV GSS Mansarovar