

G-schedule for maintenance work of transformers for the year 2017-18 at 220 KV GSS DAUSA (Part-B)

S. No.	Particulars	Numbers of transformers	Frequency of maintenance	Rate as per BSR -2011	Amount (Rs.)
				Nos.	Nos.
1.	<p>Maintenance of power transformers for the following types of power transformers. (All spares, lubricating material and only Special T&P shall be provided by RVPN. Cleaning material and general T&P shall be arranged by the contractor.)</p> <ul style="list-style-type: none"> a. Cleaning of porcelain of bushes. b. Checking of tightness of clamps & connectors. c. Cleaning of Buchholz and Oil surge relays. d. Cleaning of glasses of all oil level indicators. e. Cleaning of marshalling box, cooler control cubicle thermometer, etc. as provided. f. Assistance to RVPN in attending to oil leakage from transformer body & bushings. g. Checking of oil level in oil filled bushings. h. Checking of Drycol air drying system. i. Assistance to RVPN in measurement of IR values. j. Assistance to RVPN in measurement of Earth Resistance. k. Assistance to RVPN in testing of PRD. l. Assistance to RVPN in checking of tripping circuits of Buchholz & WDG, oil temperature controls and protection scheme. m. Checking of OLTC gear operations. 				

Devi...

...