

# RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED



(An ISO 9001:2000 Certified company)

Office of the Executive Engineer

220KV GSS RVPN, SEZ-I, JAIPUR.

Email:- [xen\\_220\\_sez\\_i\\_jaipur@rvpn.co.in](mailto: xen_220_sez_i_jaipur@rvpn.co.in) Phone-0141-2177441

## G-SCHEDULE

For Painting works of switch yard structure of 220 KV GSS, SEZ-I, Jaipur

Sr. No.	Description	Unit	Rates (as per BSR)	Area	Amount (as per BSR)
	Painting of Structure				
1	Aluminium Painting of unpainted steel structure of the GSS including paints & painting brush ,emery paper ,cloth and solvent etc. The surface shall be first cleaned with wire brush/ emery paper and there after wiped with cloth to remove rust and dust or any other deposits on erected MS steel structures and beams. One coat of red -oxide paint shall be applied after carrying out cleaning and allow to dry there after two coats of aluminium paints shall be applied each subsequent shall be applied only after the previous coat has dried up .The paints shall be from any of the following recognized manufactures namely Asian, Nerolac, berger, jonson-Nicholson etc.	SQM	31.00	938.972 SQM ( Details as per annexure -A)	Rs. 29108.13

As per the CLRC that is 60% above BSR =  $1.6 * 29108.13 = \text{Rs.}46573.01 =$

Rs.46573.00 only (R/O)

Details attached

  
**Executive Engineer**  
220 KV GSS, SEZ-I, JAIPUR