



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LTD.

(An ISO 9001:2008 Certified Company)

OFFICE OF THE ASSISTANT ENGINEER (132 KV GSS), SALASAR

Phone no. 01568 - 252182

email: - aen.132.salasar@rvpn.co.in

No.RRVPNL/AEN/132KVGSS/SLSR/Estt./D. 98

Dated. 14.09.2017

M/S All Enlisted Contractors Under
RVPNL/Jodhpur Zone

Sub. :- Acceptance of **Painting of Structure** at 132 KV GSS, Salasar (Churu) on CLRC rate as per G-Schedule.

On the above cited subject, it is intimated that for the **Steel Structure & Equipment's Painting work** at 132 KV GSS, Salasar to be awarded as per CLRC rate for the Year 2017-18. As you are enlisted firm under RVPNL Jodhpur Zone for this work at CLRC rate, please convey your acceptance for the above work latest by **20.09.2017** for further action in this regard.

If your acceptance is not received in mentioned period it will be presumed that you are not interested to carryout above work.

Enclose:- G-Schedule.

Assistant Engineer
132 KV GSS, Salasar

Copy to following for Information:-

- 01) The ZCE (T&C), RVPNL, Jodhpur
- 02) The S.E. (T&C), RVPNL, Ratangarh
- 03) The XEN (220 KV GSS), RVPNL, Sujangarh
- 04) The AO (T&C) RRVPNL, Ratangarh

Assistant Engineer
132 KV GSS, Salasar

G-Schedule for painting of old steel painted structure at 132 KV GSS, Salasar for the year 2017-18

No.	Description of work	Unit	Rate as per BSR in Rs.	Area in Sq. Mtr.	Total Amount in Rs.
1.	Aluminum painting of old painted steel structure at the GSS including the supply of paint and painting brush, emery paper, cloths and solvents etc. the surface shall be first cleaned with wire brush/ emery paper and thereafter wiped with cloth to remove rust and dust or any other deposit on erected M.S. steel structure. Two coats of aluminum shall be applied only after the previous coat has dried up. The paint used shall be from any of the following recognized manufacturer namely Asian/ Nerolac/Berger/Johnson Nicolson	Sq. Mtr.	32.00	729	23328.00
2.	Enamel painting of power transformer and other equipment's including supply of paint and spray painting set, emery paper, cloth and solvents etc. at GSS by cleaning surface thoroughly with soda/caustic solution to clean oily surface and thereafter washing with water. Thereafter two coats of smoke gray synthetic enamel paint shall be applied by spray method. Each subsequent coat shall be applied after the previous coat has fully dried up. The paints used shall be from any of the following recognized manufacturer namely Asian/ Nerolac/Berger/Johnson Nicholson. In case of surface area of radiators those fins will only be considered which are actually feasible and approachable for painting by spray or by brush.	Sq. Mtr.	33.00	650	21450.00
3.	Enamel painting on Marshalling Kiosks including supply of paint and spray painting set, emery paper, cloth and solvents etc. at GSS by cleaning surface thoroughly with soda/caustic solution to clean oily surface and thereafter washing with water. Thereafter two coats of smoke gray synthetic enamel paint shall be applied by spray method. Each subsequent coat shall be applied after the previous coat has fully dried up. The paints used shall be from any of the following recognized manufacturer namely Asian/ Nerolac/Berger/Johnson Nicholson.	Sq. Mtr.	25.00	50	1250.00
	Total				46028.00

Total Painting Area = **1429 Sq.Mtr.**

Total Amount (BSR) = **46028.00**

CLRC rate is 60% above BSR Total amount (CLRC) = **27616.80**

Grand Total
Say

Rs. 73644.80
Rs. 73645.00

(Rs. Seventy Three Thousand Six Hundred Forty Five only)

Junior Engineer (M)
132KV GSS, Salasar

Assistant Engineer
132 KV GSS, Salasar

Executive Engineer
220 KV GSS, Sujangarh

