

RAJASTHAN RAJYA VIDHYUT PRASARAN NIGAM LTD.

Office of the ASSISTANT ENGINEER, 132KV Grid Sub Station, RVPN, NPH Jodhpur [Corporate Identity Number(CIN): U40109RJ2000SGC016485] REGD. Office Vidhyut Bhawan Jyoti Nagar Jaipur 302005

email: aen.132nphjodhpur@rvpn.co.in

No. RRVPN/AEN/132kV GSS/NPH/Works./F....../D.

321

DATE: 07/03/2017

To

All the Registered Contractors, Jodhpur (T&C) Zone Notice board of 132kV GSS New Power House, Jodhpur.

Painting of the 33 kV Switch yard Steel Structures at 132kV GSS New Power House, Jodhpur as per the G-Schedule for the year

within 07days. above work, kindly send your consent along with the rates, as the CLRC rates are not applicable, as per the directions provided 132kV GSS New Power House, Jodhpur as per the G-Schedule for the quantity for the year 2016-17.If you are interested to perform the With reference to above subject this office is interested in performing the Painting of the Structures of the 33kV Switch Yard at

Thanking you.

ASSISTANT ENGINEER
132 KV GSS NEW POWER HOUSE, JODHPUR

Copy submitted to the following for information:

The Superintending Engineer (T&C), RRVPNL, Jodhpur.

The Executive Engineer (220) RVPNL, Jodhpur.

(3.) The Feeder Manager, RRVPNL, Jodhpur.

ASSISTANT ENGINEER
132 KV GSS NEW POWER HOUSE, JODHPUR



RAJASTHAN RAJYA VIDHYUT PRASARAN NIGAM LTD.

Office of the ASSISTANT ENGINEER, 132KV Grid Sub Station, RVPN, NPH Jodhpur [Corporate Identity Number(CIN): U40109RJ2000SGC016485] REGD. Office Vidhyut Bhawan Jyoti Nagar Jaipur 302005

email: aen.132nphjodhpur@rvpn.co.in Annexure-B

G-Schedule for the Painting of the 33 KV Switch-Yard Steel Structure of 132kV GSS New Power House, Jodhpur for the year 2016-17

| 0 | SCOPE OF WORK | OIY | FREQUENCY |
|-----|---|-------------|-----------|
| 9 | Painting of the Unpainted Steel Structure: Aluminium painting of the unpainted steel structure of the GSS including paint and painting brush, emery paper, cloth and solvent etc. The surface shall be first cleaned with the wire brush emery paper and thereafter wiped with cloth to remove rust and dust or any other deposits on erected | 421 sq mtr | 01 |
| | MS Steel structures and beams. One coat of Red Oxide shall be applied after carrying out the cleaning and allowed to dry. Thereafter two coats of aluminium paint shall be applied only after the previous coat. Each | | |
| | subsequent coat shall be applied only after the previous coat has dried up. The paints used shall be from any of | | |
| | the following recognised manufacturers namely Asian/Nerolac/Gerger/Johnson Nicholson. | | |
| 02. | Painting of the Old painted Steel Structure: Aluminium painting of old painted steel structure of the GSS 1680 sq mtr | 1680 sq mtr | 01 |
| | including supply of paint and painting brush, emery paper, cloth and solvent etc. The surface shall be first | | |
| | deposits on erected MS Steel structures and beams. Two coats of aluminium paint shall be applied only after the | | |
| | previous coat. Each subsequent coat shall be applied only after the previous coat has dried up. The paints used | | |

ASSISTANT ENGINEER

132 KV GSS NEW POWER HOUSE, JODHPUR