



Office of Assistant Engineer, 132 KV GSS, Banar					
G - Schedule for Structure Painting					
2011 BSR Item No.	Particulars	Unit	Rate (Rs.)	Qty.	Amount (Rs.)
2.1	PAINTING OF OLD PAINTED STEEL STRUCTURE : Aluminum painting of OLD painted steel structures of the GSS including supply of paint and painting brush, emery paper, cloth & solvent etc. The surface shall be first clean with by wire brush/emery paper & thereafter wiped with cloth to remove rust & dust or any other deposits on erected M.S steel structures & beams. Two coats of aluminum paint shall be applied. Each subsequent coat shall be applied only after previous coat has dried up. The paints used shall be from any of the following recognized manufacturer,	Sq.M.	24	3100	74400
Total					74400
Add 60% as per CLRC					44640
Total Amount					119040
Rupees One Lac Nineteen Thousand & Forty Only					

  
 JEN(M), 132 KV GSS  
 RVPN, Banar

  
 AEN, 132 KV GSS  
 RVPN, Banar