



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

(An ISO 9001:2015 Certified Company)

[Corporate Identity Number (CIN) U40109RJ2000SGC016485]

Regd. Office- Vidyut Bhawan, Jyoti Nagar, Jaipur-302005

Office of the Superintending Engineer (Proc-I)

Gate #3, Old Power House Premises, Near Ram Mandir, Banipark, Jaipur-302006

Tel : 0141-2208916 Fax : 2208916/2208921 E Mail se.tlpc@rvpn.co.in.

website: www.energy.rajasthan.gov.in/rvpnl

No. RVPN/SE/Proc.I/XEn-3/A-6/BN-9015002110/D.

556

Dated

27/08/2021

Amendment No.7

Notice for extension of e-bid under NIB No. PROC-I/NIB-2/2021-22/BN-9015002110


Following amendments in the Bid Document issued for procurement of 11 kV B&S Type Disc Insulators/ LRI under BN-9015002110 are hereby issued:

S. No.	Reference	Existing Provision	Amended Provision
1	Volume-II Clause 3.12 Type Tests	The type tests have been segregated in two parts i.e.3.12.A 'Essential Type Test' & 3.12.B 'Additional Type Test'.	The type tests have been segregated in two three parts i.e.3.12.A 'Essential Type Test', 3.12.B 'Additional Type Test' & 3.12.C 'Pollution Test'.
2	Volume-II Clause 3.12.C Type Tests	No provision	Clause No. 3.12.C "Pollution test": "In 3rd category, the bidder is required to furnish Artificial Pollution test by Salt Fog Method as per IS: 8704: 1995/ IEC: 60507: 1991 at their own cost. The Pollution test on disc insulators shall have to be conducted on suspension & tension disc insulators/ Long Rod Insulators, irrespective of electro-mechanical strength. The Artificial Pollution test by Salt Fog Method shall be conducted on salinity level of 14 to 40 kg/m ³ required for medium/moderately polluted atmosphere. This test shall not be insisted to be furnished alongwith the bid, but in case order is placed upon the bidder, the Pollution test by Salt Fog Method has to be furnished by the supplier before commencement of the supplies, conducted at some Govt. approved/ Govt. recognized/ Govt. Accredited laboratory. If this test is already conducted, the test reports must not older than 10 years as on the date of bid opening. For this purpose date of issue of type test report shall be considered. No extension of delivery period shall be granted on this account."

Page 1 of 2

S. No.	Reference	Existing Provision	Amended Provision
3	Schedule-DEL, Rate of supply for both 70kN & 120kN B&S type Disc Insulators/ Alternate: Porcelain Longrod Insulators	(i) 34 % quantity within three months from the date of issue of P.O. (ii) Next 33% quantity after three months and before six months from the date of issue of P.O. (iii) Balance 33% quantity after six months and before nine months from the date of issue of P.O.	(i) 34 % quantity within three four months from the date of issue of P.O. (ii) Next 33% quantity after three four months and before six seven months from the date of issue of P.O. (iii) Balance 33% quantity after six seven months and before nine months from the date of issue of P.O.

The above extension of e-bid notice is available on the web sites <http://energy.rajasthan.gov.in/rvpnl> and <https://sppp.rajasthan.gov.in>. Other terms & conditions shall remain the same.


 (V.P. Dhakar)
 Superintending Engineer (Proc.I)

