



**RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED**

(An ISO 9001:2008 Certified Company)  
[Corporate Identity Number (CIN) U40709RJ2000SGCC0164851]  
**Office of the Superintending Engineer (TLPC)**  
Old Power House Premises, Near Ram Mandir, Banipark, Jaipur-302 006  
Tel : 0141-2208916 Fax : 2208916/2208921

No. RVPN/SE/TLPC/PLCC/A-III /BN-3857/ D. 536 Dt. 15 JUN 2016

Corrigendum

Following corrigendum is hereby issued in the specification for Purchase of 48V Volt DC Distribution Board under BN-3857:

S.No.	Reference	Existing Provision	Corrigendum Provision
1	<b>2.01 Past Supply Criteria</b> Clause No. 2.01.4 at Page No. 59 under the "Annexure - (VI)"	<b>2.01.4</b> In support of fulfillment of the past supply criteria, the bidder shall furnish documentary evidence in the form of certificate from Chartered Accountant. This certificate should be either in original or copy duly attested by Notary. The bidder shall also sign and affix seal on the C.A. Certificate. The certificate should have membership number with the name & address of the chartered accountant. It should clearly indicate the quantity supplied, period of supply, voltage & Ampere capacity of the Battery chargers.	<b>2.01.4</b> In support of fulfillment of the past supply criteria, the bidder shall furnish documentary evidence in the form of certificate from Chartered Accountant. This certificate should be either in original or copy duly attested by Notary. The bidder shall also sign and affix seal on the C.A. Certificate. The certificate should have membership number with the name & address of the chartered accountant. It should clearly indicate the quantity supplied, period of supply, voltage & Ampere capacity of the DC Distribution Board.
2	<b>Bill of material and equipments to be mounted on 48V DCDB at page no.70 "Annexure - (VII)"</b>	2. 20 (Twenty) Nos. outgoing feeders consisting of Double Pole moulded case air circuit breaker quick action load break type rated for 10 Amps. 4. 20 (Twenty) Nos. Indicating lamps/LED'S (Group of four), MCCB FOR ON (RED) & OFF (GREEN) indication. 11 c). MCCB Trip (common for 20MCCB's).	2. 20 (Twenty) Nos. outgoing feeders consisting of Double Pole Miniature circuit breakers rated for 10 Amps. 4. 20 (Twenty) Nos. Indicating lamps/LED'S (Group of four), DP MCB FOR ON (RED) & OFF (GREEN) indication. 11 c). MCB Trip (common for 20 DP MCB's).

Other contents of the specification remain the same.

(G. Chhatwani)  
Superintending Engineer (TLPC)