



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED

(An ISO 9001:2008 Certified Company)

[Corporate Identity Number (CIN) U40109RJ2000SGC016485]

Office of the Superintending Engineer (Proc-1)

Old Power House Premises, Near Ram Mandir, Banipark, Jaipur-302 006

Tel : 0141-2208916 Fax : 2208916/ 2208921 Email : se.ilpc@rvpn.co.in

No. RVPN/SE/Proc.-1/Xen-3/A-5/BN-9015001603/ D. 15-21

Dated: 16/12/16

CORRIGENDUM

Following corrigendum in specification of 11 KV 70 KN & 120 KN DISC INSULATORS (BALL & SOCKET TYPE)/ PORCELAIN LONGROD INSULATORS under BN-9015001603 is hereby issued:

S. No.	CLAUSE NO.	EXISTING PROVISION OF SPECIFICATION	PROPOSED MODIFICATION
1.	Clause No. 23 in Schedule No. 1 at Pg-9, Appendix-V at Pg:78 & Clause No. 3 in Schedule IV A at Pg-87	In case IECMA changes the applicable formula for price variation for any item and issue guidelines for adopting the same during pendency of the contract, the new formula and guidelines shall become applicable for which no confirmation shall be taken from the supplier.	In case IECMA changes the applicable formula/indices for price variation during the pendency of the contract, and issue guidelines for adopting the same during pendency of the contract, the new formula and guidelines shall become applicable for which no confirmation shall be taken from the supplier, the same shall be applicable, provided if during pendency of the contract when both old and new price indices are being circulated, in such circumstances the lower of the price variation evaluated as per both old and new formula/indices, whichever shall be admissible to the supplier(s), and for the period from which The old indices are discontinued, the price variation shall be admissible as per the new PV formula with new indices.
2	Clause No. 3.01 of PQR (Schedule-II) at Pg-14	The bidder shall furnish valid and authenticated Type test certificate from a Govt. / a Govt. approved / a Govt. recognized / NABL accredited laboratory / ILAC i.e. International Laboratory Accreditation Cooperation (in case of foreign laboratory) of 70 KN, 120 KN Disc Insulators (B&S) Type/ porcelain Long Rod Insulators as required at Clause No.3.11 of Section-III of this specification, separately for each rating for which they are quoting the bid. Such type test certificate should not be older than 7 years as on the date of bid opening. For this purpose date of conducting type test will be considered.	The bidder shall furnish valid and authenticated Type test certificate from a Govt. / a Govt. approved / a Govt. recognized / NABL accredited laboratory / ILAC i.e. International Laboratory Accreditation Cooperation (in case of foreign laboratory), the type test reports should bear logo of NABL or ILAC MRAs whichever is applicable, of 70 KN, 120 KN Disc Insulators (B&S) Type/ porcelain Long Rod Insulators as required at Clause No.3.11 of Section-III of this specification, separately for each rating for which they are quoting the bid. Such type test certificate should not be older than 7 years as on the date of bid opening. For this purpose date of conducting type test will be considered.

Superintending Engineer(Proc-1)
RVPN, Jaipu

(Signature)
15/12