



**RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LIMITED**

(An ISO 9001:2008 Certified Company)  
 [Corporate Identity Number (CIN) U40109RJ2000SGC016485]  
**Office of the Superintending Engineer (Proc-1)**  
 Old Power House Premises, Near Ram Mandir, Banipark, Jaipur-302 006  
 Tel : 0141-2208916 Fax : 2208916/ 2208921 Email : se.ihpc@rvpn.co.in


No. RVPN/SE/Proc.-1/XEn-3/A-5/BN-9015001602/ D. 15/2/22 Dated: 16/12/16

**CORRIGENDUM**

Following corrigendum in specification of **HARDWARE CLAMPS & CONNECTORS FOR 132 KV & 220 KV SUB STATIONS** under BN-9015001602 is hereby issued:

S. No.	CLAUSE NO.	EXISTING PROVISION OF SPECIFICATION	PROPOSED MODIFICATION
1.	Clause No. 23 in Schedule No. 1 at Pg-11, Appendix-V at Pg.87 & Clause No. 4 in Schedule IV A at Pg-95	In case IECMA changes the applicable formula for price variation for any item and issue guidelines for adopting the same during pendency of the contract, the new formula and guidelines shall become applicable for which no confirmation shall be taken from the supplier.	In case IECMA changes the applicable formula/indices for price variation during the pendency of the contract for any item, and issue guidelines for adopting the same during pendency of the contract, the new formula and guidelines shall become applicable for which no confirmation shall be taken from the supplier. The same shall be applicable, provided if during pendency of the contract when both old and new price indices are being circulated, in such circumstances the lower of the price variation evaluated as per both old and new formula/indices, whichever shall be admissible to the supplier(s), and for the period from which the old indices are discontinued, the price variation shall be admissible as per the new PV formula with new indices.
2	Clause No. 3.01 of PQR (Schedule-II) at Pg-16	The bidder shall furnish valid and authenticated Type test certificate from a Govt./ a Govt. approved / a Govt. recognized / NABL accredited laboratory / ILAC i.e. International Laboratory Accreditation Cooperation (in case of foreign laboratory) of Hardware Clamps and Connectors as required at Clause No.3.7 of Section-III of this specification. Such type test certificate should not be older than 7 years as on the date of bid opening. For this purpose date of conducting type test will be considered.	The bidder shall furnish valid and authenticated Type test certificate from a Govt. / a Govt. approved / a Govt. recognized / NABL accredited laboratory / ILAC i.e. International Laboratory Accreditation Cooperation (in case of foreign laboratory), the type test reports should bear logo of NABL or ILAC whichever is applicable, of Hardware Clamps and Connectors as required at Clause No.3.7 of Section-III of this specification. Such type test certificate should not be older than 7 years as on the date of bid opening. For this purpose date of conducting type test will be considered.

3	Clause No. 3.7 in Section -III at Pg- 73	<p>The Bidder must furnish valid and authenticated type test reports for all type test specified in the latest editions of relevant ISS which should be from Govt. / Govt. approved/ Govt. recognized/ Govt. accredited/ NABL accredited/ ILAC i.e. International laboratory Accreditation Corporation (in case foreign laboratory). The drawing No. of the samples on which type tests were conducted should be clearly stated in the test report. A copy of the relevant detailed drawing indicating material, dimensions, weight etc. and duly signed and stamped by the testing authority should also be enclosed with the test report. The test should have been conducted on as many samples as specified in the ISS. The Bidder shall furnish a certificate to the effect that the material offered is identical in quality and performance with those given in test reports. Following type tests from Govt./Govt. approved / Govt. recognized/ Govt. accredited/ NABL accredited/ ILAC i.e. International laboratory Accreditation Corporation (in case foreign laboratory) shall be furnished by the bidder</p>	<p>The Bidder must furnish valid and authenticated type test reports for all type test specified in the latest editions of relevant ISS which should be from Govt. / Govt. approved/ Govt. recognized/ Govt. accredited/ NABL accredited/ ILAC i.e. International laboratory Accreditation Corporation (in case foreign laboratory), the type test reports should bear logo of NABL or ILAC MRA whichever is applicable. The drawing No. of the samples on which type tests were conducted should be clearly stated in the test report. A copy of the relevant detailed drawing indicating material, dimensions, weight etc. and duly signed and stamped by the testing authority should also be enclosed with the test report. The test should have been conducted on as many samples as specified in the ISS. The Bidder shall furnish a certificate to the effect that the material offered is identical in quality and performance with those given in test reports. Following type tests from Govt./Govt. approved / Govt. recognized/ Govt. accredited/ NABL accredited/ ILAC i.e. International laboratory Accreditation Corporation (in case foreign laboratory) shall be furnished by the bidder</p>
---	--	---	---

  
 (R.P. Gupta)  
 Superintending Engineer(Proc-1)  
 RVPN, Jaipur