



RAJASTHAN RAJYA VIDYUT PRASARAN NIGAM LTD
OFFICE OF THE CHIEF ENGINEER(MPT&S),RVPN,
HAWA SARAK, CIVIL LINES, JAIPUR- 302019
91-141-2291891 Fax No. 91-141-2291891
Email ce.mps@rvpn.co.in

NO.RVPN/CE (MPT&S)/Tech./F. /D. 248 Jaipur, Dated: 04.09.2017

CORRIGENDUM

The Technical Circular No.35 issued by this office regarding selection of over current setting vide No. 228 dated 21.08.2017 may be read as follows:

Definite time (DT) with delay of 100 msec. for over current may also be selected in the numerical relays.

a) For over current: - Reflected fault of 11 KV side on 33 KV side of 33/11 KV, 8 MVA transformers may be considered as 2500 Amp. (Primary Current).

mpu
4/9/17
(A.K. Gupta)

Addl. Chief Engineer (MPT&S)
RVPN. Jaipur.

Copy to the following for information & further necessary action:-

1. The Chief Engineer / Addl. Chief Engineer (MPT&S), RVPN, Ajmer / Jodhpur.
2. The Superintending Engineer (Prot.Engg.), RVPN, Jaipur.
3. The Superintending Engineer (MPT&S), RVPN, Jaipur/Kota/Udaipur/Ajmer/
Bikaner/Jodhpur.

mpu
4/9/17
Addl. Chief Engineer (MPT&S)
RVPN. Jaipur.