



प्रभास्मि शशि सूर्ययोः

CIN:U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED

office: Vidyut Bhawan, Janpath, Jyoti Nagar, Jaipur 302005

Website: www.energy.rajasthan.gov.in/jvvn

E-mail: jaipurdiscom@jvvn.org

OFFICE OF THE SUPERINTENDING ENGINEER (MM-II)

MM Building, Old Power House Premises,

Near Ram Mandir, Banipark, Jaipur-302006

Tel. 0141-2202607, E-Mail id:- semm2@jvvn.org



NO.JPD/SE/MM-II/SPO-V/TN-2616/D. 392

DATED: 27.5.2020

TN-2616

(SUPPLY OF MINI-TRUCK/ VAN MOUNTED SINGLE PHASE CENTRALIZED CONTROL UNIT CABLE FAULT LOCATING EQUIPMENT SUITABLE FOR LOCATING FAULT ON LOW /MEDIUM / HIGH VOLTAGE POWER CABLES UP TO 33 KV)

CORRIGENDUM No. 2

The figures 1500 Joules as appearing in Clause No. 6.3(b) of of Technical Specification (Section-III) be read as **2000 Joules or more**

बि.गुप्ता

(S.P.GUPTA)

SUPERINTENDING ENGINEER (MM-II)

Copy forwarded to the Superintending Engineer (IT), Jaipur Discom, Jaipur for arranging the hosting of above corrigendum at Nigam's website.

बि.गुप्ता 27.5.2020

SUPERINTENDING ENGINEER (MM-II)