

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER**  
**(PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail: seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 1513 Jaipur, Dated: 11/6/2020

The Superintending Engineer (O&M),  
Jaipur Discom,  
Baran.


**Sub:- Administrative approval for erection of 300 mtr S/C O/H line near NTPC Fatak for alternate supply of 33 KV Pachel kalan feeder, Distt.- Baran.**

विषय:- 33 के.वी. पचेल कलॉ फीडर की विद्युत आपूर्ति के लिए वैकल्पिक स्रोत के लिए 300 मीटर 33 के.वी. सिंगल सर्किट ओवरहेड लाइन एनटीपीसी फाटक के पास से खींचने के कार्य की प्रशासनिक स्वीकृति हेतु, जिला- बारों ।

Ref: - ZCE(O&M-KZ), Kota office letter no. 1161 dated 02.05.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- (i) Erection of 300 mtr. 33 KV S/C O/H line on ACSR Dog conductor T-off from 33 KV Pachel Kalan feeder (150 mtr on each side of railway tack) in order to utilize the spare 33 KV cable as an alternate source.

  
11.6.2020

(M.L. Gupta)  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (K/Z), Jaipur Discom, Kota.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
11.6.2020

Superintending Engineer  
(Plan & Montg.)