

Email/Fax

PC no. 1.0

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 1702 Jaipur, Dated: 14/8/2020.

The Superintending Engineer (O&M),
Jaipur Discom,
Bharatpur.

Sub:- Administrative approval for creation of 33/11 KV S/S at Peepla, P.S.-Sewar, Distt. Bharatpur.

विषय:- 33/11 के.वी. सब-स्टेशन पीपला, प.स.-सेवर, जिला- भरतपुर के निर्माण की प्रशासनिक स्वीकृति हेतु।


Ref:- Your office letter no. 1300 dated 08.06.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of Hon'ble Chairman, Discoms as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Creation of 1x5.0 MVA, 33/11 KV S/S at Peepla, P.S.- Sewar, Distt. Bharatpur with 03 nos. 11 KV outgoing feeders.
- (ii) Erection of 6.0 KM 33 KV S/C O/H line on ACSR Dog conductor T-off on 33 KV Jaghina feeder emanating from 220 KV GSS Bharatpur at a distance of 6.0 KM from 33/11 KV S/S Jaghina to proposed 33/11 KV S/S at Peepla.


Note:-

The bifurcation of 33 KV Sainthara feeder already approved vide this office letter no. 513(PC-10) dt. 05.4.2018 must be executed before creation of this S/S.


14.8.2020
(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (B/Z), Jaipur Discom, Bharatpur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


14.8.2020
Superintending Engineer
(Plan & Montg.)