

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvnl.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 1740 Jaipur, Dated: 24/8/2020

The Superintending Engineer (JPDC),
Jaipur Discom,
Jaipur.


Sub:- Revised administrative approval for 33 KV line for 33/11 KV S/S Lalgarh, Bassi, Distt. Jaipur (JPDC).

विषय:- 33/11 के.वी. सब-स्टेशन लालगढ़, बस्सी के लिए 33 के.वी लाइन की संशोधित प्रशासनिक स्वीकृति हेतु, जिला - जयपुर (जयपुर जिला वृत्त)

Ref: - SE(JPDC) office letter no. 1907 dated 27.07.2020.


In consideration of the proposal furnished vide letter under reference, I am directed to convey the revised administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Conversion of the existing 1.0 KM 33 KV S/C O/H line of Bhudla feeder on 33 KV lattice towers(42') to convert it into 33 KV D/C O/H line.
- (ii) Conversion of the existing 2.7 KM 11 KV O/H line into composite line by erecting 33 KV Towers.
- (iii) Erection of 4.8 Kms. 33 KV O/H line on ACSR Dog Conductor from previously erected 33 KV line to 33/11 KV S/S Lalgarh to utilize already existing 800 mtr 33 KV O/H Line erected against 2386(PC-38) dt. 23.06.1010


(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)