

Email/Fax

PC no. 19

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 1741 Jaipur, Dated: 24/8/2020

The Superintending Engineer (O&M),
Jaipur Discom,
Dausa.

Sub:- Revised administrative approval for 33 KV line for 33/11 KV S/S Chudiyawas,
Distt.-Dausa.


विषय:- 33/11 के.वी. सब-स्टेशन चूड़ियावास के लिये 33 के.वी. लाइन के कार्य की संशोधित
प्रशासनिक स्वीकृति हेतु, जिला- दौसा ।

Ref: - Your office letter no.1861 dated 05.08.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- i) Erection of 3.42 Km 33 KV S/C O/H line on ACSR Dog conductor plus 80 mtrs 33 KV D/C 3x300 sqmm.U/G XLPE cable (for NH 11-A By pass road crossing) from 33/11 KV S/S Nangal Rajawtan to proposed 33/11 KV S/S Chudiyawas.

Note:- The point no. (ii) of previous administrative approval issued vide this office letter no. 497 (PC No.-03) dt. 03.04.18 is hereby withdrawn.


24.8.2020
(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


24.8.2020
Superintending Engineer
(Plan & Montg.)